

# **Evaluation of the Start-Up Core Physics Tests at Japan's High Temperature Engineering Test Reactor (Annular Core Loadings)**

John D. Bess  
Nozomu Fujimoto  
James W. Sterbentz  
Luka Snoj  
Atsushi Zukeran

March 2010

The INL is a U.S. Department of Energy National Laboratory  
operated by Battelle Energy Alliance



# **Evaluation of the Start-Up Core Physics Tests at Japan's High Temperature Engineering Test Reactor (Annular Core Loadings)**

**John D. Bess  
Nozomu Fujimoto<sup>1</sup>  
James W. Sterbentz  
Luka Snoj<sup>2</sup>  
Atsushi Zukeran<sup>3</sup>**

<sup>1</sup>Japan Atomic Energy Agency

<sup>2</sup>Jozef Stefan Institute

<sup>3</sup>Senior Reactor Physics Consultant

**March 2010**

**Idaho National Laboratory  
Idaho Falls, Idaho 83415**

**<http://www.inl.gov>**

**Prepared for the  
U.S. Department of Energy  
Office of Nuclear Energy  
Under DOE Idaho Operations Office  
Contract DE-AC07-05ID14517**

**EVALUATION OF THE START-UP CORE PHYSICS TESTS AT  
JAPAN'S HIGH TEMPERATURE ENGINEERING TEST REACTOR  
(ANNULAR CORE LOADINGS)**

**Evaluators**

**John D. Bess  
Idaho National Laboratory**

**Nozomu Fujimoto  
Japan Atomic Energy Agency**

**Internal Reviewers  
James W. Sterbentz  
Idaho National Laboratory**

**Independent Reviewers**

**Luka Snoj  
Jozef Stefan Institute**

**Atsushi Zukeran  
Senior Reactor Physics Consultant**

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

## Status of Compilation / Evaluation / Peer Review

Section 1	Compiled	Independent Review	Working Group Review	Approved
1.0 DETAILED DESCRIPTION	YES	YES	YES	YES
1.1 Description of the Critical and / or Subcritical Configuration	YES	YES	YES	YES
1.2 Description of Buckling and Extrapolation Length Measurements	NA	NA	NA	NA
1.3 Description of Spectral Characteristics Measurements	NA	NA	NA	NA
1.4 Description of Reactivity Effects Measurements	YES	YES	YES	YES
1.5 Description of Reactivity Coefficient Measurements	NA	NA	NA	NA
1.6 Description of Kinetics Measurements	NA	NA	NA	NA
1.7 Description of Reaction-Rate Distribution Measurements	YES	YES	YES	YES
1.8 Description of Power Distribution Measurements	NA	NA	NA	NA
1.9 Description of Isotopic Measurements	NA	NA	NA	NA
1.10 Description of Other Miscellaneous Types of Measurements	NA	NA	NA	NA
Section 2	Evaluated	Independent Review	Working Group Review	Approved
2.0 EVALUATION OF EXPERIMENTAL DATA	YES	YES	YES	YES
2.1 Evaluation of Critical and / or Subcritical Configuration Data	YES	YES	YES	YES
2.2 Evaluation of Buckling and Extrapolation Length Data	NA	NA	NA	NA
2.3 Evaluation of Spectral Characteristics Data	NA	NA	NA	NA
2.4 Evaluation of Reactivity Effects Data	YES	YES	YES	YES
2.5 Evaluation of Reactivity Coefficient Data	NA	NA	NA	NA
2.6 Evaluation of Kinetics Measurements Data	NA	NA	NA	NA
2.7 Evaluation of Reaction Rate Distributions	YES	YES	YES	YES
2.8 Evaluation of Power Distribution Data	NA	NA	NA	NA
2.9 Evaluation of Isotopic Measurements	NA	NA	NA	NA
2.10 Evaluation of Other Miscellaneous Types of Measurements	NA	NA	NA	NA

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

<b>Section 3</b>	<b>Compiled</b>	<b>Independent Review</b>	<b>Working Group Review</b>	<b>Approved</b>
3.0 BENCHMARK SPECIFICATIONS	YES	YES	YES	YES
3.1 Benchmark-Model Specifications for Critical and / or Subcritical Measurements	YES	YES	YES	YES
3.2 Benchmark-Model Specifications for Buckling and Extrapolation Length Measurements	NA	NA	NA	NA
3.3 Benchmark-Model Specifications for Spectral Characteristics Measurements	NA	NA	NA	NA
3.4 Benchmark-Model Specifications for Reactivity Effects Measurements	YES	YES	YES	YES
3.5 Benchmark-Model Specifications for Reactivity Coefficient Measurements	NA	NA	NA	NA
3.6 Benchmark-Model Specifications for Kinetics Measurements	NA	NA	NA	NA
3.7 Benchmark-Model Specifications for Reaction-Rate Distribution Measurements	YES	YES	YES	YES
3.8 Benchmark-Model Specifications for Power Distribution Measurements	NA	NA	NA	NA
3.9 Benchmark-Model Specifications for Isotopic Measurements	NA	NA	NA	NA
3.10 Benchmark-Model Specifications of Other Miscellaneous Types of Measurements	NA	NA	NA	NA
<b>Section 4</b>	<b>Compiled</b>	<b>Independent Review</b>	<b>Working Group Review</b>	<b>Approved</b>
4.0 RESULTS OF SAMPLE CALCULATIONS	YES	YES	YES	YES
4.1 Results of Calculations of the Critical or Subcritical Configurations	YES	YES	YES	YES
4.2 Results of Buckling and Extrapolation Length Calculations	NA	NA	NA	NA
4.3 Results of Spectral Characteristics Calculations	NA	NA	NA	NA
4.4 Results of Reactivity Effect Calculations	YES	YES	YES	YES
4.5 Results of Reactivity Coefficient Calculations	NA	NA	NA	NA
4.6 Results of Kinetics Parameter Calculations	NA	NA	NA	NA
4.7 Results of Reaction-Rate Distribution Calculations	YES	YES	YES	YES
4.8 Results of Power Distribution Calculations	NA	NA	NA	NA
4.9 Results of Isotopic Calculations	NA	NA	NA	NA
4.10 Results of Calculations of Other Miscellaneous Types of Measurements	NA	NA	NA	NA
<b>Section 5</b>	<b>Compiled</b>	<b>Independent Review</b>	<b>Working Group Review</b>	<b>Approved</b>
5.0 REFERENCES	YES	YES	YES	YES
Appendix A: Computer Codes, Cross Sections, and Typical Input Listings	YES	YES	YES	YES

## EVALUATION OF THE START-UP CORE PHYSICS TESTS AT JAPAN'S HIGH TEMPERATURE ENGINEERING TEST REACTOR (ANNULAR CORE LOADINGS)

**IDENTIFICATION NUMBER:** HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

**KEY WORDS:** annular cores, critical configurations, graphite-moderated, graphite-reflected, helium coolant, HTTR, low enriched uranium (LEU), pin-in-block fuel, prismatic fuel, thermal reactor, TRISO, uranium oxide fuel

### SUMMARY INFORMATION

#### 1.0 DETAILED DESCRIPTION

The High Temperature Engineering Test Reactor (HTTR) of the Japan Atomic Energy Agency (JAEA) is a 30 MWth, graphite-moderated, helium-cooled reactor that was constructed with the objectives to establish and upgrade the technological basis for advanced high-temperature gas-cooled reactors (HTGRs) as well as to conduct various irradiation tests for innovative high-temperature research. The core size of the HTTR represents about one-half of that of future HTGRs, and the high excess reactivity of the HTTR, necessary for compensation of temperature, xenon, and burnup effects during power operations, is similar to that of future HTGRs. During the start-up core physics tests of the HTTR, various annular cores were formed to provide experimental data for verification of design codes for future HTGRs (Ref. 1, p. 310).

The Japanese government approved construction of the HTTR in the 1989 fiscal year budget; construction began at the Oarai Research and Development Center in March 1991 and was completed May 1996. Fuel loading began July 1, 1998, from the core periphery. The first criticality was attained with an annular core on November 10, 1998 at 14:18, followed by a series of start-up core physics tests (Figure 1.1) until a fully-loaded core was developed on December 16, 1998. Criticality tests were carried out into January 1999. The first full power operation with an average core outlet temperature of 850°C was completed on December 7, 2001, and operational licensing of the HTTR was approved on March 6, 2002. The HTTR attained high temperature operation at 950 °C in April 19, 2004. After a series of safety demonstration tests, it will be used as the heat source in a hydrogen production system by 2015 (Ref. 3, pp. 12-14).

Hot zero-power critical,<sup>a</sup> rise-to-power,<sup>b</sup> irradiation,<sup>c</sup> and safety demonstration testing<sup>de</sup> have also been performed with the HTTR, representing additional means for computational validation efforts. Power tests were performed in steps from 0 to 30 MW, with various tests performed at each step to confirm core

---

<sup>a</sup> J. C. Kuijper, X. Raepsaet, J. B. M. de Haas, W. von Lense, U. Ohlig, H.-J. Ruetten, H. Brockmann, F. Damian, F. Dolci, W. Bernnat, J. Oppe, J. L. Kloosterman, N. Cerullo, G. Lomonaco, A. Negrini, J. Magill, and R. Seiler, "HTGR Reactor Physics and Fuel Cycle Studies," *Nucl. Eng. Des.*, **236**: 615-634 (2006).

<sup>b</sup> S. Nakagawa, Y. Tachibana, K. Takamatsu, S. Ueta, and S. Hanawa, "Performance Test of HTTR," *Nucl. Eng. Des.*, **233**: 291-300 (2004).

<sup>c</sup> T. Shibata, T. Kikuchi, S. Miyamoto, and K. Ogura, "Assessment of Irradiation Temperature Stability of the First Irradiation Test Rig in the HTTR," *Nucl. Eng. Des.*, **223**: 133-143 (2003).

<sup>d</sup> Y. Tachibana, S. Nakagawa, T. Takeda, A. Saikusa, T. Furusawa, K. Takamatsu, K. Sawa, and T. Iyoku, "Plan for the First Phase of Safety Demonstration Tests of the High Temperature Engineering Test Reactor (HTTR)," *Nucl. Eng. Des.*, **224**: 179-197 (2003).

<sup>e</sup> S. Nakagawa, K. Takamatsu, Y. Tachibana, N. Sakaba, and T. Iyoku, "Safety Demonstration Tests using High Temperature Engineering Test Reactor," *Nucl. Eng. Des.*, **233**: 301-308 (2004).

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

characteristics, thermal-hydraulic properties, and radiation shielding (Ref. 4, p. 284). The high-temperature test operation at 950 °C represented the fifth and final phase of the rise-to-power tests.<sup>a</sup> The safety tests demonstrated inherent safety features of the HTTR such as slow temperature response during abnormal events due to the large heat capacity of the core and the negative reactivity feedback.<sup>b</sup>

The experimental benchmark performed and currently evaluated in this report pertains to the data available for the annular core criticals from the initial six isothermal, annular and fully-loaded, core critical measurements performed at the HTTR. Evaluation of the start-up core physics tests specific to the fully-loaded core is compiled elsewhere (HTTR-GCR-RESR-001).




Figure 1.1. Progress of Start-Up Core Physics Tests.<sup>c</sup>

## 1.1 Description of the Critical and / or Subcritical Configuration

### 1.1.1 Overview of Experiment

The initial start-up core physics tests for the High Temperature Engineering Test Reactor were performed between the months of July 1998 and January 1999. The HTTR facility is at the Oarai Research and Development Center of the JAEA.

<sup>a</sup> S. Fujikawa, H. Hayashi, T. Nakazawa, K. Kawasaki, T. Iyoku, S. Nakagawa, and N. Sakaba, "Achievement of Reactor-Outlet Coolant Temperature of 950 °C in HTTR," *J. Nucl. Sci. Tech.*, **41**(12): 1245-1254 (December 2004).

<sup>b</sup> S. Nakagawa, D. Tochio, K. Takamatsu, M. Goro, and T. Takeda, "Improvement of Analysis Technology for High Temperature Gas-Cooled Reactor by using Data Obtained in High Temperature Engineering Test Reactor," *J. Power Energy Syst.*, **2**(1): 83-91 (2008).

<sup>c</sup> "Present Status of HTGR Research and Development," Japan Atomic Energy Research Institute, Tokaimura, March 2004.

First criticality was attained on November 10, 1998, and the core was fully loaded in December 1998. During the fuel loading period, various tests were conducted under cold clean conditions as the start-up core physics tests. During these tests, the power was limited to below 30 W and the helium pressure was 1 bar. The tests for the critical approach, excess reactivity, shutdown margin, neutron flux distribution and control rod worth were conducted ([Ref. 4, p. 284](#)). Elsewhere the pressure is listed as 1 atmosphere ([Ref. 1, p. 312](#)). One atmosphere is equal to  $1.01325 \times 10^5$  Pa, or 1.01325 bar.

Of the initial six isothermal, annular and fully-loaded, core critical measurements that were performed, only the annular core loadings were evaluated in this benchmark analysis. The maximum uncertainty range is between -1.03 and +1.00 %  $\Delta k$  ( $1\sigma$ ) for the 19-fuel-column core, with a decrease in the uncertainty as graphite dummy blocks are replaced by fuel blocks in the core. Dominant uncertainties are the impurities in the IG-110 graphite blocks, PGX graphite reflector blocks, and IG-11 graphite dummy blocks. Comprehensive biases could not be completed for all aspects of this experiment.

Currently the calculations performed using the benchmark models have a  $k_{\text{eff}}$  between 1.4 to 2.7 % of the experimental benchmark value and within  $3\sigma$ , except for configuration 4, which is within  $4\sigma$ . It is currently difficult to obtain the necessary information to further improve the confidence in the benchmark model and effectively reduce the overall uncertainty; the necessary data is proprietary and its released is being restricted, because the benchmark configuration of the HTTR core is the same that is currently in operation. Once this information is made available, the HTTR benchmark can be adjusted as appropriate.

### **1.1.2 Geometry of the Experiment Configuration and Measurement Procedure**


The geometric information publicly available for this benchmark can be found compiled in Section 1.1.2 of [HTTR-GCR-RESR-001](#).

#### **1.1.2.1 Description of Criticality Measurements**

Before fuel loading, the whole region in the core was filled with graphite dummy blocks. Helium gas was filled up to 1 atm at room temperature. Dummy blocks were replaced with fuel blocks, column by column, in the fuel loading, starting from the core periphery to the center, as shown in Figure 1.2.



## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATEFigure 1.2. Loading Pattern of the HTTR (Redrawn from [Ref. 1, p. 313](#)).

In the first phase of fuel loading, six fuel columns were loaded consecutively. In the second phase, three fuel columns were loaded at a time, until a total of 15 columns were in the core. In the third phase of fuel loading, columns were loaded one at a time, so as to identify the number of fuel columns needed for the first criticality. In every loading phase, all control rods were withdrawn from the core after each fuel loading, and inverse multiplication factors were measured. Initial criticality was achieved with 19 fuel columns loaded. Symmetric annular cores were formed at 21-, 24-, and 27-fuel-column loaded cores. The fully-loaded core consists of 30 fuel columns. Figure 1.3 shows some of the fuel-loading steps during the initial core loading ([Ref. 4, p. 285](#)).




Figure 1.3. Critical Approach at Room Temperature using the Fuel Addition Method (Ref. 4, p. 285).

The inverse neutron multiplication factor was monitored in order to observe the approach to criticality; the core was regarded as critical when the neutron flux was self-sustained after removing the temporary neutron source. After the initial criticality, reactivity increase was measured using the IK (Inverse Kinetics) method. The excess reactivity of the core was then obtained by adding all increments of the reactivity from the first criticality to the fully-loaded core (Ref. 2, p. 14).

Inverse multiplication factors were evaluated at 0, 6, 9, 12, 15, 16, 17, and 18 fuel-column-loaded cores to predict the first criticality (Ref. 2, p. 39). The inverse multiplication data were recorded and are shown in Figure 1.4.




Figure 1.4. Inverse Multiplication Data for the Initial Approach to Critical of the HTTR.<sup>a</sup>

During the first approach to critical (after loading the 19<sup>th</sup> fuel assembly) the source criticality at very low power was achieved. Then the neutron source was removed and the central control rod moved to compensate for the change in reactivity. The first criticality of the reactor was attained on November 10, 1998. Figure 1.5 shows the result of the reactivity measurements during this approach to critical (Ref. 2, p. 113).

<sup>a</sup> "Present Status of HTGR Research and Development," Japan Atomic Energy Research Institute, Tokaimura, March 2004.




Figure 1.5. Initial Approach to Criticality Reactivity Measurements (Ref 2, p. 114).

The control rod (CR) positions are provided in Table 1.1 for the critical conditions of the annular and fully-loaded cores. The CR pairs were named center (C), ring 1 (R1), ring 2 (R2), and ring 3 (R3) from the center to the outside as shown in Figure 1.2 (also see Section 3.1.2.11 and Figure 3.17). Both R2 and R3 CRs are in the replaceable reflector region surrounding the core, where the six CR pairs on the sides of the hexagonal loading pattern are R2 CRs and the three remaining CR pairs at corners of the hex are R3 CRs. The C-CR was inserted into the 19-column core to adjust initial criticality while the other CRs were fully withdrawn (Ref. 1, p. 317).

All control rod insertion levels are adjusted on the same level except for the three pairs of control rods in the most outer region in the side reflectors. These three pairs of CRs are usually fully withdrawn (Ref. 2, p. 40).

There were two CR patterns used for the 24-fuel-column core. The first was the flat standard (FS) pattern, where the C, R1, and R2 CRs were inserted into the core at the same height, and the R3 CRs were fully withdrawn. The second pattern was the F23 pattern, where the R2 and R3 CRs in the side reflector were inserted into the core at the same height and the C and R1 CRs were fully withdrawn. The F23 pattern was used to simulate the control of future HTGRs, where the reflector CRs would mainly be

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

used for reactivity control. The effective multiplication factors for the measured CR positions at critical conditions were evaluated for different annular cores and temperatures. The results in Table 1.1 are adjusted such that the multiplication factors could be evaluated at 27 °C, 300 K (Ref. 1, pp. 317-318).

A simpler statement for control rod positions of four of the critical cases is shown in Table 1.2, representing the average for rods C, R1, and R2 (with R3 completely withdrawn).

Effective corrections to critical rod position in the core include a sinking effect from the CR driving mechanism of about -14 mm and a temperature expansion effect of about +2 mm from 25 to 27 °C (Ref. 2, p. 46). Reported Japanese data typically had the sinking effect already accounted for in the reported rod positions.

Control rods positions were defined with distance from the bottom of the fifth fuel layer (Ref. 1, p. 317).

Table 1.1. Measured Control Rod Positions for Critical Conditions (Ref. 1, p. 318).

Case	Fuel Columns	Temperature (°C)	$k_m^{(a)}$	Critical Rod Position (mm) <sup>(b)</sup>				Remark <sup>(c)</sup>
				C	R1	R2	R3	
1	19	23	1.00049	1739	4050	3325	4050	C
2	21	24	1.00037	2647	2645	2646	4049	FS
3	24	24	1.00037	2213	2215	2215	4049	FS
4	24	24	1.00037	4051	4050	1593	1592	F23
5	27	24	1.00037	1901	1899	1899	4050	FS
6	30	25	1.00025	1775	1775	1775	4049	FS

- (a) Measured  $k_m$  has been corrected with the measured temperature coefficient (TC) for the 30-fuel-column core [ $-1.23 \times 10^{-4}$  ( $\Delta k/k/^\circ\text{C}$ ) to 27 °C (300 K)]. It was assumed that use of the TC for the 30-fuel-column core was practically still useful for the other cores because of the small temperature difference of <4 °C.
- (b) Nominally fully withdrawn positions of C, R1, and R3 CRs are 4060 mm and that of the R2 CRs is 3335 mm.
- (c) C = criticality obtained using central control rod only. FS = flat standard pattern where C, R1, and R2 CRs were inserted into the core at the same levels while R3 CRs were fully withdrawn. F23 = only R2 and R3 CRs were used for control while C and R1 CRs were fully withdrawn.

Table 1.2. Average Control Rod Positions for Critical Conditions (Ref. 2, p. 40).

Fuel Column	21 (Case 2)	24 (Case 3)	27 (Case 5)	30 (Case 6)
Rod Position (mm)	2646 ± 5	2215 ± 5	1899 ± 5	1775 ± 5

### 1.1.3 Material Data

The material data publicly available for this benchmark can be found compiled in Section 1.1.3 of [HTTR-GCR-RESR-001](#).

### 1.1.4 Temperature Data

The core is at room temperature ([Ref. 2, p. 14](#)). Table 1.1 provides the temperature of the experiment for each of the six critical configurations, ranging between 23 and 25°C.

### 1.1.5 Additional Information Relevant to Critical and Subcritical Measurements

Additional information is not available.

## 1.2 Description of Buckling and Extrapolation Length Measurements

Buckling and extrapolation length measurements were not made.

## 1.3 Description of Spectral Characteristics Measurements

Spectral characteristics measurements were not made.

## 1.4 Description of Reactivity Effects Measurements

After the initial criticality the excess reactivity of the core was then obtained by adding all increments of the reactivity from the first criticality to the fully-loaded core ([Ref. 2, p. 14](#)).

Further information regarding the measurement of excess reactivity of the annular core configurations is provided in Section 1.4.2.1 of [HTTR-GCR-RESR-001](#).

## 1.5 Description of Reactivity Coefficient Measurements

Reactivity coefficient measurements were not made.

## 1.6 Description of Kinetics Measurements

Kinetics measurements were not made.

## 1.7 Description of Reaction-Rate Distribution Measurements

### 1.7.1 Overview of Experiment

The axial reaction rate profile in the instrumentation columns has been evaluated for this benchmark configuration.



## 1.7.2 Geometry of the Experiment Configuration and Measurement Procedure

The geometry of the core is that of the fully-loaded core configuration in Section 1.1.2 with modifications as stated below.

### 1.7.2.1 Axial Reaction Rate Distribution

The fission reaction rate of  $^{235}\text{U}$  was regarded as a neutron flux distribution because the neutron flux distribution could not be directly measured in the HTTR core. The three micro fission chambers (FCs) placed in the irradiation test columns were used to measure the axial reaction rate. The FCs are 5 cm long with a diameter of 0.6 cm. A FC was connected to the end of a long aluminum stick such that it could be axially traversed by moving the stick in the aluminum tube well inserted into the holes of the irradiation test columns. The temporary neutron source was withdrawn from the core during measurements. The reaction rates were then measured at several points around the peak of the reaction rate distribution to search for the peak. The reactor power was changed by the movement of the FC because reactivity was added by movement of the attached stick and cable, which caused a change in the reaction rates of the FCs. The reaction rate of the traversing FC was then normalized with the reaction rate of the FC fixed in another irradiation test column. The axial fission reaction rate distributions were measured for the 24- and 30-fuel-column cores. Both FS and F23 patterns were formed in the 24-fuel-column core. The experimental error of the neutron flux was  $\sim 0.2\%$ , and was evaluated from the number of FC pulse counts. Measured distributions are shown (compared with some of Japan's calculated results) in Figure 1.6 ([Ref. 1, pp. 317-318](#)).

The reaction rate for the 30-fuel-column core configuration is evaluated in [HTTR-GCR-RESR-001](#), as it represents measurements performed using the fully-loaded core configuration of the HTTR.




Figure 1.6. Axial Reaction Rate Distribution in Irradiation Column for 24- and 30-Fuel-Column Cores (Ref. 1, p. 318). F23 and FS are defined in the footnote of Table 1.1. The 30-fuel-column core reaction-rate measurements are evaluated in [HTTR-GCR-RESR-001](#).



### **1.7.3 Material Data**

The materials in the core were those described in the fully-loaded core configuration in Section 1.1.3 with modifications as stated below.

### **1.7.4 Temperature Data**

Experiments were essentially performed at room temperature.

### **1.7.5 Additional Information Relevant to Reaction-Rate Distribution Measurements**

Additional information is not available.

## **1.8 Description of Power Distribution Measurements**

Power distribution measurements were not made.

## **1.9 Description of Isotopic Measurements**

Isotopic measurements were not made.

## **1.10 Description of Other Miscellaneous Types of Measurements**

Other miscellaneous types of measurements were not made.

## 2.0 EVALUATION OF EXPERIMENTAL DATA

The overall uncertainty in the calculated value of  $k_{\text{eff}}$ , which is a function of multiple input parameters, is given by<sup>a</sup>

$$u_c^2(k_{\text{eff}}) = \sum_{i=1}^N (\Delta k_i)^2 + 2 \sum_{i=1}^{N-1} \sum_{j=i+1}^N (\Delta k_i)(\Delta k_j)r_{i,j} . \quad (2.1)$$

In Equation 2.1,  $\Delta k_i$  is the change in  $k_{\text{eff}}$  when parameter  $i$  is changed by the standard deviation in the parameter, and  $r_{i,j}$  is the correlation coefficient for parameters  $i$  and  $j$ .

Where standard deviations are available, they are used for calculating the effects these uncertainties might have on  $k_{\text{eff}}$ , in terms of  $\Delta k_i$ . Where observed ranges are given, but not standard deviations, the limiting values of the observed ranges are usually applied, and plausible distribution functions are assumed for finding  $\Delta k_i$ . Where only tolerances are given, their limiting values are used, along with plausible distribution functions. Where no guidance is given on the variability of a parameter, engineering judgment is used to select a range of variation that will produce the largest reasonable uncertainty in  $k_{\text{eff}}$ . The bounding values in this range are then applied in the uncertainty analysis. If the overall uncertainty in  $k_{\text{eff}}$  predicted by this approach is small enough that the experiment can be judged an acceptable benchmark, one can be confident that the real experiment is actually even better. All uncertainties are adjusted to values of one standard deviation ( $1\sigma$ ). No information is available on correlations among parameters, so all parameters and their uncertainties are assumed to be uncorrelated.

Usually, no information is publicly available about the distribution function of the deviation of a parameter from its nominal value. In most cases, it is reasonably assumed that the most relevant quantity is uniformly distributed. For example, if the change in  $k_{\text{eff}}$  from its nominal value is dependent on the change in the volume of a spatial region, then it is assumed that the deviation of the volume of that region from its nominal value is uniformly distributed.

The uncertainty analyses were performed in accordance with guidance provided in the ICSBEP Handbook.

It should be noted that assuming a uniform distribution of a parameter between its limits leads to overprediction of the effect on  $k_{\text{eff}}$ .

These observations are used repeatedly in the following analysis.

The following sections discuss the calculation of the effects of uncertainties in the parameters listed in tables in each section. The values of the tabulated parameters are computed in the benchmark critical configuration and in the configuration with each parameter assigned its maximum variation (or its standard deviation when available), one parameter at a time. The bases for the choices of the parameter values are discussed.

In all cases where tolerances or observed variations apply to large numbers of objects, such as TRISO fuel particles, both deterministic (or systematic) uncertainties (applying to all the objects equally) and random uncertainties (different from one object to the next) will occur. For the fuel particles and their subregions especially, the random uncertainties are extremely small (i.e., the tolerance limit for the random uncertainty divided by the square root of the number of fuel particles in the core). In all cases, division by such large numbers would make the random component of the uncertainty negligible.

---

<sup>a</sup> *International Handbook of Evaluated Criticality Safety Benchmark Experiments*, NEA/NSC/DOC(95)03/I-VIII, OECD-NEA, "ICSBEP Guide to the Expression of Uncertainties," Revision 1, p. 29, September 30, 2004.

Positional dependence of objects within the assembly also influences the effective proportional effect on the resultant uncertainty and bias calculations. However, since no information is available about how the uncertainties are divided between the systematic and random components, it is assumed throughout that the uncertainties are 25 % systematic and 75 % random for all uncertainties that exhibit a random component.

This assumption provides a basic prediction of the effect on  $k_{\text{eff}}$  until additional information regarding systematic uncertainties can be better evaluated. The 25 % systematic uncertainty is bound by the fact that most systematic uncertainties would be below 50 % of the total uncertainty and above the historic approach of ignoring the unknown systematic components (i.e., treat it with a 0 % probability). In actuality, careful experimenters may have an unknown systematic uncertainty that is approximately 10-15 % of their total reported uncertainty. Evaluated uncertainties are listed as calculated, such that the readers may themselves adjust results according to some desired systematic-to-random uncertainty ratio. The summary in Section 2.1.7 does list the systematic and random components of the uncertainty as separate entities based on the assumption that uncertainties with random components have 25 % systematic uncertainty.

It is important to note that most parameters regarding the TRISO particles are normally distributed.

## 2.1 Evaluation of Critical and / or Subcritical Configuration Data

In the preliminary Japanese computational evaluation, the predicted number of fuel columns to achieve criticality was  $16 \pm 1$ , much less than the experimental result of 19. It was regarded that the neglect of nitrogen in the porous graphite led to this discrepancy. Two reevaluations were carried out after the initial criticality experiment (Ref. 1, pp. 313-314). The first reevaluation examined the air content in the graphite, simplification of graphite geometry, and impurity concentration in the dummy blocks. The predicted number of fuel columns for initial criticality was changed to  $18 \pm 1$ .<sup>a</sup> The second reevaluation wasn't performed until after the full power tests at 30 MW and 850 °C. Heterogeneity effects and air composition in the graphite was analyzed; the reevaluation also predicted  $18 \pm 1$  fuel columns for initial criticality.<sup>b</sup>

Monte Carlo n-Particle (MCNP) version 5.1.40 calculations were utilized to estimate the biases and uncertainties associated with the experimental results for HTTR critical configurations in this evaluation. MCNP is a general-purpose, continuous-energy, generalized-geometry, time-dependent, coupled n-particle Monte Carlo transport code.<sup>c</sup> The Evaluated Neutron Data File library, ENDF/B-VII.0,<sup>d</sup> was utilized in analysis of the experiment and benchmark model biases and uncertainties.

Elemental data such as molecular weights and isotopic abundances were taken from the 16<sup>th</sup> edition of the Chart of the Nuclides.<sup>e</sup> These values are summarized in Appendix C.

<sup>a</sup> Fujimoto, N., Nakano, M., Takeuchi, M., Fujisaki, S., and Yamashita, K., "Start-Up Core Physics Tests of High Temperature Engineering Test Reactor (HTTR), (II): First Criticality by an Annular Form Fuel Loading and Its Criticality Prediction Method," *J. Atomic Energy Society Japan*, **42**(5), 458-464 (2000).

<sup>b</sup> Yamashita, K., Fujimoto, N., Takeuchi, M., Fujisaki, S., Nakano, M., Umeda, M., Takeda, T., Mogi, H., and Tanaka, T., "Startup Core Physics Tests of High Temperature Engineering Test Reactor (HTTR), (I): Test Plan, Fuel Loading and Nuclear Characteristics Tests," *J. Atomic Energy Society Japan*, **42**(1), 30-42 (2000).

<sup>c</sup> X-5 Monte Carlo Team, "MCNP – a General Monte Carlo n-Particle Transport Code, version 5," LA-UR-03-1987, Los Alamos National Laboratory (2003).

<sup>d</sup> M. B. Chadwick, et al., "ENDF/B-VII.0: Next Generation Evaluated Nuclear Data Library for Nuclear Science and Technology," *Nucl. Data Sheets*, **107**: 2931-3060 (2006).

<sup>e</sup> Nuclides and Isotopes: Chart of the Nuclides, 16<sup>th</sup> edition, (2002).

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Only the primary components of the HTTR active core and surrounding reflector region were included in the analysis of uncertainties in this evaluation. The uncertainty analysis was performed using a model temperature of approximately 300 K. Five configurations, or cases, representing the HTTR annular cores, created during initial fuel loading, are analyzed in this benchmark. The fully-loaded core configuration is analyzed in a separate report ([HTTR-GCR-RESR-001](#)). The difference between the different cases is the number of loaded fuel columns in the core; these are identified in Table 1.1.

For all impurity assessments, only the equivalent natural-boron content is utilized in the evaluation. In the compositions used in the evaluation models, the natural-boron content is adjusted to include only the primary absorber  $^{10}\text{B}$ , according to an isotopic abundance of 19.9 at. %.

All MCNP calculations of  $k_{\text{eff}}$  have statistical uncertainties between 0.00011 and 0.00012, resulting in  $\Delta k$  statistical uncertainties of approximately 0.00016, assuming no correlation between the individual MCNP results.

Some of the calculated uncertainties are poorly estimated because they are very small and on the order of the statistical uncertainty of the analysis method. However, these uncertainties are insignificant in magnitude compared to the total benchmark uncertainty. Reanalysis of most of these parameters with larger variations would not significantly reduce their uncertainties below the statistical uncertainty of the Monte Carlo calculations.

Uncertainties less than 0.00001 are reported as negligible (neg). When calculated uncertainties in  $\Delta k_{\text{eff}}$  are less than their statistical uncertainties, the statistical uncertainties are used in the calculation of the total uncertainty.

The term “Scaling Factor” denotes the necessary correction to adjust the evaluated uncertainty in  $k_{\text{eff}}$  to a  $1\sigma$  value. Often a larger uncertainty is evaluated such that the calculated  $\Delta k$  value is greater than the statistical uncertainty in the analysis method.

## 2.1.1 Experimental Uncertainties

### 2.1.1.1 Temperature

Temperature coefficients were not determined for the annular core configurations. The experimenters assumed that the temperature coefficient for the fully-loaded core configuration applies toward all HTTR configurations. Various temperature coefficients of reactivity are reported, ranging from  $-1.23 \times 10^{-4} \Delta k/k/^\circ\text{C}$  (Table 1.17 of [HTTR-GCR-RESR-001](#)) to  $-14.2 \text{ pcm}/^\circ\text{C}$  ([Ref. 2, p. 113 and 132](#)). An average of  $-13.25 \text{ pcm}/^\circ\text{C}$  with a deviation of  $\pm 0.95$  ( $1\sigma$ ) was selected to represent the effective change in reactivity with temperature adjustment. The experiments were performed near room temperature, and an uncertainty of  $\pm 1^\circ\text{C}$  ( $1\sigma$ ) was selected to represent the uncertainty in the temperature of the experiment. Results are shown in Table 2.1.

The uncertainty in the temperature is considered all systematic with no random component.

Table 2.1. Effect of Uncertainty in Temperature.

Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
-1 $^\circ\text{C}$	0.00013	$\pm$	0.00001	1	0.00013	$\pm$	0.00001
+1 $^\circ\text{C}$	-0.00013	$\pm$	0.00001	1	-0.00013	$\pm$	0.00001

### 2.1.1.2 Control Rod Position

Control rod positions were varied  $\pm 15$  mm ( $3\sigma$ ), as shown in Table 1.2, to determine the effective change in  $k_{\text{eff}}$ . The “sinking effect” of -14 mm that was described in Section 1.1.2.1 (just prior to Table 1.1) had already been applied to the rod position shown in Tables 1.1 and 1.2. It is unconfirmed whether temperature expansion effect of  $\pm 2$  mm (reported at the end of Section 1.1.2.4 in [HTTR-GCR-RESR-001](#)) applies uniformly to all control rods, how it was obtained, or that it was even applied to the reported experimental positions. Therefore it is applied with the  $\pm 5$  mm in a root mean square approach, the overall uncertainty in the height remains approximately  $\pm 5$  mm. No additional bias or bias uncertainty was evaluated for the sinking effect of the control rods. Results are shown in Table 2.2.

The total number of control rods used in the core is 32 (16 pairs). For determining the random component of the uncertainty in Section 2.1.7, the results in Table 2.2 are divided by  $\sqrt{16}$ .

Table 2.2. Effect of Uncertainty in Control Rod Position.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	-15 mm ( $3\sigma$ )	-0.00036	$\pm$	0.00017	3	-0.00012	$\pm$	0.00006
	+15 mm ( $3\sigma$ )	0.00041	$\pm$	0.00017	3	0.00014	$\pm$	0.00006
2	-15 mm ( $3\sigma$ )	-0.00133	$\pm$	0.00017	3	-0.00044	$\pm$	0.00006
	+15 mm ( $3\sigma$ )	0.00142	$\pm$	0.00016	3	0.00047	$\pm$	0.00005
3	-15 mm ( $3\sigma$ )	-0.00175	$\pm$	0.00016	3	-0.00058	$\pm$	0.00005
	+15 mm ( $3\sigma$ )	0.00156	$\pm$	0.00017	3	0.00052	$\pm$	0.00006
4	-15 mm ( $3\sigma$ )	-0.00111	$\pm$	0.00017	3	-0.00037	$\pm$	0.00006
	+15 mm ( $3\sigma$ )	0.00076	$\pm$	0.00017	3	0.00025	$\pm$	0.00006
5	-15 mm ( $3\sigma$ )	-0.00169	$\pm$	0.00016	3	-0.00056	$\pm$	0.00005
	+15 mm ( $3\sigma$ )	0.00187	$\pm$	0.00016	3	0.00062	$\pm$	0.00005

### 2.1.1.3 Measured Value of $k_{\text{eff}}$

There is no additional information regarding the accuracy of the  $k_{\text{eff}}$  measurements for the critical core conditions reported in Table 1.1. Typically the uncertainty and its effect are relatively insignificant.

## 2.1.2 Geometrical Properties

### 2.1.2.1 Coated Fuel Particles

When adjusting the diameters of the TRISO particle coatings, the other diameters are held constant. This in turn would increase or decrease the mass of the remaining layers. Whereas the diameters of the different layers appeared to be documented with more detail (see Table 1.14 and Figure 1.48 of [HTTR-GCR-RESR-001](#)), this approach seemed appropriate. The uncertainty in the mass is then evaluated as part of the density uncertainty Section 2.1.3.1.

### Kernel Diameter

Because of the overspecification of the TRISO particles in Table 1.14 ([HTTR-GCR-RESR-001](#)) and the correlation of uranium kernel diameter, density, TRISO packing fraction, and mass, the effect of the

uncertainty in the kernel diameter is not included in the total uncertainty. However, an analysis of the uncertainty based upon the fuel mass is performed in Section 2.1.6.

### **Buffer Diameter**

The buffer thickness was varied  $\pm 12 \mu\text{m}$  ( $3\sigma$ ) from the nominal value of  $60 \mu\text{m}$  (Tables 1.12 and 1.14, and Figure 1.48 of [HTTR-GCR-RESR-001](#)) to determine the effective change in  $k_{\text{eff}}$ . All other thicknesses in the TRISO particle were maintained the same. The packing fraction of the TRISO particles in the fuel was not conserved, so as to conserve fuel mass, but remained within  $1\sigma$  of the nominal value of 30 vol. % ( $\pm 3\%$  in Table 1.14 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.3.

The total number of TRISO particles used in the fully-loaded core is approximately 868,140,000. For determining the random component of the uncertainty, the results in Table 2.3 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.3.

Table 2.3. Effect of Uncertainty in Buffer Diameter.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-12 $\mu\text{m}$ ( $3\sigma$ )	0.00009	$\pm$	0.00016	3	0.00003	$\pm$	0.00005	$5.38 \times 10^8$
	+12 $\mu\text{m}$ ( $3\sigma$ )	0.00000	$\pm$	0.00017	3	0.00000	$\pm$	0.00006	
2	-12 $\mu\text{m}$ ( $3\sigma$ )	-0.00005	$\pm$	0.00016	3	-0.00002	$\pm$	0.00006	$5.98 \times 10^8$
	+12 $\mu\text{m}$ ( $3\sigma$ )	-0.00016	$\pm$	0.00017	3	-0.00005	$\pm$	0.00006	
3	-12 $\mu\text{m}$ ( $3\sigma$ )	-0.00019	$\pm$	0.00016	3	-0.00006	$\pm$	0.00005	$6.88 \times 10^8$
	+12 $\mu\text{m}$ ( $3\sigma$ )	-0.00015	$\pm$	0.00017	3	-0.00005	$\pm$	0.00006	
4	-12 $\mu\text{m}$ ( $3\sigma$ )	0.00002	$\pm$	0.00017	3	0.00001	$\pm$	0.00006	$6.88 \times 10^8$
	+12 $\mu\text{m}$ ( $3\sigma$ )	-0.00043	$\pm$	0.00017	3	-0.00014	$\pm$	0.00006	
5	-12 $\mu\text{m}$ ( $3\sigma$ )	0.00028	$\pm$	0.00016	3	0.00009	$\pm$	0.00005	$7.78 \times 10^8$
	+12 $\mu\text{m}$ ( $3\sigma$ )	-0.00022	$\pm$	0.00016	3	-0.00007	$\pm$	0.00005	

### **IPyC Diameter**

The IPyC thickness was varied  $\pm 6 \mu\text{m}$  ( $3\sigma$ ) from the nominal value of  $30 \mu\text{m}$  (Tables 1.12 and 1.14, and Figure 1.48 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . All other thicknesses in the TRISO particle were maintained the same. The packing fraction of the TRISO particles in the fuel was not conserved but remained within  $1\sigma$  of the nominal value of 30 vol. % ( $\pm 3\%$  in Table 1.14 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.4.

The total number of TRISO particles used in the fully-loaded core is approximately 868,140,000. For determining the random component of the uncertainty, the results in Table 2.4 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.4.

Table 2.4. Effect of Uncertainty in IPyC Diameter.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-6 $\mu\text{m}$ ( $3\sigma$ )	0.00003	$\pm$	0.00017	3	0.00001	$\pm$	0.00006	$5.38 \times 10^8$
	+6 $\mu\text{m}$ ( $3\sigma$ )	0.00014	$\pm$	0.00016	3	0.00005	$\pm$	0.00005	
2	-6 $\mu\text{m}$ ( $3\sigma$ )	-0.00002	$\pm$	0.00016	3	-0.00001	$\pm$	0.00005	$5.98 \times 10^8$
	+6 $\mu\text{m}$ ( $3\sigma$ )	-0.00002	$\pm$	0.00017	3	-0.00001	$\pm$	0.00006	
3	-6 $\mu\text{m}$ ( $3\sigma$ )	-0.00017	$\pm$	0.00017	3	-0.00006	$\pm$	0.00006	$6.88 \times 10^8$
	+6 $\mu\text{m}$ ( $3\sigma$ )	0.00007	$\pm$	0.00017	3	0.00002	$\pm$	0.00006	
4	-6 $\mu\text{m}$ ( $3\sigma$ )	-0.00008	$\pm$	0.00017	3	-0.00003	$\pm$	0.00006	$6.88 \times 10^8$
	+6 $\mu\text{m}$ ( $3\sigma$ )	0.00003	$\pm$	0.00017	3	0.00001	$\pm$	0.00006	
5	-6 $\mu\text{m}$ ( $3\sigma$ )	0.00010	$\pm$	0.00016	3	0.00003	$\pm$	0.00005	$7.78 \times 10^8$
	+6 $\mu\text{m}$ ( $3\sigma$ )	0.00004	$\pm$	0.00016	3	0.00001	$\pm$	0.00005	

**SiC Diameter**

The SiC thickness was varied  $\pm 12 \mu\text{m}$  ( $3\sigma$ ) from the nominal value of  $30 \mu\text{m}$  (Tables 1.12 and 1.14, and Figure 1.48 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . Although there is a negative component to the deviation in the thickness (Figure 1.48 of [HTTR-GCR-RESR-001](#)), TRISO particles with SiC thicknesses less than  $25 \mu\text{m}$  are not acceptable for use as a final product. The thickness of  $25 \mu\text{m}$  for the thickness appears to be a manufacturing limit while the thickness of  $30 \mu\text{m}$  is more likely to be the actual thickness of the SiC layer. All other thicknesses in the TRISO particle were maintained the same. The packing fraction of the TRISO particles in the fuel was not conserved but remained within  $1\sigma$  of the nominal value of 30 vol. % ( $\pm 3\%$  in Table 1.14 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.5.

The total number of TRISO particles used in the fully-loaded core is approximately 868,140,000. For determining the random component of the uncertainty, the results in Table 2.5 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.5.



## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.5. Effect of Uncertainty in SiC Diameter.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-12 $\mu\text{m}$ ( $3\sigma$ )	0.00019	$\pm$	0.00017	3	0.00006	$\pm$	0.00006	$5.38 \times 10^8$
	+12 $\mu\text{m}$ ( $3\sigma$ )	-0.00062	$\pm$	0.00017	3	-0.00021	$\pm$	0.00006	
2	-12 $\mu\text{m}$ ( $3\sigma$ )	0.00070	$\pm$	0.00017	3	0.00023	$\pm$	0.00006	$5.98 \times 10^8$
	+12 $\mu\text{m}$ ( $3\sigma$ )	-0.00021	$\pm$	0.00016	3	-0.00007	$\pm$	0.00005	
3	-12 $\mu\text{m}$ ( $3\sigma$ )	0.00062	$\pm$	0.00016	3	0.00021	$\pm$	0.00005	$6.88 \times 10^8$
	+12 $\mu\text{m}$ ( $3\sigma$ )	-0.00057	$\pm$	0.00017	3	-0.00019	$\pm$	0.00006	
4	-12 $\mu\text{m}$ ( $3\sigma$ )	0.00025	$\pm$	0.00016	3	0.00008	$\pm$	0.00005	$6.88 \times 10^8$
	+12 $\mu\text{m}$ ( $3\sigma$ )	-0.00080	$\pm$	0.00017	3	-0.00027	$\pm$	0.00006	
5	-12 $\mu\text{m}$ ( $3\sigma$ )	0.00068	$\pm$	0.00016	3	0.00023	$\pm$	0.00005	$7.78 \times 10^8$
	+12 $\mu\text{m}$ ( $3\sigma$ )	-0.00074	$\pm$	0.00016	3	-0.00025	$\pm$	0.00005	

**OPyC Diameter**

The OPyC thickness was varied  $\pm 6 \mu\text{m}$  ( $3\sigma$ ) from the nominal value of  $45 \mu\text{m}$  (Tables 1.12 and 1.14, and Figure 1.48 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . All other thicknesses in the TRISO particle were maintained the same. The packing fraction of the TRISO particles in the fuel was not conserved but remained within  $1\sigma$  of the nominal value of 30 vol. % ( $\pm 3\%$  in Table 1.14 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.6.

The total number of TRISO particles used in the fully-loaded core is approximately 868,140,000. For determining the random component of the uncertainty, the results in Table 2.6 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.6.

Table 2.6. Effect of Uncertainty in OPyC Diameter.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-6 $\mu\text{m}$ ( $3\sigma$ )	-0.00002	$\pm$	0.00016	3	-0.00001	$\pm$	0.00005	$5.38 \times 10^8$
	+6 $\mu\text{m}$ ( $3\sigma$ )	0.00000	$\pm$	0.00017	3	0.00000	$\pm$	0.00006	
2	-6 $\mu\text{m}$ ( $3\sigma$ )	0.00019	$\pm$	0.00016	3	0.00006	$\pm$	0.00005	$5.98 \times 10^8$
	+6 $\mu\text{m}$ ( $3\sigma$ )	0.00032	$\pm$	0.00017	3	0.00011	$\pm$	0.00006	
3	-6 $\mu\text{m}$ ( $3\sigma$ )	-0.00018	$\pm$	0.00017	3	-0.00006	$\pm$	0.00006	$6.88 \times 10^8$
	+6 $\mu\text{m}$ ( $3\sigma$ )	0.00011	$\pm$	0.00017	3	0.00004	$\pm$	0.00006	
4	-6 $\mu\text{m}$ ( $3\sigma$ )	-0.00014	$\pm$	0.00017	3	-0.00005	$\pm$	0.00006	$6.88 \times 10^8$
	+6 $\mu\text{m}$ ( $3\sigma$ )	-0.00031	$\pm$	0.00017	3	-0.00010	$\pm$	0.00006	
5	-6 $\mu\text{m}$ ( $3\sigma$ )	-0.00003	$\pm$	0.00016	3	-0.00001	$\pm$	0.00005	$7.78 \times 10^8$
	+6 $\mu\text{m}$ ( $3\sigma$ )	-0.00002	$\pm$	0.00016	3	-0.00001	$\pm$	0.00005	



**Overcoat Diameter**

Because insufficient data is available for the final composition and density of the graphite overcoat, this layer is being treated with equal properties to that of the surrounding compact graphite matrix (Table 1.14 of [HTTR-GCR-RESR-001](#)). Therefore modification of the overcoat diameter would not generate an effective uncertainty in  $k_{\text{eff}}$  beyond statistical uncertainty.

**2.1.2.2 Prismatic Fuel Compact****Dimensions**

The inner and outer diameters (ID and OD) of a fuel compact were each individually varied  $\pm 0.3$  mm and the height (H) was varied  $\pm 0.5$  mm to determine the effective uncertainty in  $k_{\text{eff}}$ . For the effective change in height, the fuel stack height was adjusted by  $\pm 7.0$  mm and the effect from a height change in a single fuel compact was then determined by dividing by 14 for the number of compacts in a fuel rod. The nominal values for the inner diameter, outer diameter, and height of the fuel compacts are 10.0, 26.0, and 39.0 mm, respectively (Table 1.14 of [HTTR-GCR-RESR-001](#)). Results are shown in Tables 2.7 through 2.9. In essence, changing the dimensions of the fuel compact without changing the number of TRISO particles would slightly adjust the packing fraction, but within the uncertainty limits.

Later information was obtained regarding manufacturing tolerances for the fuel compacts. The  $\pm 0.1$  mm of the ID and OD represents a bounding limit (with assumed uniform probability) and the effective stack height has a bounding limit (with assumed uniform probability) of  $\pm 1.0$  mm.<sup>a</sup> The appropriate corrections to the scaling factors have been incorporated into the uncertainty analysis of these parameters.

The total number of fuel compacts used in the fully-loaded core is 66,780. For determining the random component of the uncertainty, the results in Tables 2.7 through 2.9 would be divided by  $\sqrt{N}$ , where N for each case is shown in Tables 2.7 through 2.9.

Table 2.7. Effect of Uncertainty in Compact Dimensions (Inner Diameter).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.3 mm (3 $\times$ limit)	0.00016	$\pm$	0.00016	$3\sqrt{3}$	0.00003	$\pm$	0.00003	41,370
	+0.3 mm (3 $\times$ limit)	-0.00003	$\pm$	0.00017	$3\sqrt{3}$	-0.00001	$\pm$	0.00003	
2	-0.3 mm (3 $\times$ limit)	0.00014	$\pm$	0.00016	$3\sqrt{3}$	0.00003	$\pm$	0.00003	45,990
	+0.3 mm (3 $\times$ limit)	-0.00020	$\pm$	0.00016	$3\sqrt{3}$	-0.00004	$\pm$	0.00003	
3	-0.3 mm (3 $\times$ limit)	0.00014	$\pm$	0.00017	$3\sqrt{3}$	0.00003	$\pm$	0.00003	52,920
	+0.3 mm (3 $\times$ limit)	-0.00008	$\pm$	0.00017	$3\sqrt{3}$	-0.00002	$\pm$	0.00003	
4	-0.3 mm (3 $\times$ limit)	-0.00004	$\pm$	0.00017	$3\sqrt{3}$	-0.00001	$\pm$	0.00003	52,920
	+0.3 mm (3 $\times$ limit)	-0.00037	$\pm$	0.00017	$3\sqrt{3}$	-0.00007	$\pm$	0.00003	
5	-0.3 mm (3 $\times$ limit)	0.00012	$\pm$	0.00016	$3\sqrt{3}$	0.00002	$\pm$	0.00003	59,850
	+0.3 mm (3 $\times$ limit)	-0.00023	$\pm$	0.00016	$3\sqrt{3}$	-0.00004	$\pm$	0.00003	

<sup>a</sup> S. Maruyama, K. Yamashita, N. Fujimoto, I. Murata, R. Shindo, and Y. Sudo, "Determination of Hot Spot Factors for Calculation of the Maximum Fuel Temperatures in the Core Thermal and Hydraulic Design of HTTR," JAERI-M 88-250, JAEA (November 18, 1988). [in Japanese].

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.8. Effect of Uncertainty in Compact Dimensions (Outer Diameter).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.3 mm (3 $\times$ limit)	-0.00048	$\pm$	0.00017	$3\sqrt{3}$	-0.00009	$\pm$	0.00003	41,370
	+0.3 mm (3 $\times$ limit)	0.00060	$\pm$	0.00016	$3\sqrt{3}$	0.00012	$\pm$	0.00003	
2	-0.3 mm (3 $\times$ limit)	-0.00050	$\pm$	0.00016	$3\sqrt{3}$	-0.00010	$\pm$	0.00003	45,990
	+0.3 mm (3 $\times$ limit)	0.00049	$\pm$	0.00016	$3\sqrt{3}$	0.00009	$\pm$	0.00003	
3	-0.3 mm (3 $\times$ limit)	-0.00087	$\pm$	0.00016	$3\sqrt{3}$	-0.00017	$\pm$	0.00003	52,920
	+0.3 mm (3 $\times$ limit)	0.00068	$\pm$	0.00016	$3\sqrt{3}$	0.00013	$\pm$	0.00003	
4	-0.3 mm (3 $\times$ limit)	-0.00081	$\pm$	0.00017	$3\sqrt{3}$	-0.00016	$\pm$	0.00003	52,920
	+0.3 mm (3 $\times$ limit)	0.00057	$\pm$	0.00017	$3\sqrt{3}$	0.00011	$\pm$	0.00003	
5	-0.3 mm (3 $\times$ limit)	-0.00066	$\pm$	0.00016	$3\sqrt{3}$	-0.00013	$\pm$	0.00003	59,850
	+0.3 mm (3 $\times$ limit)	0.00059	$\pm$	0.00016	$3\sqrt{3}$	0.00011	$\pm$	0.00003	

Table 2.9. Effect of Uncertainty in Compact Dimensions (Height).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-7.0 mm (7 $\times$ limit)	-0.00262	$\pm$	0.00016	$7\sqrt{3}$	-0.00022	$\pm$	0.00001	41,370
	+7.0 mm (7 $\times$ limit)	0.00246	$\pm$	0.00017	$7\sqrt{3}$	0.00020	$\pm$	0.00001	
2	-7.0 mm (7 $\times$ limit)	-0.00236	$\pm$	0.00017	$7\sqrt{3}$	-0.00019	$\pm$	0.00001	45,990
	+7.0 mm (7 $\times$ limit)	0.00216	$\pm$	0.00017	$7\sqrt{3}$	0.00018	$\pm$	0.00001	
3	-7.0 mm (7 $\times$ limit)	-0.00260	$\pm$	0.00017	$7\sqrt{3}$	-0.00021	$\pm$	0.00001	52,920
	+7.0 mm (7 $\times$ limit)	0.00191	$\pm$	0.00017	$7\sqrt{3}$	0.00016	$\pm$	0.00001	
4	-7.0 mm (7 $\times$ limit)	-0.00282	$\pm$	0.00017	$7\sqrt{3}$	-0.00023	$\pm$	0.00001	52,920
	+7.0 mm (7 $\times$ limit)	0.00201	$\pm$	0.00017	$7\sqrt{3}$	0.00017	$\pm$	0.00001	
5	-7.0 mm (7 $\times$ limit)	-0.00268	$\pm$	0.00016	$7\sqrt{3}$	-0.00022	$\pm$	0.00001	59,850
	+7.0 mm (7 $\times$ limit)	0.00201	$\pm$	0.00016	$7\sqrt{3}$	0.00017	$\pm$	0.00001	

**Packing Fraction**

Because of the overspecification of the TRISO particles in Table 1.14 ([HTTR-GCR-RESR-001](#)) and the correlation of uranium kernel diameter, density, TRISO packing fraction, and mass, the effect of the uncertainty in the packing fraction is not included in the total uncertainty. However, an analysis of the uncertainty based upon the fuel mass is performed in Section 2.1.6.

**2.1.2.3 Graphite Sleeves**

The uncertainty in the sleeve thickness was unreported. An inner diameter uncertainty of  $\pm 0.5$  mm, which is limited by the 0.25 mm gap width between the sleeve and fuel compacts (Table 1.13 of [HTTR-GCR-RESR-001](#)), and an outer diameter uncertainty of  $\pm 2$  mm were assumed; their effects on the

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

uncertainty of  $k_{\text{eff}}$  were determined. Figure 1.51 of [HTTR-GCR-RESR-001](#) shows an inner diameter of 26.25 mm for the graphite sleeves, which would only provide a gap space of 0.125 mm. The assumed uncertainty encompasses the discrepancy in this value. Results are shown in Tables 2.10 and 2.11.

The fuel sleeve height was varied  $\pm 0.5$  mm from the nominal value of 577 mm (Table 1.14 and Figure 1.51 of [HTTR-GCR-RESR-001](#)) and the effect on the uncertainty of  $k_{\text{eff}}$  was determined. Results are shown in Table 2.12.

Later information was obtained regarding manufacturing tolerances for the fuel sleeves. The  $\pm 0.1$  mm of the ID and OD represents a bounding limit (with assumed uniform probability) and the height is then assumed to have a bounding limit (with assumed uniform probability) also of  $\pm 0.1$  mm.<sup>a</sup> The appropriate corrections to the scaling factors have been incorporated into the uncertainty analysis of these parameters.

The total number of graphite sleeves used in the fully-loaded core is 4,770. For determining the random component of the uncertainty, the results in Tables 2.10 through 2.12 would be divided by  $\sqrt{N}$ , where N for each case is shown in Tables 2.10 through 2.12.

Table 2.10. Effect of Uncertainty in Graphite Sleeve Dimensions (Inner Diameter).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.5 mm	0.00079	$\pm$	0.00017	$5\sqrt{3}$	0.00009	$\pm$	0.00002	2,955
	+0.5 mm	-0.00089	$\pm$	0.00017	$5\sqrt{3}$	-0.00010	$\pm$	0.00002	
2	-0.5 mm	0.00077	$\pm$	0.00017	$5\sqrt{3}$	0.00009	$\pm$	0.00002	3,285
	+0.5 mm	-0.00074	$\pm$	0.00016	$5\sqrt{3}$	-0.00009	$\pm$	0.00002	
3	-0.5 mm	0.00083	$\pm$	0.00016	$5\sqrt{3}$	0.00010	$\pm$	0.00002	3,780
	+0.5 mm	-0.00102	$\pm$	0.00016	$5\sqrt{3}$	-0.00012	$\pm$	0.00002	
4	-0.5 mm	0.00111	$\pm$	0.00017	$5\sqrt{3}$	0.00013	$\pm$	0.00002	3,780
	+0.5 mm	-0.00103	$\pm$	0.00017	$5\sqrt{3}$	-0.00012	$\pm$	0.00002	
5	-0.5 mm	0.00110	$\pm$	0.00016	$5\sqrt{3}$	0.00013	$\pm$	0.00002	4,275
	+0.5 mm	-0.00125	$\pm$	0.00016	$5\sqrt{3}$	-0.00014	$\pm$	0.00002	

<sup>a</sup> S. Maruyama, K. Yamashita, N. Fujimoto, I. Murata, R. Shindo, and Y. Sudo, "Determination of Hot Spot Factors for Calculation of the Maximum Fuel Temperatures in the Core Thermal and Hydraulic Design of HTTR," JAERI-M 88-250, JAEA (November 18, 1988). [in Japanese].

Table 2.11. Effect of Uncertainty in Graphite Sleeve Dimensions (Outer Diameter).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-2 mm	-0.00499	$\pm$	0.00016	$20\sqrt{3}$	-0.00014	$\pm$	0.00000	2,955
	+2 mm	0.00574	$\pm$	0.00016	$20\sqrt{3}$	0.00017	$\pm$	0.00000	
2	-2 mm	-0.00555	$\pm$	0.00017	$20\sqrt{3}$	-0.00016	$\pm$	0.00000	3,285
	+2 mm	0.00587	$\pm$	0.00017	$20\sqrt{3}$	0.00017	$\pm$	0.00000	
3	-2 mm	-0.00622	$\pm$	0.00016	$20\sqrt{3}$	-0.00018	$\pm$	0.00000	3,780
	+2 mm	0.00640	$\pm$	0.00016	$20\sqrt{3}$	0.00018	$\pm$	0.00000	
4	-2 mm	-0.00692	$\pm$	0.00017	$20\sqrt{3}$	-0.00020	$\pm$	0.00000	3,780
	+2 mm	0.00715	$\pm$	0.00017	$20\sqrt{3}$	0.00021	$\pm$	0.00000	
5	-2 mm	-0.00675	$\pm$	0.00016	$20\sqrt{3}$	-0.00019	$\pm$	0.00000	4,275
	+2 mm	0.00700	$\pm$	0.00016	$20\sqrt{3}$	0.00020	$\pm$	0.00000	

Table 2.12. Effect of Uncertainty in Graphite Sleeve Dimensions (Height).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.5 mm (1 $\sigma$ )	-0.00047	$\pm$	0.00016	$5\sqrt{3}$	-0.00005	$\pm$	0.00002	2,955
	+0.5 mm (1 $\sigma$ )	0.00039	$\pm$	0.00017	$5\sqrt{3}$	0.00005	$\pm$	0.00002	
2	-0.5 mm (1 $\sigma$ )	-0.00042	$\pm$	0.00017	$5\sqrt{3}$	-0.00005	$\pm$	0.00002	3,285
	+0.5 mm (1 $\sigma$ )	0.00036	$\pm$	0.00016	$5\sqrt{3}$	0.00004	$\pm$	0.00002	
3	-0.5 mm (1 $\sigma$ )	-0.00035	$\pm$	0.00017	$5\sqrt{3}$	-0.00004	$\pm$	0.00002	3,780
	+0.5 mm (1 $\sigma$ )	0.00025	$\pm$	0.00016	$5\sqrt{3}$	0.00003	$\pm$	0.00002	
4	-0.5 mm (1 $\sigma$ )	-0.00058	$\pm$	0.00017	$5\sqrt{3}$	-0.00007	$\pm$	0.00002	3,780
	+0.5 mm (1 $\sigma$ )	0.00026	$\pm$	0.00017	$5\sqrt{3}$	0.00003	$\pm$	0.00002	
5	-0.5 mm (1 $\sigma$ )	-0.00068	$\pm$	0.00016	$5\sqrt{3}$	-0.00008	$\pm$	0.00002	4,275
	+0.5 mm (1 $\sigma$ )	0.00022	$\pm$	0.00016	$5\sqrt{3}$	0.00003	$\pm$	0.00002	

#### 2.1.2.4 Burnable Poisons

The uncertainty in the diameters of the BPs and BP insertion holes was unreported. A BP diameter uncertainty of  $\pm 1$  mm from the nominal diameter (D) of 14 mm and a BP insertion hole diameter uncertainty of  $\pm 1$  mm from the nominal diameter of 15 mm were assumed and their effects on the uncertainty of  $k_{\text{eff}}$  were determined. Results are shown in Tables 2.13 and 2.15.

The uncertainty in the height stack of the BPs was unreported. A stack height (H) uncertainty of  $\pm 1$  mm from the nominal height of 200 mm was assumed (approximately  $\pm 0.1$  mm per BP pellet) and the effective uncertainty in  $k_{\text{eff}}$  was determined. The height of the BP insertion hole was adjusted to accommodate the change in BP stack height. Results are shown in Table 2.14.

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

The uncertainty in the dimensions of the graphite disks was unreported. A diameter uncertainty of  $\pm 1$  mm from the nominal diameter of 14 mm and a height uncertainty of  $\pm 1$  mm from the nominal stack height of 100 mm were assumed and their effects on the uncertainty of  $k_{\text{eff}}$  were determined. The height of the BP insertion hole was adjusted to accommodate the change in graphite-disk stack height. Results are shown in Tables 2.16 and 2.17.

Because of the tight manufacturing tolerances of the fuel compacts and graphite sleeves (Sections 2.1.2.2 and 2.1.2.3, respectively) it is believed that similar tolerances apply to other graphite and boron carbide components of the HTTR. Therefore, the BP and graphite disk diameters are treated with a tolerance (with uniform probability) of  $\pm 0.1$  mm and a stack height tolerance (with uniform probability) of  $\pm 1.0$  mm. The appropriate corrections to the scaling factors have been incorporated into the uncertainty analysis of these parameters.

The total number of burnable poison pellets used in the fully-loaded core is 5,520. For determining the random component of the uncertainty, the results in Tables 2.13 through 2.17 would be divided by  $\sqrt{N}$ , where N for each case is shown in Tables 2.13 through 2.17. The total number of BP stacks is 600, of BP insertion holes is 450, and of graphite disk stacks is 300, in the fully-loaded core configuration.

Table 2.13. Effect of Uncertainty in BP Pin Dimensions (Diameter).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-1 mm (10 $\times$ limit)	0.01047	$\pm$	0.00017	$10\sqrt{3}$	0.00060	$\pm$	0.00001	3,496
	+1 mm (10 $\times$ limit)	-0.00974	$\pm$	0.00017	$10\sqrt{3}$	-0.00056	$\pm$	0.00001	
2	-1 mm (10 $\times$ limit)	0.01125	$\pm$	0.00016	$10\sqrt{3}$	0.00065	$\pm$	0.00001	3,864
	+1 mm (10 $\times$ limit)	-0.01045	$\pm$	0.00016	$10\sqrt{3}$	-0.00060	$\pm$	0.00001	
3	-1 mm (10 $\times$ limit)	0.01198	$\pm$	0.00016	$10\sqrt{3}$	0.00069	$\pm$	0.00001	4,416
	+1 mm (10 $\times$ limit)	-0.01149	$\pm$	0.00016	$10\sqrt{3}$	-0.00066	$\pm$	0.00001	
4	-1 mm (10 $\times$ limit)	0.01202	$\pm$	0.00017	$10\sqrt{3}$	0.00069	$\pm$	0.00001	4,416
	+1 mm (10 $\times$ limit)	-0.01171	$\pm$	0.00016	$10\sqrt{3}$	-0.00068	$\pm$	0.00001	
5	-1 mm (10 $\times$ limit)	0.01287	$\pm$	0.00016	$10\sqrt{3}$	0.00074	$\pm$	0.00001	4,968
	+1 mm (10 $\times$ limit)	-0.01234	$\pm$	0.00016	$10\sqrt{3}$	-0.00071	$\pm$	0.00001	

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.14. Effect of Uncertainty in BP Pin Dimensions (Stack Height).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-1 mm	0.00061	$\pm$	0.00017	$\sqrt{3}$	0.00035	$\pm$	0.00010	380
	+1 mm	-0.00050	$\pm$	0.00017	$\sqrt{3}$	-0.00029	$\pm$	0.00010	
2	-1 mm	0.00056	$\pm$	0.00017	$\sqrt{3}$	0.00032	$\pm$	0.00010	420
	+1 mm	-0.00065	$\pm$	0.00016	$\sqrt{3}$	-0.00038	$\pm$	0.00009	
3	-1 mm	0.00044	$\pm$	0.00017	$\sqrt{3}$	0.00025	$\pm$	0.00010	480
	+1 mm	-0.00077	$\pm$	0.00017	$\sqrt{3}$	-0.00044	$\pm$	0.00010	
4	-1 mm	0.00050	$\pm$	0.00017	$\sqrt{3}$	0.00029	$\pm$	0.00010	480
	+1 mm	-0.00088	$\pm$	0.00017	$\sqrt{3}$	-0.00051	$\pm$	0.00010	
5	-1 mm	0.00055	$\pm$	0.00016	$\sqrt{3}$	0.00032	$\pm$	0.00009	520
	+1 mm	-0.00065	$\pm$	0.00016	$\sqrt{3}$	-0.00038	$\pm$	0.00009	

Table 2.15. Effect of Uncertainty in BP Insertion Hole Diameter.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-1 mm (10 $\times$ limit)	0.00102	$\pm$	0.00017	$10\sqrt{3}$	0.00006	$\pm$	0.00001	285
	+1 mm (10 $\times$ limit)	-0.00092	$\pm$	0.00017	$10\sqrt{3}$	-0.00005	$\pm$	0.00001	
2	-1 mm (10 $\times$ limit)	0.00116	$\pm$	0.00016	$10\sqrt{3}$	0.00007	$\pm$	0.00001	315
	+1 mm (10 $\times$ limit)	-0.00076	$\pm$	0.00016	$10\sqrt{3}$	-0.00004	$\pm$	0.00001	
3	-1 mm (10 $\times$ limit)	0.00076	$\pm$	0.00017	$10\sqrt{3}$	0.00004	$\pm$	0.00001	360
	+1 mm (10 $\times$ limit)	-0.00104	$\pm$	0.00016	$10\sqrt{3}$	-0.00006	$\pm$	0.00001	
4	-1 mm (10 $\times$ limit)	0.00069	$\pm$	0.00016	$10\sqrt{3}$	0.00004	$\pm$	0.00001	360
	+1 mm (10 $\times$ limit)	-0.00122	$\pm$	0.00016	$10\sqrt{3}$	-0.00007	$\pm$	0.00001	
5	-1 mm (10 $\times$ limit)	0.00109	$\pm$	0.00016	$10\sqrt{3}$	0.00006	$\pm$	0.00001	405
	+1 mm (10 $\times$ limit)	-0.00098	$\pm$	0.00016	$10\sqrt{3}$	-0.00006	$\pm$	0.00001	

Table 2.16. Effect of Uncertainty in Graphite Disk Dimensions (Diameter).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-1 mm (10 $\times$ limit)	-0.00018	$\pm$	0.00017	$10\sqrt{3}$	-0.00001	$\pm$	0.00001	190
	+1 mm (10 $\times$ limit)	0.00008	$\pm$	0.00017	$10\sqrt{3}$	0.00000	$\pm$	0.00001	
2	-1 mm (10 $\times$ limit)	0.00008	$\pm$	0.00016	$10\sqrt{3}$	0.00000	$\pm$	0.00001	210
	+1 mm (10 $\times$ limit)	-0.00005	$\pm$	0.00017	$10\sqrt{3}$	0.00000	$\pm$	0.00001	
3	-1 mm (10 $\times$ limit)	-0.00002	$\pm$	0.00016	$10\sqrt{3}$	0.00000	$\pm$	0.00001	240
	+1 mm (10 $\times$ limit)	0.00011	$\pm$	0.00017	$10\sqrt{3}$	0.00001	$\pm$	0.00001	
4	-1 mm (10 $\times$ limit)	-0.00011	$\pm$	0.00017	$10\sqrt{3}$	-0.00001	$\pm$	0.00001	240
	+1 mm (10 $\times$ limit)	-0.00008	$\pm$	0.00017	$10\sqrt{3}$	0.00000	$\pm$	0.00001	
5	-1 mm (10 $\times$ limit)	-0.00004	$\pm$	0.00016	$10\sqrt{3}$	0.00000	$\pm$	0.00001	270
	+1 mm (10 $\times$ limit)	-0.00012	$\pm$	0.00016	$10\sqrt{3}$	-0.00001	$\pm$	0.00001	

Table 2.17. Effect of Uncertainty in Graphite Disk Dimensions (Stack Height).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-1 mm	-0.00001	$\pm$	0.00017	$\sqrt{3}$	-0.00001	$\pm$	0.00010	190
	+1 mm	0.00022	$\pm$	0.00016	$\sqrt{3}$	0.00013	$\pm$	0.00009	
2	-1 mm	0.00008	$\pm$	0.00016	$\sqrt{3}$	0.00005	$\pm$	0.00009	210
	+1 mm	-0.00005	$\pm$	0.00017	$\sqrt{3}$	-0.00003	$\pm$	0.00010	
3	-1 mm	-0.00004	$\pm$	0.00016	$\sqrt{3}$	-0.00002	$\pm$	0.00009	240
	+1 mm	0.00001	$\pm$	0.00017	$\sqrt{3}$	0.00001	$\pm$	0.00010	
4	-1 mm	0.00000	$\pm$	0.00017	$\sqrt{3}$	0.00000	$\pm$	0.00010	240
	+1 mm	-0.00009	$\pm$	0.00017	$\sqrt{3}$	-0.00005	$\pm$	0.00010	
5	-1 mm	-0.00015	$\pm$	0.00016	$\sqrt{3}$	-0.00009	$\pm$	0.00009	270
	+1 mm	0.00021	$\pm$	0.00016	$\sqrt{3}$	0.00012	$\pm$	0.00009	

### 2.1.2.5 Control Rods

#### **Absorber Dimensions**

The uncertainty in the absorber dimensions was unreported. Assumed inner and outer diameter (ID and OD) uncertainties are  $\pm 5$  mm each from the nominal values of 75 and 105 mm (Table 1.15 of [HTTR-GCR-RESR-001](#)), respectively, and their effects on the uncertainty of  $k_{\text{eff}}$  were determined. The uncertainty in the pellet height was assumed to be  $\pm 1$  cm from the nominal stack height (H) of 29 cm. The alternate value of 115 mm provided for the outer diameter of the absorber material is believed to be a typographical error (see footnote of Table 1.15 of [HTTR-GCR-RESR-001](#)). Results are shown in Tables 2.18 through 2.20.

Because of the tight manufacturing tolerances of the fuel compacts and graphite sleeves (Sections 2.1.2.2 and 2.1.2.3, respectively) it is believed that similar tolerances apply to other graphite and boron carbide components of the HTTR. Therefore, the absorber diameters are treated with a tolerance (with uniform probability) of  $\pm 0.1$  mm and a stack height tolerance (with uniform probability) of  $\pm 1.0$  mm. The appropriate corrections to the scaling factors have been incorporated into the uncertainty analysis of these parameters.

The total number of control rod absorber pellets used in the fully-loaded core is approximately 975, as approximately 30% of the control rods are actually inserted into the core. For determining the random component of the uncertainty, the results in Tables 2.18 through 2.20 would be divided by  $\sqrt{N}$ , where  $N$  for each case is shown in Tables 2.18 through 2.20.

Table 2.18. Effect of Uncertainty in CR Absorber Dimensions (Inner Diameter).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-5 mm (50 $\times$ limit)	-0.00026	$\pm$	0.00017	$50\sqrt{3}$	0.00000	$\pm$	0.00000	225
	+5 mm (50 $\times$ limit)	0.00003	$\pm$	0.00017	$50\sqrt{3}$	0.00000	$\pm$	0.00000	
2	-5 mm (50 $\times$ limit)	-0.00021	$\pm$	0.00017	$50\sqrt{3}$	0.00000	$\pm$	0.00000	585
	+5 mm (50 $\times$ limit)	0.00037	$\pm$	0.00017	$50\sqrt{3}$	0.00000	$\pm$	0.00000	
3	-5 mm (50 $\times$ limit)	-0.00033	$\pm$	0.00017	$50\sqrt{3}$	0.00000	$\pm$	0.00000	780
	+5 mm (50 $\times$ limit)	0.00014	$\pm$	0.00017	$50\sqrt{3}$	0.00000	$\pm$	0.00000	
4	-5 mm (50 $\times$ limit)	-0.00042	$\pm$	0.00016	$50\sqrt{3}$	0.00000	$\pm$	0.00000	720
	+5 mm (50 $\times$ limit)	0.00037	$\pm$	0.00017	$50\sqrt{3}$	0.00000	$\pm$	0.00000	
5	-5 mm (50 $\times$ limit)	-0.00032	$\pm$	0.00016	$50\sqrt{3}$	0.00000	$\pm$	0.00000	910
	+5 mm (50 $\times$ limit)	0.00035	$\pm$	0.00016	$50\sqrt{3}$	0.00000	$\pm$	0.00000	

Table 2.19. Effect of Uncertainty in CR Absorber Dimensions (Outer Diameter).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-5 mm (50 $\times$ limit)	0.00072	$\pm$	0.00016	$50\sqrt{3}$	0.00001	$\pm$	0.00000	225
	+5 mm (50 $\times$ limit)	-0.00083	$\pm$	0.00017	$50\sqrt{3}$	-0.00001	$\pm$	0.00000	
2	-5 mm (50 $\times$ limit)	0.00130	$\pm$	0.00017	$50\sqrt{3}$	0.00002	$\pm$	0.00000	585
	+5 mm (50 $\times$ limit)	-0.00100	$\pm$	0.00016	$50\sqrt{3}$	-0.00001	$\pm$	0.00000	
3	-5 mm (50 $\times$ limit)	0.00135	$\pm$	0.00017	$50\sqrt{3}$	0.00002	$\pm$	0.00000	780
	+5 mm (50 $\times$ limit)	-0.00145	$\pm$	0.00017	$50\sqrt{3}$	-0.00002	$\pm$	0.00000	
4	-5 mm (50 $\times$ limit)	0.00226	$\pm$	0.00017	$50\sqrt{3}$	0.00003	$\pm$	0.00000	720
	+5 mm (50 $\times$ limit)	-0.00275	$\pm$	0.00017	$50\sqrt{3}$	-0.00003	$\pm$	0.00000	
5	-5 mm (50 $\times$ limit)	0.00160	$\pm$	0.00016	$50\sqrt{3}$	0.00002	$\pm$	0.00000	910
	+5 mm (50 $\times$ limit)	-0.00187	$\pm$	0.00016	$50\sqrt{3}$	-0.00002	$\pm$	0.00000	



Table 2.20. Effect of Uncertainty in CR Absorber Dimensions (Stack Height).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-1 cm (10 $\times$ limit)	0.00024	$\pm$	0.00017	$10\sqrt{3}$	0.00001	$\pm$	0.00001	22.5
	+1 cm (10 $\times$ limit)	-0.00023	$\pm$	0.00016	$10\sqrt{3}$	-0.00001	$\pm$	0.00001	
2	-1 cm (10 $\times$ limit)	0.00085	$\pm$	0.00016	$10\sqrt{3}$	0.00005	$\pm$	0.00001	58.5
	+1 cm (10 $\times$ limit)	-0.00089	$\pm$	0.00017	$10\sqrt{3}$	-0.00005	$\pm$	0.00001	
3	-1 cm (10 $\times$ limit)	0.00039	$\pm$	0.00017	$10\sqrt{3}$	0.00002	$\pm$	0.00001	78.0
	+1 cm (10 $\times$ limit)	-0.00099	$\pm$	0.00017	$10\sqrt{3}$	-0.00006	$\pm$	0.00001	
4	-1 cm (10 $\times$ limit)	0.00059	$\pm$	0.00017	$10\sqrt{3}$	0.00003	$\pm$	0.00001	72.0
	+1 cm (10 $\times$ limit)	-0.00073	$\pm$	0.00017	$10\sqrt{3}$	-0.00004	$\pm$	0.00001	
5	-1 cm (10 $\times$ limit)	0.00042	$\pm$	0.00016	$10\sqrt{3}$	0.00002	$\pm$	0.00001	91.0
	+1 cm (10 $\times$ limit)	-0.00111	$\pm$	0.00016	$10\sqrt{3}$	-0.00006	$\pm$	0.00001	

### Clad Dimensions

The uncertainty in the clad dimensions was unreported, and detailed dimensions for anything similar to the diagram shown in Figure 1.60 of [HTTR-GCR-RESR-001](#) were unavailable. Therefore a solid clad material encasing the control rod absorber was defined without detail for the end caps. Inner and outer thicknesses were varied  $\pm 5$  mm from the nominal values of 65 and 113 mm (Table 1.15 of [HTTR-GCR-RESR-001](#)), respectively, to determine their effects on the uncertainty of  $k_{\text{eff}}$ . The spine diameter was varied  $\pm 10$  mm from the nominal value of 10 mm (Table 1.15 of [HTTR-GCR-RESR-001](#)) and its effect on the uncertainty of  $k_{\text{eff}}$  was determined. The clad height of a single control rod section was varied  $\pm 1$  cm. The reported clad thickness of 3.5 mm does not appear to conform to the difference between reported diameters of the clad and absorber materials. It is unclear whether a gap exists or there is rounding of values in the original table. The uncertainties evaluated encompass the overall uncertainty in this discrepancy. The control rod diameters are chosen as the more appropriate dimensions for modeling, such that inner and outer clad thicknesses are approximately 5 and 4 mm, respectively. Results are shown in Tables 2.21 through 2.24.

Height change of clad also affects the effective height of each control rod segment.

Because of the tight manufacturing tolerances of the fuel compacts and graphite sleeves (Sections 2.1.2.2 and 2.1.2.3, respectively) it is believed that tighter tolerances apply to the absorber cladding. Therefore, the diameters are treated with a tolerance (with uniform probability) of  $\pm 0.5$  mm and a height tolerance (with uniform probability) of  $\pm 1.0$  mm. The appropriate corrections to the scaling factors have been incorporated into the uncertainty analysis of these parameters.

The total number of control rod sections used in the fully-loaded core is approximately 97.5, as approximately 30% of the control rods are actually inserted into the core. For determining the random component of the uncertainty, the results in Tables 2.21 through 2.24 would be divided by  $\sqrt{N}$ , where N for each case is shown in Tables 2.21 through 2.24.

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.21. Effect of Uncertainty in CR Clad Dimensions (Inner Diameter).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-5 mm (10 $\times$ limit)	-0.00004	$\pm$	0.00016	$10\sqrt{3}$	0.00000	$\pm$	0.00001	22.5
	+5 mm (10 $\times$ limit)	-0.00018	$\pm$	0.00017	$10\sqrt{3}$	-0.00001	$\pm$	0.00001	
2	-5 mm (10 $\times$ limit)	-0.00003	$\pm$	0.00017	$10\sqrt{3}$	0.00000	$\pm$	0.00001	58.5
	+5 mm (10 $\times$ limit)	0.00021	$\pm$	0.00016	$10\sqrt{3}$	0.00001	$\pm$	0.00001	
3	-5 mm (10 $\times$ limit)	-0.00003	$\pm$	0.00016	$10\sqrt{3}$	0.00000	$\pm$	0.00001	78.0
	+5 mm (10 $\times$ limit)	-0.00019	$\pm$	0.00017	$10\sqrt{3}$	-0.00001	$\pm$	0.00001	
4	-5 mm (10 $\times$ limit)	-0.00007	$\pm$	0.00017	$10\sqrt{3}$	0.00000	$\pm$	0.00001	72.0
	+5 mm (10 $\times$ limit)	-0.00011	$\pm$	0.00017	$10\sqrt{3}$	-0.00001	$\pm$	0.00001	
5	-5 mm (10 $\times$ limit)	-0.00002	$\pm$	0.00016	$10\sqrt{3}$	0.00000	$\pm$	0.00001	91.0
	+5 mm (10 $\times$ limit)	-0.00006	$\pm$	0.00016	$10\sqrt{3}$	0.00000	$\pm$	0.00001	

Table 2.22. Effect of Uncertainty in CR Clad Dimensions (Outer Diameter).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-5 mm (10 $\times$ limit)	-0.00033	$\pm$	0.00017	$10\sqrt{3}$	-0.00002	$\pm$	0.00001	22.5
	+5 mm (10 $\times$ limit)	0.00018	$\pm$	0.00017	$10\sqrt{3}$	0.00001	$\pm$	0.00001	
2	-5 mm (10 $\times$ limit)	-0.00053	$\pm$	0.00017	$10\sqrt{3}$	-0.00003	$\pm$	0.00001	58.5
	+5 mm (10 $\times$ limit)	0.00028	$\pm$	0.00016	$10\sqrt{3}$	0.00002	$\pm$	0.00001	
3	-5 mm (10 $\times$ limit)	-0.00082	$\pm$	0.00017	$10\sqrt{3}$	-0.00005	$\pm$	0.00001	78.0
	+5 mm (10 $\times$ limit)	0.00055	$\pm$	0.00016	$10\sqrt{3}$	0.00003	$\pm$	0.00001	
4	-5 mm (10 $\times$ limit)	-0.00169	$\pm$	0.00017	$10\sqrt{3}$	-0.00010	$\pm$	0.00001	72.0
	+5 mm (10 $\times$ limit)	0.00108	$\pm$	0.00017	$10\sqrt{3}$	0.00006	$\pm$	0.00001	
5	-5 mm (10 $\times$ limit)	-0.00087	$\pm$	0.00016	$10\sqrt{3}$	-0.00005	$\pm$	0.00001	91.0
	+5 mm (10 $\times$ limit)	0.00058	$\pm$	0.00016	$10\sqrt{3}$	0.00003	$\pm$	0.00001	

Table 2.23. Effect of Uncertainty in CR Clad Dimensions (Height).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-1 cm (10 $\times$ limit)	0.00036	$\pm$	0.00016	$10\sqrt{3}$	-0.00002	$\pm$	0.00001	22.5
	+1 cm (10 $\times$ limit)	-0.00046	$\pm$	0.00016	$10\sqrt{3}$	-0.00003	$\pm$	0.00001	
2	-1 cm (10 $\times$ limit)	0.00188	$\pm$	0.00017	$10\sqrt{3}$	-0.00011	$\pm$	0.00001	58.5
	+1 cm (10 $\times$ limit)	-0.00192	$\pm$	0.00017	$10\sqrt{3}$	-0.00011	$\pm$	0.00001	
3	-1 cm (10 $\times$ limit)	0.00243	$\pm$	0.00017	$10\sqrt{3}$	-0.00014	$\pm$	0.00001	78.0
	+1 cm (10 $\times$ limit)	-0.00231	$\pm$	0.00017	$10\sqrt{3}$	-0.00013	$\pm$	0.00001	
4	-1 cm (10 $\times$ limit)	0.00136	$\pm$	0.00017	$10\sqrt{3}$	-0.00008	$\pm$	0.00001	72.0
	+1 cm (10 $\times$ limit)	-0.00130	$\pm$	0.00017	$10\sqrt{3}$	-0.00008	$\pm$	0.00001	
5	-1 cm (10 $\times$ limit)	0.00235	$\pm$	0.00016	$10\sqrt{3}$	-0.00014	$\pm$	0.00001	91.0
	+1 cm (10 $\times$ limit)	-0.00258	$\pm$	0.00016	$10\sqrt{3}$	-0.00015	$\pm$	0.00001	

Table 2.24. Effect of Uncertainty in CR Clad Dimensions (Spine Diameter).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-10 mm (20 $\times$ limit)	-0.00002	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000	22.5
	+10 mm (20 $\times$ limit)	0.00001	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000	
2	-10 mm (20 $\times$ limit)	0.00008	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000	58.5
	+10 mm (20 $\times$ limit)	0.00014	$\pm$	0.00016	$20\sqrt{3}$	0.00000	$\pm$	0.00000	
3	-10 mm (20 $\times$ limit)	-0.00002	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000	78.0
	+10 mm (20 $\times$ limit)	-0.00017	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000	
4	-10 mm (20 $\times$ limit)	-0.00010	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000	72.0
	+10 mm (20 $\times$ limit)	0.00010	$\pm$	0.00016	$20\sqrt{3}$	0.00000	$\pm$	0.00000	
5	-10 mm (20 $\times$ limit)	-0.00026	$\pm$	0.00016	$20\sqrt{3}$	-0.00001	$\pm$	0.00000	91.0
	+10 mm (20 $\times$ limit)	0.00007	$\pm$	0.00016	$20\sqrt{3}$	0.00000	$\pm$	0.00000	

### 2.1.2.6 Instrumentation

Insufficient information is available to comprehensively model and evaluate the uncertainties and biases related to the utility of instrumentation in the HTTR. Neglect of instrumentation inclusion in the model would be a bias; uncertainty in the dimensions and composition of the instrumentation would provide uncertainty in that bias or uncertainty in the model should it have been included in the benchmark model. An approximation of the instrumentation in the HTTR was modeled using information from Section 1.1.2.3 of [HTTR-GCR-RESR-001](#) and approximate diagrams shown in a presentation at the IAEA CRP-

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

5 Meeting.<sup>a</sup> The expected bias in the instrumentation, from the aforementioned reference, is  $\sim 0.2\%$   $\Delta k/k$ .

Figures 2.1 through 2.4 provide basic geometric descriptions of the instrumentation utilized in the HTTR core. Figure 2.1 shows the respective heights. Figure 2.2, 2.3, and 2.4 provide additional information regarding channels 1, 2, and 3, respectively (columns E05, E13, and E21, respectively, in Figure 2.5). The 5-cm long 0.6-cm diameter  $\text{BF}_3$  counters were modeled containing gas at 1 atm with 100 at.%  $^{10}\text{B}$  content. All metallic components were modeled as aluminum. Approximate dimensions were used based on scaling of the Figures 2.2 through 2.4 and the known hole diameter of 123 mm.

Approximate biases were calculated for the annular core configurations (Table 3.1). The bias for the fully-loaded core critical was calculated to be  $0.254 \pm 0.073\%$   $\Delta k/k$  (HTTR-GCR-RESR-001 Section 3.1.1.1), which is similar to the previously reported value. The uncertainty in the biases was approximated by dividing the biases in half, and then treating it as a bounding uncertainty and dividing by  $\sqrt{3}$ . The uncertainty in the instrumentation is included in the total benchmark model uncertainty, and is provided in Table 3.1. The instrumentation is not included in the benchmark model but the bias in used to correct the experimental  $k_{\text{eff}}$ . Because the actual dimensions and material properties are approximated, this uncertainty is treated as completely systematic with no random components.





Figure 2.1. Vertical Position of the Temporary Neutron Detectors (Ref 1, p. 314).

$\text{BF}_3$  = boron-trifluoride neutron detector

CIC = gamma-ray compensated ionization chamber


FC = micro-fission chamber

<sup>a</sup> N. Fujimoto, N. Nojiri, and K. Yamashita, "HTTR's Benchmark Calculation of Start-Up Core Physics Tests," Report of the 3<sup>rd</sup> Research Coordination Meeting on the CRP, IAEA, Oarai, Japan, March 12-16 (2001).


Figure 2.2. Approximation of Instrumentation Channel 1 (Column E05).<sup>a</sup>

<sup>a</sup> N. Fujimoto, N. Nojiri, and K. Yamashita, "HTTR's Benchmark Calculation of Start-Up Core Physics Tests," Report of the 3<sup>rd</sup> Research Coordination Meeting on the CRP, IAEA, Oarai, Japan, March 12-16 (2001).




Figure 2.3. Approximation of Instrumentation Channel 2 (Column E13).<sup>a</sup>

<sup>a</sup> N. Fujimoto, N. Nojiri, and K. Yamashita, "HTTR's Benchmark Calculation of Start-Up Core Physics Tests," Report of the 3<sup>rd</sup> Research Coordination Meeting on the CRP, IAEA, Oarai, Japan, March 12-16 (2001).



Page 34 of 183

North  
↑

09-GA50001-61

Figure 2.5. Fuel Column Name and Zone Number in the HTTR Core (adapted from [Ref. 2, p. 12](#)).



## 2.1.2.7 Graphite Blocks

**Block Dimensions**

An uncertainty in the block dimensions was unreported. The uncertainty in the flat-to-flat distance and the height were each varied  $\pm 1$  mm from their nominal values of 360 and 580 cm (Tables 1.13 and 1.16 of [HTTR-GCR-RESR-001](#)), respectively, and their effects on the uncertainty of  $k_{\text{eff}}$  were determined. The average gap between columns was reported as approximately 2 mm ([Ref. 2, p. 13](#)), allowing room for the flat-to-flat uncertainty. All graphite blocks were varied with this analysis: fuel, reflector, control, instrumentation, and dummy. Results are shown in Tables 2.25 and 2.26.

Because of the tight manufacturing tolerances of the fuel compacts and graphite sleeves (Sections 2.1.2.2 and 2.1.2.3, respectively) it is believed that similar tolerances apply to other graphite and boron carbide components of the HTTR. Therefore, the graphite block dimensions are treated with a tolerance (with uniform probability) of  $\pm 0.1$  mm. The appropriate corrections to the scaling factors have been incorporated into the uncertainty analysis of these parameters.

The total number of graphite blocks used in all core configurations is 549. For determining the random component of the uncertainty, the results in Tables 2.25 and 2.26 would be divided by  $\sqrt{549}$ .

Table 2.25. Effect of Uncertainty in Graphite Block Dimensions (Flat-to-Flat Distance).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	-1 mm (10 $\times$ limit)	-0.00263	$\pm$	0.00016	$10\sqrt{3}$	-0.00015	$\pm$	0.00001
	+1 mm (10 $\times$ limit)	0.00238	$\pm$	0.00017	$10\sqrt{3}$	0.00014	$\pm$	0.00001
2	-1 mm (10 $\times$ limit)	-0.00242	$\pm$	0.00016	$10\sqrt{3}$	-0.00014	$\pm$	0.00001
	+1 mm (10 $\times$ limit)	0.00222	$\pm$	0.00017	$10\sqrt{3}$	0.00013	$\pm$	0.00001
3	-1 mm (10 $\times$ limit)	-0.00335	$\pm$	0.00017	$10\sqrt{3}$	-0.00019	$\pm$	0.00001
	+1 mm (10 $\times$ limit)	0.00247	$\pm$	0.00016	$10\sqrt{3}$	0.00014	$\pm$	0.00001
4	-1 mm (10 $\times$ limit)	-0.00385	$\pm$	0.00017	$10\sqrt{3}$	-0.00022	$\pm$	0.00001
	+1 mm (10 $\times$ limit)	0.00308	$\pm$	0.00017	$10\sqrt{3}$	0.00018	$\pm$	0.00001
5	-1 mm (10 $\times$ limit)	-0.00384	$\pm$	0.00016	$10\sqrt{3}$	-0.00022	$\pm$	0.00001
	+1 mm (10 $\times$ limit)	0.00311	$\pm$	0.00016	$10\sqrt{3}$	0.00018	$\pm$	0.00001

Table 2.26. Effect of Uncertainty in Graphite Block Dimensions (Height).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	-1 mm (10 $\times$ limit)	0.00006	$\pm$	0.00017	$10\sqrt{3}$	0.00000	$\pm$	0.00001
	+1 mm (10 $\times$ limit)	-0.00004	$\pm$	0.00016	$10\sqrt{3}$	0.00000	$\pm$	0.00001
2	-1 mm (10 $\times$ limit)	0.00005	$\pm$	0.00017	$10\sqrt{3}$	0.00000	$\pm$	0.00001
	+1 mm (10 $\times$ limit)	0.00010	$\pm$	0.00017	$10\sqrt{3}$	0.00001	$\pm$	0.00001
3	-1 mm (10 $\times$ limit)	0.00006	$\pm$	0.00017	$10\sqrt{3}$	0.00000	$\pm$	0.00001
	+1 mm (10 $\times$ limit)	0.00001	$\pm$	0.00017	$10\sqrt{3}$	0.00000	$\pm$	0.00001
4	-1 mm (10 $\times$ limit)	-0.00010	$\pm$	0.00017	$10\sqrt{3}$	-0.00001	$\pm$	0.00001
	+1 mm (10 $\times$ limit)	-0.00015	$\pm$	0.00017	$10\sqrt{3}$	-0.00001	$\pm$	0.00001
5	-1 mm (10 $\times$ limit)	-0.00002	$\pm$	0.00016	$10\sqrt{3}$	0.00000	$\pm$	0.00001
	+1 mm (10 $\times$ limit)	-0.00006	$\pm$	0.00016	$10\sqrt{3}$	0.00000	$\pm$	0.00001

**Dowel/Socket Dimensions**

Insufficient information is available to completely model and evaluate the uncertainties and biases related to the incorporation of dowels and sockets in the HTTR. Uncertainty in the volume fraction will be included as part of the assessment of the uncertainty in the total density of the graphite blocks.

**Coolant Channel Diameter**

An assumed variation of  $\pm 2$  mm in the diameter of the coolant channels of the fuel blocks (nominally 41 mm, Table 1.13 of [HTTR-GCR-RESR-001](#)) and reflector blocks (nominally 23 mm) in the fuel columns was performed to determine the effective uncertainty in  $k_{\text{eff}}$ . Results are shown in Tables 2.27 and 2.28.

Insufficient information was available to determine the dimensions of the coolant channels of the lowest reflector blocks. They were modeled similar to the other reflector blocks utilized in the fuel columns. No bias or biased uncertainty was assessed.

Because of the tight manufacturing tolerances of the fuel compacts and graphite sleeves (Sections 2.1.2.2 and 2.1.2.3, respectively) it is believed that similar tolerances apply to other graphite and boron carbide components of the HTTR. Therefore, the coolant channel diameters are treated with a tolerance (with uniform probability) of  $\pm 0.1$  mm. The appropriate corrections to the scaling factors have been incorporated into the uncertainty analysis of these parameters.

The total number of fuel coolant channels used in the fully-loaded core is 4,770. For determining the random component of the uncertainty, the results in Table 2.27 would be divided by  $\sqrt{N}$ . The total number of reflector coolant channels in all core configurations is 3,816. For determining the random component of the uncertainty, the results in Table 2.28 would be divided by  $\sqrt{3,816}$ .

Table 2.27. Effect of Uncertainty in Coolant Channel Diameter (Fuel Blocks).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-2 mm (20 $\times$ limit)	0.00620	$\pm$	0.00017	$20\sqrt{3}$	0.00018	$\pm$	0.00000	2,955
	+2 mm (20 $\times$ limit)	-0.00644	$\pm$	0.00017	$20\sqrt{3}$	-0.00019	$\pm$	0.00000	
2	-2 mm (20 $\times$ limit)	0.00694	$\pm$	0.00016	$20\sqrt{3}$	0.00020	$\pm$	0.00000	3,285
	+2 mm (20 $\times$ limit)	-0.00705	$\pm$	0.00017	$20\sqrt{3}$	-0.00020	$\pm$	0.00000	
3	-2 mm (20 $\times$ limit)	0.00730	$\pm$	0.00016	$20\sqrt{3}$	0.00021	$\pm$	0.00000	3,780
	+2 mm (20 $\times$ limit)	-0.00814	$\pm$	0.00016	$20\sqrt{3}$	-0.00023	$\pm$	0.00000	
4	-2 mm (20 $\times$ limit)	0.00837	$\pm$	0.00016	$20\sqrt{3}$	0.00024	$\pm$	0.00000	3,780
	+2 mm (20 $\times$ limit)	-0.00929	$\pm$	0.00017	$20\sqrt{3}$	-0.00027	$\pm$	0.00000	
5	-2 mm (20 $\times$ limit)	0.00787	$\pm$	0.00016	$20\sqrt{3}$	0.00023	$\pm$	0.00000	4,275
	+2 mm (20 $\times$ limit)	-0.00889	$\pm$	0.00016	$20\sqrt{3}$	-0.00026	$\pm$	0.00000	

Table 2.28. Effect of Uncertainty in Coolant Channel Diameter (Reflector Blocks).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	-2 mm (20 $\times$ limit)	0.00039	$\pm$	0.00016	$20\sqrt{3}$	0.00001	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00072	$\pm$	0.00017	$20\sqrt{3}$	-0.00002	$\pm$	0.00000
2	-2 mm (20 $\times$ limit)	0.00045	$\pm$	0.00017	$20\sqrt{3}$	0.00001	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00008	$\pm$	0.00016	$20\sqrt{3}$	0.00000	$\pm$	0.00000
3	-2 mm (20 $\times$ limit)	0.00028	$\pm$	0.00016	$20\sqrt{3}$	0.00001	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00072	$\pm$	0.00016	$20\sqrt{3}$	-0.00002	$\pm$	0.00000
4	-2 mm (20 $\times$ limit)	0.00009	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00054	$\pm$	0.00017	$20\sqrt{3}$	-0.00002	$\pm$	0.00000
5	-2 mm (20 $\times$ limit)	0.00026	$\pm$	0.00016	$20\sqrt{3}$	0.00001	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00045	$\pm$	0.00016	$20\sqrt{3}$	-0.00001	$\pm$	0.00000

### **Fuel and Coolant Channel Pitch**

An uncertainty in the fuel and coolant channel pitches in the fuel columns was not reported. For the evaluation of this uncertainty, the channels were modeled closer together then further apart by adjusting the pitch between them. A variation of  $\pm 2.0$  mm from the nominal pitch of 51.5 mm (Figures 1.52 and 1.53 of [HTTR-GCR-RESR-001](#)) was assumed and the effects on the uncertainty of  $k_{\text{eff}}$  were determined. Results are shown in Table 2.29.

Because of the tight manufacturing tolerances of the fuel compacts and graphite sleeves (Sections 2.1.2.2 and 2.1.2.3, respectively) it is believed that similar tolerances apply to other graphite and boron carbide components of the HTTR. Therefore, the coolant channel pitch is treated with a tolerance (with uniform

probability) of  $\pm 0.1$  mm. The appropriate corrections to the scaling factors have been incorporated into the uncertainty analysis of these parameters.

The total number of pitch positions used in the fully-loaded core is 8,586. For determining the random component of the uncertainty, the results in Table 2.29 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.29.

Table 2.29. Effect of Uncertainty in Fuel and Coolant Channel Pitch.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-2 mm ( $20 \times$ limit)	-0.00620	$\pm$	0.00017	$20\sqrt{3}$	-0.00018	$\pm$	0.00000	6,771
	+2 mm ( $20 \times$ limit)	0.00628	$\pm$	0.00017	$20\sqrt{3}$	0.00018	$\pm$	0.00000	
2	-2 mm ( $20 \times$ limit)	-0.00584	$\pm$	0.00016	$20\sqrt{3}$	-0.00017	$\pm$	0.00000	7,101
	+2 mm ( $20 \times$ limit)	0.00583	$\pm$	0.00016	$20\sqrt{3}$	0.00017	$\pm$	0.00000	
3	-2 mm ( $20 \times$ limit)	-0.00510	$\pm$	0.00016	$20\sqrt{3}$	-0.00015	$\pm$	0.00000	7,596
	+2 mm ( $20 \times$ limit)	0.00472	$\pm$	0.00017	$20\sqrt{3}$	0.00014	$\pm$	0.00000	
4	-2 mm ( $20 \times$ limit)	-0.00485	$\pm$	0.00017	$20\sqrt{3}$	-0.00014	$\pm$	0.00000	7,596
	+2 mm ( $20 \times$ limit)	0.00474	$\pm$	0.00017	$20\sqrt{3}$	0.00014	$\pm$	0.00000	
5	-2 mm ( $20 \times$ limit)	-0.00413	$\pm$	0.0016	$20\sqrt{3}$	-0.00012	$\pm$	0.00000	8,091
	+2 mm ( $20 \times$ limit)	0.00411	$\pm$	0.00016	$20\sqrt{3}$	0.00012	$\pm$	0.00000	

### **Handling Socket Dimensions**

The handling sockets were not included in the model as there was insufficient information to model them completely. The calculated volume of the socket (estimated using dimensions in Figure 1.52 of [HTTR-GCR-RESR-001](#)) is roughly 0.5 vol. % of the complete block envelope. This volume reduction is included as a reduction in total block density in the benchmark model. A bias has not been assessed. Uncertainty in the volume fraction will be included as part of the assessment of the uncertainty in the total density of the graphite blocks.

### **Column Pitch**

An uncertainty in column pitch was assumed based upon the average distance between blocks of approximately 2 mm. For the evaluation of this uncertainty, the columns were modeled closer together then further apart by adjusting the pitch between them. A variation of  $\pm 2$  mm ( $2 \times$  bounding limit) from the nominal value of 362 mm was analyzed and the effects on the uncertainty of  $k_{\text{eff}}$  were determined. Results are shown in Table 2.30.

The total number of columns used in all core configurations is 61. For determining the random component of the uncertainty, the results in Table 2.30 would be divided by  $\sqrt{61}$ .

Table 2.30. Effect of Uncertainty in Column Pitch.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	-2 mm	0.00204	$\pm$	0.00017	$2\sqrt{3}$	0.00059	$\pm$	0.00005
	+2 mm	-0.00249	$\pm$	0.00017	$2\sqrt{3}$	-0.00072	$\pm$	0.00005
2	-2 mm	0.00215	$\pm$	0.00017	$2\sqrt{3}$	0.00062	$\pm$	0.00005
	+2 mm	-0.00231	$\pm$	0.00017	$2\sqrt{3}$	-0.00067	$\pm$	0.00005
3	-2 mm	0.00203	$\pm$	0.00017	$2\sqrt{3}$	0.00059	$\pm$	0.00005
	+2 mm	-0.00251	$\pm$	0.00017	$2\sqrt{3}$	-0.00072	$\pm$	0.00005
4	-2 mm	0.00185	$\pm$	0.00017	$2\sqrt{3}$	0.00053	$\pm$	0.00005
	+2 mm	-0.00267	$\pm$	0.00017	$2\sqrt{3}$	-0.00077	$\pm$	0.00005
5	-2 mm	0.00219	$\pm$	0.00016	$2\sqrt{3}$	0.00063	$\pm$	0.00005
	+2 mm	-0.00224	$\pm$	0.00016	$2\sqrt{3}$	-0.00065	$\pm$	0.00004

### **Control-Rod Channel Diameter**

An assumed variation of  $\pm 2$  mm in the diameter of the control-rod coolant channels (nominal value of 123 mm, Figure 1.64 of [HTTR-GCR-RESR-001](#)) in the control block columns was performed to determine the effective uncertainty in  $k_{\text{eff}}$ . Results are shown in Table 2.31.

Because of the tight manufacturing tolerances of the fuel compacts and graphite sleeves (Sections 2.1.2.2 and 2.1.2.3, respectively) it is believed that similar tolerances apply to other graphite and boron carbide components of the HTTR. Therefore, the control-rod channel diameter is treated with a tolerance (with uniform probability) of  $\pm 0.1$  mm. The appropriate corrections to the scaling factors have been incorporated into the uncertainty analysis of these parameters.

The total number of control-rod channels (including empty instrumentation channels) in blocks used in all core configurations is approximately 437. For determining the random component of the uncertainty, the results in Table 2.31 would be divided by  $\sqrt{437}$ .

Table 2.31. Effect of Uncertainty in CR Channel Diameter.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	-2 mm (20 $\times$ limit)	0.00111	$\pm$	0.00017	$20\sqrt{3}$	0.00003	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00142	$\pm$	0.00017	$20\sqrt{3}$	-0.00004	$\pm$	0.00000
2	-2 mm (20 $\times$ limit)	0.00136	$\pm$	0.00017	$20\sqrt{3}$	0.00004	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00126	$\pm$	0.00016	$20\sqrt{3}$	-0.00004	$\pm$	0.00000
3	-2 mm (20 $\times$ limit)	0.00131	$\pm$	0.00016	$20\sqrt{3}$	0.00004	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00148	$\pm$	0.00016	$20\sqrt{3}$	-0.00004	$\pm$	0.00000
4	-2 mm (20 $\times$ limit)	0.00122	$\pm$	0.00017	$20\sqrt{3}$	0.00004	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00169	$\pm$	0.00017	$20\sqrt{3}$	-0.00005	$\pm$	0.00000
5	-2 mm (20 $\times$ limit)	0.00144	$\pm$	0.00016	$20\sqrt{3}$	0.00004	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00149	$\pm$	0.00016	$20\sqrt{3}$	-0.00004	$\pm$	0.00000

### **Control-Rod Channel Pitch**

An uncertainty in control-rod coolant channel pitch in the fuel and reflector blocks was not reported. For the evaluation of this uncertainty, the channels were modeled closer together then further apart by adjusting the pitch between them. A variation of  $\pm 2$  mm from the nominal distance of 108 mm from the block axis (Figure 1.64 of [HTTR-GCR-RESR-001](#)) was assumed and the effects on the uncertainty of  $k_{\text{eff}}$  were determined. Results are shown in Table 2.32.

Because of the tight manufacturing tolerances of the fuel compacts and graphite sleeves (Sections 2.1.2.2 and 2.1.2.3, respectively) it is believed that similar tolerances apply to other graphite and boron carbide components of the HTTR. Therefore, the control-rod channel pitch is treated with a tolerance (with uniform probability) of  $\pm 0.1$  mm. The appropriate corrections to the scaling factors have been incorporated into the uncertainty analysis of these parameters.

The total number of control-rod channels (including empty instrumentation channels) in blocks used in the all core configurations is approximately 437. For determining the random component of the uncertainty, the results in Table 2.32 would be divided by  $\sqrt{437}$ .

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.32. Effect of Uncertainty in Control-Rod Channel Pitch.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	-2 mm (20 $\times$ limit)	-0.00009	$\pm$	0.00016	$20\sqrt{3}$	0.00000	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00004	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000
2	-2 mm (20 $\times$ limit)	0.00044	$\pm$	0.00017	$20\sqrt{3}$	0.00001	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	0.00010	$\pm$	0.00016	$20\sqrt{3}$	0.00000	$\pm$	0.00000
3	-2 mm (20 $\times$ limit)	-0.00005	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00023	$\pm$	0.00017	$20\sqrt{3}$	-0.00001	$\pm$	0.00000
4	-2 mm (20 $\times$ limit)	-0.00007	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	-0.00031	$\pm$	0.00017	$20\sqrt{3}$	-0.00001	$\pm$	0.00000
5	-2 mm (20 $\times$ limit)	-0.00002	$\pm$	0.00016	$20\sqrt{3}$	0.00000	$\pm$	0.00000
	+2 mm (20 $\times$ limit)	0.00012	$\pm$	0.00016	$20\sqrt{3}$	0.00000	$\pm$	0.00000

### 2.1.2.8 Permanent Reflectors

Insufficient information is available to model in detail the permanent reflector of the HTTR. A bias was not assessed for any simplification of the permanent reflector. The actual reflector is in the shape of a dodecagon block with an overall diameter and length of 4250 mm and 5250 mm, respectively. It is unclear as to whether the diameter is inscribed within or circumscribed around the polygon.

A radial representation of the permanent reflector had the outer diameter varied  $\pm 10$  cm to determine the effective change in  $\Delta k$ . The difference between the reported diameter and an equivalent diameter circle representative of an inscribed or circumscribed dodecagon would be -10 cm and +5 cm, respectively. This uncertainty is treated as a bounding uncertainty. Any uncertainty in the unreported manufacturing tolerances would be negligible. Results are shown in Table 2.33.

The permanent reflector is comprised of 12 circumferential segments in eight axial layers for a total of 96 blocks. However, the uncertainty in the diameter of the model's permanent reflector is not adjusted for random uncertainty and treated as 100% systematic because of the uncertainty in the overall detail of the permanent reflector.

Table 2.33. Effect of Uncertainty in Permanent Reflector Diameter.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	-10 cm	-0.00202	$\pm$	0.00017	$\sqrt{3}$	-0.00117	$\pm$	0.00010
	+10 cm	0.00155	$\pm$	0.00016	$2\sqrt{3}$	0.00045	$\pm$	0.00005
2	-10 cm	-0.00144	$\pm$	0.00016	$\sqrt{3}$	-0.00083	$\pm$	0.00009
	+10 cm	0.00150	$\pm$	0.00017	$2\sqrt{3}$	0.00043	$\pm$	0.00005
3	-10 cm	-0.00145	$\pm$	0.00016	$\sqrt{3}$	-0.00084	$\pm$	0.00009
	+10 cm	0.00119	$\pm$	0.00016	$2\sqrt{3}$	0.00034	$\pm$	0.00005
4	-10 cm	-0.00093	$\pm$	0.00017	$\sqrt{3}$	-0.00054	$\pm$	0.00010
	+10 cm	0.00050	$\pm$	0.00017	$2\sqrt{3}$	0.00014	$\pm$	0.00005
5	-10 cm	-0.00144	$\pm$	0.00016	$\sqrt{3}$	-0.00083	$\pm$	0.00009
	+10 cm	0.00083	$\pm$	0.00016	$2\sqrt{3}$	0.00024	$\pm$	0.00005

### 2.1.2.9 Dummy Blocks

The uncertainty in the outer dimensions of the dummy blocks was included with the graphite block analysis in Section 2.1.2.7. There are two types of dummy blocks, one with a hole pattern similar to that of a control block, and the other with three holes but of smaller diameter (Ref. 2, p. 14). Because the true dimensions of the smaller hole design is unknown, the dummy blocks will all be modeled with the holes of the control blocks but an additional uncertainty will be added to account for this discrepancy. This uncertainty will be assessed by completely filling the holes of the dummy blocks with IG-11 graphite material (Section 2.1.3.9).

## 2.1.3 Compositional Variations

### 2.1.3.1 Coated Fuel Particles

#### Uranium Enrichment

The concentration of  $^{234}\text{U}$  expected in the TRISO fuel had to be determined, as it was not provided. First the weight fractions of isotopes in natural uranium dioxide were determined. Then the enriched weight percent of  $^{235}\text{U}$  was multiplied by the natural weight percent of  $^{234}\text{U}$  (0.0055 at.%) and divided by the natural weight percent of  $^{235}\text{U}$  (0.72 at.%). Thus an approximate concentration of “enriched”  $^{234}\text{U}$  content could be determined for this evaluation, which may slightly underestimate the actual  $^{234}\text{U}$  content.

$$\gamma_{^{234}\text{U}}^{\text{Enriched}} = \frac{\gamma_{^{234}\text{U}}^{\text{Natural}}}{\gamma_{^{235}\text{U}}^{\text{Natural}}} \gamma_{^{235}\text{U}}^{\text{Enriched}}.$$

Information was not provided regarding the uncertainty in the uranium enrichment of the TRISO kernels. It is reported elsewhere that the manufacturing tolerance limit for the enrichment is 4.5% of the reported weight percent.<sup>a</sup> For example, the enrichment of 3.4 wt.% is bound within a tolerance of  $\pm 0.153$  wt.%.

<sup>a</sup> S. Maruyama, K. Yamashita, N. Fujimoto, I. Murata, R. Shindo, and Y. Sudo, “Determination of Hot Spot Factors for Calculation of the Maximum Fuel Temperatures in the Core Thermal and Hydraulic Design of HTTR,” JAERI-M 88-250, JAEA (November 18, 1988). [in Japanese].



## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

The  $^{234}\text{U}$  content adjusted to match the effective increase or decrease in enrichment of  $^{235}\text{U}$ , to determine the effective uncertainty in  $k_{\text{eff}}$ . The nominal enrichment values are shown in Figure 1.46 and Table 1.11 of [HTTR-GCR-RESR-001](#). Results are shown in Tables 2.34 through 2.38. The actual uncertainty in the uranium enrichment is much smaller than the manufacturing limits; however this information is not publicly available. Therefore, the bounding limits are treated with a normal distribution instead of one with uniform probability.

Configurations 1 through 4 do not contain uranium fuel with the enrichments of 3.40 and 6.70 wt.%.

The uncertainty in the uranium enrichment is considered all systematic with no random component.

Table 2.34. Effect of Uncertainty in Uranium Enrichment (Case 1).

Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
-0.1755 wt.% of 3.9 wt.%	-0.00012	$\pm$	0.00016	3	-0.00004	$\pm$	0.00005
+0.1755 wt.% of 3.9 wt.%	0.00035	$\pm$	0.00016	3	0.00012	$\pm$	0.00005
-0.1935 wt.% of 4.3 wt.%	-0.00163	$\pm$	0.00016	3	-0.00054	$\pm$	0.00005
+0.1935 wt.% of 4.3 wt.%	0.00162	$\pm$	0.00016	3	0.00054	$\pm$	0.00005
-0.216 wt.% of 4.8 wt.%	-0.00069	$\pm$	0.00016	3	-0.00023	$\pm$	0.00005
+0.216 wt.% of 4.8 wt.%	0.00066	$\pm$	0.00016	3	0.00022	$\pm$	0.00005
-0.234 wt.% of 5.2 wt.%	-0.00018	$\pm$	0.00016	3	-0.00006	$\pm$	0.00005
+0.234 wt.% of 5.2 wt.%	0.00023	$\pm$	0.00016	3	0.00008	$\pm$	0.00005
-0.2655 wt.% of 5.9 wt.%	-0.00189	$\pm$	0.00016	3	-0.00063	$\pm$	0.00005
+0.2655 wt.% of 5.9 wt.%	0.00180	$\pm$	0.00016	3	0.00060	$\pm$	0.00005
-0.2835 wt.% of 6.3 wt.%	-0.00127	$\pm$	0.00016	3	-0.00042	$\pm$	0.00005
+0.2835 wt.% of 6.3 wt.%	0.00101	$\pm$	0.00016	3	0.00034	$\pm$	0.00005
-0.324 wt.% of 7.2 wt.%	-0.00221	$\pm$	0.00016	3	-0.00074	$\pm$	0.00005
+0.324 wt.% of 7.2 wt.%	0.00238	$\pm$	0.00016	3	0.00079	$\pm$	0.00005
-0.3555 wt.% of 7.9 wt.%	-0.00114	$\pm$	0.00016	3	-0.00038	$\pm$	0.00005
+0.3555 wt.% of 7.9 wt.%	0.00143	$\pm$	0.00016	3	0.00048	$\pm$	0.00005
-0.423 wt.% of 9.4 wt.%	-0.00166	$\pm$	0.00016	3	-0.00055	$\pm$	0.00005
+0.423 wt.% of 9.4 wt.%	0.00186	$\pm$	0.00016	3	0.00062	$\pm$	0.00005
-0.4455 wt.% of 9.9 wt.%	-0.00093	$\pm$	0.00016	3	-0.00031	$\pm$	0.00005
+0.4455 wt.% of 9.9 wt.%	0.00081	$\pm$	0.00016	3	0.00027	$\pm$	0.00005

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.35. Effect of Uncertainty in Uranium Enrichment (Case 2).

Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
-0.1755 wt.% of 3.9 wt. %	-0.00091	$\pm$	0.00016	3	-0.00030	$\pm$	0.00005
+0.1755 wt.% of 3.9 wt. %	0.00068	$\pm$	0.00016	3	0.00023	$\pm$	0.00005
-0.1935 wt.% of 4.3 wt. %	-0.00244	$\pm$	0.00016	3	-0.00081	$\pm$	0.00005
+0.1935 wt.% of 4.3 wt. %	0.00220	$\pm$	0.00016	3	0.00073	$\pm$	0.00005
-0.216 wt.% of 4.8 wt. %	-0.00124	$\pm$	0.00016	3	-0.00041	$\pm$	0.00005
+0.216 wt.% of 4.8 wt. %	0.00110	$\pm$	0.00016	3	0.00037	$\pm$	0.00005
-0.234 wt.% of 5.2 wt. %	-0.00099	$\pm$	0.00016	3	-0.00033	$\pm$	0.00005
+0.234 wt.% of 5.2 wt. %	0.00051	$\pm$	0.00016	3	0.00017	$\pm$	0.00005
-0.2655 wt.% of 5.9 wt. %	-0.00229	$\pm$	0.00016	3	-0.00076	$\pm$	0.00005
+0.2655 wt.% of 5.9 wt. %	0.00227	$\pm$	0.00016	3	0.00076	$\pm$	0.00005
-0.2835 wt.% of 6.3 wt. %	-0.00202	$\pm$	0.00016	3	-0.00067	$\pm$	0.00005
+0.2835 wt.% of 6.3 wt. %	0.00140	$\pm$	0.00016	3	0.00047	$\pm$	0.00005
-0.324 wt.% of 7.2 wt. %	-0.00213	$\pm$	0.00016	3	-0.00071	$\pm$	0.00005
+0.324 wt.% of 7.2 wt. %	0.00180	$\pm$	0.00016	3	0.00060	$\pm$	0.00005
-0.3555 wt.% of 7.9 wt. %	-0.00114	$\pm$	0.00016	3	-0.00038	$\pm$	0.00005
+0.3555 wt.% of 7.9 wt. %	0.00093	$\pm$	0.00016	3	0.00031	$\pm$	0.00005
-0.423 wt.% of 9.4 wt. %	-0.00078	$\pm$	0.00016	3	-0.00026	$\pm$	0.00005
+0.423 wt.% of 9.4 wt. %	0.00048	$\pm$	0.00016	3	0.00016	$\pm$	0.00005
-0.4455 wt.% of 9.9 wt. %	-0.00044	$\pm$	0.00016	3	-0.00015	$\pm$	0.00005
+0.4455 wt.% of 9.9 wt. %	0.00013	$\pm$	0.00016	3	0.00004	$\pm$	0.00005

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.36. Effect of Uncertainty in Uranium Enrichment (Case 3).

Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
-0.1755 wt.% of 3.9 wt. %	-0.00193	$\pm$	0.00016	3	-0.00064	$\pm$	0.00005
+0.1755 wt.% of 3.9 wt. %	0.00231	$\pm$	0.00016	3	0.00077	$\pm$	0.00005
-0.1935 wt.% of 4.3 wt. %	-0.00277	$\pm$	0.00016	3	-0.00092	$\pm$	0.00005
+0.1935 wt.% of 4.3 wt. %	0.00293	$\pm$	0.00016	3	0.00098	$\pm$	0.00005
-0.216 wt.% of 4.8 wt. %	-0.00130	$\pm$	0.00016	3	-0.00043	$\pm$	0.00005
+0.216 wt.% of 4.8 wt. %	0.00157	$\pm$	0.00016	3	0.00052	$\pm$	0.00005
-0.234 wt.% of 5.2 wt. %	-0.00137	$\pm$	0.00016	3	-0.00046	$\pm$	0.00005
+0.234 wt.% of 5.2 wt. %	0.00148	$\pm$	0.00016	3	0.00049	$\pm$	0.00005
-0.2655 wt.% of 5.9 wt. %	-0.00175	$\pm$	0.00016	3	-0.00058	$\pm$	0.00005
+0.2655 wt.% of 5.9 wt. %	0.00212	$\pm$	0.00016	3	0.00071	$\pm$	0.00005
-0.2835 wt.% of 6.3 wt. %	-0.00135	$\pm$	0.00016	3	-0.00045	$\pm$	0.00005
+0.2835 wt.% of 6.3 wt. %	0.00155	$\pm$	0.00016	3	0.00052	$\pm$	0.00005
-0.324 wt.% of 7.2 wt. %	-0.00094	$\pm$	0.00016	3	-0.00031	$\pm$	0.00005
+0.324 wt.% of 7.2 wt. %	0.00108	$\pm$	0.00016	3	0.00036	$\pm$	0.00005
-0.3555 wt.% of 7.9 wt. %	-0.00034	$\pm$	0.00016	3	-0.00011	$\pm$	0.00005
+0.3555 wt.% of 7.9 wt. %	0.00051	$\pm$	0.00016	3	0.00017	$\pm$	0.00005
-0.423 wt.% of 9.4 wt. %	-0.00008	$\pm$	0.00016	3	-0.00003	$\pm$	0.00005
+0.423 wt.% of 9.4 wt. %	0.00039	$\pm$	0.00016	3	0.00013	$\pm$	0.00005
-0.4455 wt.% of 9.9 wt. %	0.00003	$\pm$	0.00016	3	0.00001	$\pm$	0.00005
+0.4455 wt.% of 9.9 wt. %	0.00003	$\pm$	0.00016	3	0.00001	$\pm$	0.00005

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.37. Effect of Uncertainty in Uranium Enrichment (Case 4).

Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
-0.1755 wt.% of 3.9 wt. %	-0.00159	$\pm$	0.00017	3	-0.00053	$\pm$	0.00006
+0.1755 wt.% of 3.9 wt. %	0.00176	$\pm$	0.00017	3	0.00059	$\pm$	0.00006
-0.1935 wt.% of 4.3 wt. %	-0.00193	$\pm$	0.00017	3	-0.00064	$\pm$	0.00006
+0.1935 wt.% of 4.3 wt. %	0.00238	$\pm$	0.00016	3	0.00079	$\pm$	0.00005
-0.216 wt.% of 4.8 wt. %	-0.00091	$\pm$	0.00017	3	-0.00030	$\pm$	0.00006
+0.216 wt.% of 4.8 wt. %	0.00108	$\pm$	0.00017	3	0.00036	$\pm$	0.00006
-0.234 wt.% of 5.2 wt. %	-0.00135	$\pm$	0.00017	3	-0.00045	$\pm$	0.00006
+0.234 wt.% of 5.2 wt. %	0.00154	$\pm$	0.00017	3	0.00051	$\pm$	0.00006
-0.2655 wt.% of 5.9 wt. %	-0.00145	$\pm$	0.00017	3	-0.00048	$\pm$	0.00006
+0.2655 wt.% of 5.9 wt. %	0.00124	$\pm$	0.00017	3	0.00041	$\pm$	0.00006
-0.2835 wt.% of 6.3 wt. %	-0.00190	$\pm$	0.00017	3	-0.00063	$\pm$	0.00006
+0.2835 wt.% of 6.3 wt. %	0.00197	$\pm$	0.00017	3	0.00066	$\pm$	0.00006
-0.324 wt.% of 7.2 wt. %	-0.00103	$\pm$	0.00016	3	-0.00034	$\pm$	0.00005
+0.324 wt.% of 7.2 wt. %	0.00099	$\pm$	0.00017	3	0.00033	$\pm$	0.00006
-0.3555 wt.% of 7.9 wt. %	-0.00112	$\pm$	0.00017	3	-0.00037	$\pm$	0.00006
+0.3555 wt.% of 7.9 wt. %	0.00133	$\pm$	0.00016	3	0.00044	$\pm$	0.00005
-0.423 wt.% of 9.4 wt. %	-0.00042	$\pm$	0.00016	3	-0.00014	$\pm$	0.00005
+0.423 wt.% of 9.4 wt. %	0.00055	$\pm$	0.00017	3	0.00018	$\pm$	0.00006
-0.4455 wt.% of 9.9 wt. %	-0.00013	$\pm$	0.00017	3	-0.00004	$\pm$	0.00006
+0.4455 wt.% of 9.9 wt. %	0.00032	$\pm$	0.00017	3	0.00011	$\pm$	0.00006

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.38. Effect of Uncertainty in Uranium Enrichment (Case 5).

Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
-0.153 wt.% of 3.4 wt. %	-0.00162	$\pm$	0.00017	3	-0.00054	$\pm$	0.00006
+0.153 wt.% of 3.4 wt. %	0.00125	$\pm$	0.00016	3	0.00042	$\pm$	0.00005
-0.1755 wt.% of 3.9 wt. %	-0.00238	$\pm$	0.00016	3	-0.00079	$\pm$	0.00005
+0.1755 wt.% of 3.9 wt. %	0.00238	$\pm$	0.00017	3	0.00079	$\pm$	0.00006
-0.1935 wt.% of 4.3 wt. %	-0.00399	$\pm$	0.00016	3	-0.00133	$\pm$	0.00005
+0.1935 wt.% of 4.3 wt. %	0.00398	$\pm$	0.00017	3	0.00133	$\pm$	0.00006
-0.216 wt.% of 4.8 wt. %	-0.00155	$\pm$	0.00017	3	-0.00052	$\pm$	0.00006
+0.216 wt.% of 4.8 wt. %	0.00152	$\pm$	0.00016	3	0.00051	$\pm$	0.00005
-0.234 wt.% of 5.2 wt. %	-0.00118	$\pm$	0.00017	3	-0.00039	$\pm$	0.00006
+0.234 wt.% of 5.2 wt. %	0.00111	$\pm$	0.00016	3	0.00037	$\pm$	0.00005
-0.2655 wt.% of 5.9 wt. %	-0.00157	$\pm$	0.00017	3	-0.00052	$\pm$	0.00006
+0.2655 wt.% of 5.9 wt. %	0.00142	$\pm$	0.00016	3	0.00047	$\pm$	0.00005
-0.2835 wt.% of 6.3 wt. %	-0.00091	$\pm$	0.00016	3	-0.00030	$\pm$	0.00005
+0.2835 wt.% of 6.3 wt. %	0.00078	$\pm$	0.00016	3	0.00026	$\pm$	0.00005
-0.3015 wt.% of 6.7 wt. %	0.00009	$\pm$	0.00017	3	0.00003	$\pm$	0.00006
+0.3015 wt.% of 6.7 wt. %	0.00007	$\pm$	0.00016	3	0.00002	$\pm$	0.00005
-0.324 wt.% of 7.2 wt. %	-0.00037	$\pm$	0.00017	3	-0.00012	$\pm$	0.00006
+0.324 wt.% of 7.2 wt. %	0.00033	$\pm$	0.00017	3	0.00011	$\pm$	0.00006
-0.3555 wt.% of 7.9 wt. %	-0.00025	$\pm$	0.00017	3	-0.00008	$\pm$	0.00006
+0.3555 wt.% of 7.9 wt. %	0.00019	$\pm$	0.00016	3	0.00006	$\pm$	0.00005
-0.423 wt.% of 9.4 wt. %	0.00003	$\pm$	0.00017	3	0.00001	$\pm$	0.00006
+0.423 wt.% of 9.4 wt. %	-0.00005	$\pm$	0.00016	3	-0.00002	$\pm$	0.00005
-0.4455 wt.% of 9.9 wt. %	-0.00002	$\pm$	0.00017	3	-0.00001	$\pm$	0.00006
+0.4455 wt.% of 9.9 wt. %	0.00022	$\pm$	0.00016	3	0.00007	$\pm$	0.00005

**Oxygen to Uranium Ratio**

The oxygen to uranium ratio was varied by a best judgment value of  $\pm 0.06$  ( $3 \times$  bounding limit) from the nominal value of 2.00 to determine the effective uncertainty in  $k_{\text{eff}}$ . Results are shown in Table 2.39.

The uncertainty in the oxygen to uranium ratio is considered all systematic with no random component.

Table 2.39. Effect of Uncertainty in Oxygen to Uranium Ratio.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.06	0.00044	$\pm$	0.00017	$3\sqrt{3}$	0.00008	$\pm$	0.00003	$5.38 \times 10^8$
	+0.06	-0.00047	$\pm$	0.00016	$3\sqrt{3}$	-0.00009	$\pm$	0.00003	
2	-0.06	0.00074	$\pm$	0.00016	$3\sqrt{3}$	0.00014	$\pm$	0.00003	$5.98 \times 10^8$
	+0.06	-0.00036	$\pm$	0.00016	$3\sqrt{3}$	-0.00007	$\pm$	0.00003	
3	-0.06	0.00035	$\pm$	0.00016	$3\sqrt{3}$	0.00007	$\pm$	0.00003	$6.88 \times 10^8$
	+0.06	-0.00086	$\pm$	0.00017	$3\sqrt{3}$	-0.00017	$\pm$	0.00003	
4	-0.06	0.00055	$\pm$	0.00016	$3\sqrt{3}$	0.00011	$\pm$	0.00003	$6.88 \times 10^8$
	+0.06	-0.00060	$\pm$	0.00017	$3\sqrt{3}$	-0.00012	$\pm$	0.00003	
5	-0.06	0.00048	$\pm$	0.00016	$3\sqrt{3}$	0.00009	$\pm$	0.00003	$7.78 \times 10^8$
	+0.06	-0.00063	$\pm$	0.00016	$3\sqrt{3}$	-0.00012	$\pm$	0.00003	

**UO<sub>2</sub> Density**

Because of the overspecification of the TRISO particles in Table 1.14 ([HTTR-GCR-RESR-001](#)) and the correlation of uranium kernel diameter, density, TRISO packing fraction, and mass, the effect of the uncertainty in the fuel density is not included in the total uncertainty. However, an analysis of the uncertainty based upon the fuel mass is performed in Section 2.1.6.

**UO<sub>2</sub> Impurity**

The kernel impurity was varied from 0-3 ppm by weight of equivalent natural-boron content to determine the bounding uncertainty in  $k_{\text{eff}}$ . The maximum limit was multiplied 10-fold so as to quantify the effective upper uncertainty in the UO<sub>2</sub> impurity. The average value is 1.5 ppm by weight (Tables 1.13 and 1.14 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.40.

The uncertainty in the UO<sub>2</sub> impurity is considered all systematic with no random component.

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATETable 2.40. Effect of Uncertainty in UO<sub>2</sub> Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	0.00055	$\pm$	0.00016	$\sqrt{3}$	0.00032	$\pm$	0.00009
	30 ppm	-0.00963	$\pm$	0.00017	$10\sqrt{3}$	-0.00056	$\pm$	0.00001
2	0 ppm	0.00081	$\pm$	0.00016	$\sqrt{3}$	0.00047	$\pm$	0.00009
	30 ppm	-0.01034	$\pm$	0.00017	$10\sqrt{3}$	-0.00060	$\pm$	0.00001
3	0 ppm	0.00042	$\pm$	0.00016	$\sqrt{3}$	0.00024	$\pm$	0.00009
	30 ppm	-0.01176	$\pm$	0.00016	$10\sqrt{3}$	-0.00068	$\pm$	0.00001
4	0 ppm	0.00045	$\pm$	0.00016	$\sqrt{3}$	0.00026	$\pm$	0.00009
	30 ppm	-0.01090	$\pm$	0.00016	$10\sqrt{3}$	-0.00063	$\pm$	0.00001
5	0 ppm	0.00082	$\pm$	0.00016	$\sqrt{3}$	0.00047	$\pm$	0.00009
	30 ppm	-0.01260	$\pm$	0.00016	$10\sqrt{3}$	-0.00073	$\pm$	0.00001

**Buffer Density**

The buffer density was varied  $\pm 0.30 \text{ g/cm}^3$  from the nominal value of  $1.10 \text{ g/cm}^3$  (Table 1.14 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . This value is three times the bounding limit. Results are shown in Table 2.41.

The total number of TRISO particles used in the fully-loaded core is approximately 868,140,000. For determining the random component of the uncertainty, the results in Table 2.41 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.41.

Table 2.41. Effect of Uncertainty in Buffer Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.30 g/cm <sup>3</sup>	-0.00005	$\pm$	0.00017	$3\sqrt{3}$	-0.00001	$\pm$	0.00003	$5.38 \times 10^8$
	+0.30 g/cm <sup>3</sup>	0.00014	$\pm$	0.00017	$3\sqrt{3}$	0.00003	$\pm$	0.00003	
2	-0.30 g/cm <sup>3</sup>	-0.00009	$\pm$	0.00017	$3\sqrt{3}$	-0.00002	$\pm$	0.00003	$5.98 \times 10^8$
	+0.30 g/cm <sup>3</sup>	0.00026	$\pm$	0.00016	$3\sqrt{3}$	0.00005	$\pm$	0.00003	
3	-0.30 g/cm <sup>3</sup>	-0.00021	$\pm$	0.00017	$3\sqrt{3}$	-0.00004	$\pm$	0.00003	$6.88 \times 10^8$
	+0.30 g/cm <sup>3</sup>	0.00006	$\pm$	0.00017	$3\sqrt{3}$	0.00001	$\pm$	0.00003	
4	-0.30 g/cm <sup>3</sup>	-0.00001	$\pm$	0.00017	$3\sqrt{3}$	0.00000	$\pm$	0.00003	$6.88 \times 10^8$
	+0.30 g/cm <sup>3</sup>	-0.00019	$\pm$	0.00016	$3\sqrt{3}$	-0.00004	$\pm$	0.00003	
5	-0.30 g/cm <sup>3</sup>	-0.00002	$\pm$	0.00016	$3\sqrt{3}$	0.00000	$\pm$	0.00003	$7.78 \times 10^8$
	+0.30 g/cm <sup>3</sup>	0.00007	$\pm$	0.00016	$3\sqrt{3}$	0.00001	$\pm$	0.00003	

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE**Buffer Impurity**

The buffer impurity was varied from 0-3 ppm by weight of equivalent natural-boron content to determine the bounding uncertainty in  $k_{\text{eff}}$ . The average value is 1.5 ppm by weight (Table 1.13 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.42.

The uncertainty in the buffer impurity is considered all systematic with no random component.

Table 2.42. Effect of Uncertainty in Buffer Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	0.00004	$\pm$	0.00017	$\sqrt{3}$	0.00002	$\pm$	0.00010
	3 ppm	0.00001	$\pm$	0.00017	$\sqrt{3}$	0.00001	$\pm$	0.00010
2	0 ppm	0.00014	$\pm$	0.00017	$\sqrt{3}$	0.00008	$\pm$	0.00010
	3 ppm	0.00000	$\pm$	0.00017	$\sqrt{3}$	0.00000	$\pm$	0.00010
3	0 ppm	0.00014	$\pm$	0.00016	$\sqrt{3}$	0.00008	$\pm$	0.00009
	3 ppm	-0.00021	$\pm$	0.00017	$\sqrt{3}$	-0.00012	$\pm$	0.00010
4	0 ppm	-0.00005	$\pm$	0.00017	$\sqrt{3}$	-0.00003	$\pm$	0.00010
	3 ppm	-0.00017	$\pm$	0.00017	$\sqrt{3}$	-0.00010	$\pm$	0.00010
5	0 ppm	0.00014	$\pm$	0.00016	$\sqrt{3}$	0.00008	$\pm$	0.00009
	3 ppm	-0.00020	$\pm$	0.00016	$\sqrt{3}$	-0.00012	$\pm$	0.00009

**IPyC Density**

The IPyC density was varied +0.30 and -0.15 g/cm<sup>3</sup> from the nominal value of 1.85 g/cm<sup>3</sup> (Table 1.14 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . These values are three times the bounding limit. Results are shown in Table 2.43.

The total number of TRISO particles used in the fully-loaded core is approximately 868,140,000. For determining the random component of the uncertainty, the results in Table 2.43 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.43.



## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.43. Effect of Uncertainty in IPyC Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.15 g/cm <sup>3</sup>	0.00000	$\pm$	0.00016	$3\sqrt{3}$	0.00000	$\pm$	0.00003	$5.38 \times 10^8$
	+0.30 g/cm <sup>3</sup>	0.00017	$\pm$	0.00017	$3\sqrt{3}$	0.00003	$\pm$	0.00003	
2	-0.15 g/cm <sup>3</sup>	0.00012	$\pm$	0.00016	$3\sqrt{3}$	0.00002	$\pm$	0.00003	$5.98 \times 10^8$
	+0.30 g/cm <sup>3</sup>	0.00027	$\pm$	0.00017	$3\sqrt{3}$	0.00005	$\pm$	0.00003	
3	-0.15 g/cm <sup>3</sup>	0.00006	$\pm$	0.00016	$3\sqrt{3}$	0.00001	$\pm$	0.00003	$6.88 \times 10^8$
	+0.30 g/cm <sup>3</sup>	0.00010	$\pm$	0.00017	$3\sqrt{3}$	0.00002	$\pm$	0.00003	
4	-0.15 g/cm <sup>3</sup>	-0.00011	$\pm$	0.00017	$3\sqrt{3}$	-0.00002	$\pm$	0.00003	$6.88 \times 10^8$
	+0.30 g/cm <sup>3</sup>	-0.00005	$\pm$	0.00017	$3\sqrt{3}$	-0.00001	$\pm$	0.00003	
5	-0.15 g/cm <sup>3</sup>	0.00015	$\pm$	0.00016	$3\sqrt{3}$	0.00003	$\pm$	0.00003	$7.78 \times 10^8$
	+0.30 g/cm <sup>3</sup>	0.00010	$\pm$	0.00016	$3\sqrt{3}$	0.00002	$\pm$	0.00003	

**IPyC Impurity**

The IPyC impurity was varied from 0-3 ppm by weight of equivalent natural-boron content to determine the bounding uncertainty in  $k_{\text{eff}}$ . The average value is 1.5 ppm by weight (Table 1.13 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.28.

The uncertainty in the IPyC impurity is considered all systematic with no random component.

Table 2.28. Effect of Uncertainty in IPyC Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	0.00006	$\pm$	0.00017	$\sqrt{3}$	0.00003	$\pm$	0.00010
	3 ppm	-0.00006	$\pm$	0.00017	$\sqrt{3}$	-0.00003	$\pm$	0.00010
2	0 ppm	0.00002	$\pm$	0.00016	$\sqrt{3}$	0.00001	$\pm$	0.00009
	3 ppm	0.00008	$\pm$	0.00017	$\sqrt{3}$	0.00005	$\pm$	0.00010
3	0 ppm	-0.00019	$\pm$	0.00016	$\sqrt{3}$	-0.00011	$\pm$	0.00009
	3 ppm	-0.00027	$\pm$	0.00017	$\sqrt{3}$	-0.00016	$\pm$	0.00010
4	0 ppm	0.00005	$\pm$	0.00017	$\sqrt{3}$	0.00003	$\pm$	0.00010
	3 ppm	-0.00005	$\pm$	0.00017	$\sqrt{3}$	-0.00003	$\pm$	0.00010
5	0 ppm	0.00023	$\pm$	0.00016	$\sqrt{3}$	0.00013	$\pm$	0.00009
	3 ppm	-0.00011	$\pm$	0.00016	$\sqrt{3}$	-0.00006	$\pm$	0.00009

**SiC Density**

The SiC density was increased by 0.06 g/cm<sup>3</sup>, where 0.02 g/cm<sup>3</sup> is typical for SiC material, from the nominal value of 3.20 g/cm<sup>3</sup> (Table 1.14 of [HTTR-GCR-RESR-001](#)) to determine the effective

uncertainty in  $k_{\text{eff}}$ . This value is three times the bounding limit. The density was not decreased because of the minimum requirement for SiC density. Results are shown in Table 2.44.

The total number of TRISO particles used in the fully-loaded core is approximately 868,140,000. For determining the random component of the uncertainty, the results in Table 2.44 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.44.

Table 2.44. Effect of Uncertainty in SiC Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	+0.06 g/cm <sup>3</sup>	0.00003	$\pm$	0.00016	$6\sqrt{3}$	0.00000	$\pm$	0.00002	$5.38 \times 10^8$
2	+0.06 g/cm <sup>3</sup>	0.00029	$\pm$	0.00017	$6\sqrt{3}$	0.00003	$\pm$	0.00002	$5.98 \times 10^8$
3	+0.06 g/cm <sup>3</sup>	-0.00014	$\pm$	0.00017	$6\sqrt{3}$	-0.00001	$\pm$	0.00002	$6.88 \times 10^8$
4	+0.06 g/cm <sup>3</sup>	-0.00026	$\pm$	0.00017	$6\sqrt{3}$	-0.00003	$\pm$	0.00002	$6.88 \times 10^8$
5	+0.06 g/cm <sup>3</sup>	-0.00018	$\pm$	0.00016	$6\sqrt{3}$	-0.00002	$\pm$	0.00002	$7.78 \times 10^8$

### SiC Impurity

The SiC impurity was varied from 0-3 ppm by weight of equivalent natural-boron content to determine the bounding uncertainty in  $k_{\text{eff}}$ . The average value is 1.5 ppm by weight (Table 1.13 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.45.

The uncertainty in the SiC impurity is considered all systematic with no random component.

Table 2.45. Effect of Uncertainty in SiC Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	0.00007	$\pm$	0.00017	$\sqrt{3}$	0.00004	$\pm$	0.00010
	3 ppm	0.00001	$\pm$	0.00017	$\sqrt{3}$	0.00001	$\pm$	0.00010
2	0 ppm	0.00017	$\pm$	0.00016	$\sqrt{3}$	0.00010	$\pm$	0.00009
	3 ppm	-0.00013	$\pm$	0.00016	$\sqrt{3}$	-0.00008	$\pm$	0.00009
3	0 ppm	-0.00012	$\pm$	0.00017	$\sqrt{3}$	-0.00007	$\pm$	0.00010
	3 ppm	-0.00014	$\pm$	0.00017	$\sqrt{3}$	-0.00008	$\pm$	0.00010
4	0 ppm	0.00000	$\pm$	0.00016	$\sqrt{3}$	0.00000	$\pm$	0.00009
	3 ppm	-0.00019	$\pm$	0.00017	$\sqrt{3}$	-0.00011	$\pm$	0.00010
5	0 ppm	0.00000	$\pm$	0.00016	$\sqrt{3}$	0.00000	$\pm$	0.00009
	3 ppm	-0.00027	$\pm$	0.00016	$\sqrt{3}$	-0.00016	$\pm$	0.00009

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE**OPyC Density**

The OPyC density was varied  $+0.30$  and  $-0.15$  g/cm<sup>3</sup> from the nominal value of  $1.85$  g/cm<sup>3</sup> (Table 1.14 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . This value is three times the bounding limit. Results are shown in Table 2.46.

The total number of TRISO particles used in the fully-loaded core is approximately 868,140,000. For determining the random component of the uncertainty, the results in Table 2.46 would be divided by  $\sqrt{N}$ , where  $N$  for each case is shown in Table 2.46.

Table 2.46. Effect of Uncertainty in OPyC Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	$-0.15$ g/cm <sup>3</sup>	-0.00012	$\pm$	0.00017	$3\sqrt{3}$	-0.00002	$\pm$	0.00003	$5.38 \times 10^8$
	$+0.30$ g/cm <sup>3</sup>	0.00009	$\pm$	0.00017	$3\sqrt{3}$	-0.00002	$\pm$	0.00003	
2	$-0.15$ g/cm <sup>3</sup>	0.00005	$\pm$	0.00017	$3\sqrt{3}$	0.00001	$\pm$	0.00003	$5.98 \times 10^8$
	$+0.30$ g/cm <sup>3</sup>	0.00026	$\pm$	0.00016	$3\sqrt{3}$	0.00005	$\pm$	0.00003	
3	$-0.15$ g/cm <sup>3</sup>	-0.00018	$\pm$	0.00016	$3\sqrt{3}$	-0.00003	$\pm$	0.00003	$6.88 \times 10^8$
	$+0.30$ g/cm <sup>3</sup>	-0.00026	$\pm$	0.00016	$3\sqrt{3}$	-0.00005	$\pm$	0.00003	
4	$-0.15$ g/cm <sup>3</sup>	-0.00012	$\pm$	0.00017	$3\sqrt{3}$	-0.00011	$\pm$	0.00010	$6.88 \times 10^8$
	$+0.30$ g/cm <sup>3</sup>	-0.00004	$\pm$	0.00017	$3\sqrt{3}$	-0.00001	$\pm$	0.00003	
5	$-0.15$ g/cm <sup>3</sup>	-0.00010	$\pm$	0.00016	$3\sqrt{3}$	-0.00002	$\pm$	0.00003	$7.78 \times 10^8$
	$+0.30$ g/cm <sup>3</sup>	0.00009	$\pm$	0.00016	$3\sqrt{3}$	0.00002	$\pm$	0.00003	

**OPyC Impurity**

The OPyC impurity was varied from 0-3 ppm by weight of equivalent natural-boron content to determine the bounding uncertainty in  $k_{\text{eff}}$ . The average value is 1.5 ppm by weight (Table 1.13 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.47.

The uncertainty in the OPyC impurity is considered all systematic with no random component.

Table 2.47. Effect of Uncertainty in OPyC Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	0.00009	$\pm$	0.00017	$\sqrt{3}$	0.00005	$\pm$	0.00010
	3 ppm	0.00009	$\pm$	0.00017	$\sqrt{3}$	0.00005	$\pm$	0.00010
2	0 ppm	0.00041	$\pm$	0.00016	$\sqrt{3}$	0.00024	$\pm$	0.00009
	3 ppm	-0.00026	$\pm$	0.00016	$\sqrt{3}$	-0.00015	$\pm$	0.00009
3	0 ppm	-0.00018	$\pm$	0.00016	$\sqrt{3}$	-0.00003	$\pm$	0.00003
	3 ppm	-0.00026	$\pm$	0.00016	$\sqrt{3}$	-0.00005	$\pm$	0.00003
4	0 ppm	-0.00020	$\pm$	0.00017	$\sqrt{3}$	-0.00012	$\pm$	0.00010
	3 ppm	-0.00005	$\pm$	0.00017	$\sqrt{3}$	-0.00003	$\pm$	0.00010
5	0 ppm	0.00034	$\pm$	0.00016	$\sqrt{3}$	0.000020	$\pm$	0.00009
	3 ppm	-0.00040	$\pm$	0.00016	$\sqrt{3}$	-0.00023	$\pm$	0.00009

**Overcoat Density**

Because insufficient data is available for the final composition and density of the graphite overcoat, this layer is being treated with equal properties to that of the surrounding compact graphite matrix. The overcoat density was varied  $\pm 0.15 \text{ g/cm}^3$  to determine the effective uncertainty in  $k_{\text{eff}}$ . This value is three times the bounding limit. Results are shown in Table 2.48.

The total number of TRISO particles used in the fully-loaded core is approximately 868,140,000. For determining the random component of the uncertainty, the results in Table 2.48 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.48.

Table 2.48. Effect of Uncertainty in Overcoat Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.15 g/cm <sup>3</sup>	-0.00030	$\pm$	0.00017	$3\sqrt{3}$	-0.00006	$\pm$	0.00003	$5.38 \times 10^8$
	+0.15 g/cm <sup>3</sup>	0.00034	$\pm$	0.00017	$3\sqrt{3}$	0.00007	$\pm$	0.00003	
2	-0.15 g/cm <sup>3</sup>	-0.00018	$\pm$	0.00017	$3\sqrt{3}$	-0.00003	$\pm$	0.00003	$5.98 \times 10^8$
	+0.15 g/cm <sup>3</sup>	0.00039	$\pm$	0.00016	$3\sqrt{3}$	0.00008	$\pm$	0.00003	
3	-0.15 g/cm <sup>3</sup>	-0.00050	$\pm$	0.00016	$3\sqrt{3}$	-0.00010	$\pm$	0.00003	$6.88 \times 10^8$
	+0.15 g/cm <sup>3</sup>	0.00014	$\pm$	0.00017	$3\sqrt{3}$	0.00003	$\pm$	0.00003	
4	-0.15 g/cm <sup>3</sup>	-0.00058	$\pm$	0.00016	$3\sqrt{3}$	-0.00011	$\pm$	0.00003	$6.88 \times 10^8$
	+0.15 g/cm <sup>3</sup>	0.00032	$\pm$	0.00017	$3\sqrt{3}$	0.00006	$\pm$	0.00003	
5	-0.15 g/cm <sup>3</sup>	-0.00024	$\pm$	0.00016	$3\sqrt{3}$	-0.00005	$\pm$	0.00003	$7.78 \times 10^8$
	+0.15 g/cm <sup>3</sup>	0.00025	$\pm$	0.00016	$3\sqrt{3}$	0.00005	$\pm$	0.00003	

**Overcoat Composition**

Because insufficient data is available for the final composition and density of the graphite overcoat, this layer is being treated with equal properties to that of the surrounding compact graphite matrix. In essence, the uncertainty has already been accounted for, as the surrounding graphite matrix has been characterized for uncertainties, and the overcoat has been demonstrated elsewhere to have negligible impact on the calculation of  $k_{\text{eff}}$  when it is not explicitly modeled, but included in the surrounding matrix.<sup>a</sup>

**Overcoat Impurity**

The overcoat impurity was varied from 0-5 ppm by weight of equivalent natural-boron content to determine the bounding uncertainty in  $k_{\text{eff}}$ . The average value of the coated fuel particles is 1.5 ppm by weight (Table 1.13 of [HTTR-GCR-RESR-001](#)); it is assumed that the overcoat would have a comparable impurity amount. The alternative is to use the impurity of the compact (matrix) material, which is 0.82 ppm by weight (Table 1.27 of [HTTR-GCR-RESR-001](#)). The larger amount is selected, i.e. 1.5 ppm. Results are shown in Table 2.49.

The uncertainty in the overcoat impurity is considered all systematic with no random component.

Table 2.49. Effect of Uncertainty in Overcoat Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	0.00046	$\pm$	0.00017	$\sqrt{3}$	0.00027	$\pm$	0.00010
	5 ppm	-0.00069	$\pm$	0.00017	$\sqrt{3}$	-0.00040	$\pm$	0.00010
2	0 ppm	0.00052	$\pm$	0.00017	$\sqrt{3}$	0.00030	$\pm$	0.00010
	5 ppm	-0.00103	$\pm$	0.00017	$\sqrt{3}$	-0.00059	$\pm$	0.00010
3	0 ppm	0.00077	$\pm$	0.00016	$\sqrt{3}$	0.00044	$\pm$	0.00009
	5 ppm	-0.00122	$\pm$	0.00017	$\sqrt{3}$	-0.00070	$\pm$	0.00010
4	0 ppm	0.00044	$\pm$	0.00017	$\sqrt{3}$	0.00025	$\pm$	0.00010
	5 ppm	-0.00132	$\pm$	0.00017	$\sqrt{3}$	-0.00076	$\pm$	0.00010
5	0 ppm	0.00055	$\pm$	0.00016	$\sqrt{3}$	0.00032	$\pm$	0.00009
	5 ppm	-0.00119	$\pm$	0.00016	$\sqrt{3}$	-0.00069	$\pm$	0.00009

**2.1.3.2 Prismatic Fuel Compact****Density**

The compact matrix density was varied  $\pm 0.15 \text{ g/cm}^3$  from the nominal value of  $1.70 \text{ g/cm}^3$  (Table 1.14 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . This value is three times the bounding limit. Results are shown in Table 2.50.

<sup>a</sup> W. Ji, J. L. Conlin, W. R. Martin, J. C. Lee, and F. B. Brown, "Explicit Modeling of Particle Fuel for the Very-High Temperature Gas-Cooled Reactor," *Trans. Am. Nucl. Soc.*, **92** (June 2005).

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

The total number of fuel compacts used in the fully-loaded core is 66,780. For determining the random component of the uncertainty, the results in Table 2.50 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.50.

Table 2.50. Effect of Uncertainty in Compact Matrix Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.15 g/cm <sup>3</sup>	-0.00009	$\pm$	0.00016	$3\sqrt{3}$	-0.00002	$\pm$	0.00003	41,370
	+0.15 g/cm <sup>3</sup>	-0.00012	$\pm$	0.00017	$3\sqrt{3}$	-0.00002	$\pm$	0.00003	
2	-0.15 g/cm <sup>3</sup>	0.00016	$\pm$	0.00017	$3\sqrt{3}$	0.00003	$\pm$	0.00003	45,990
	+0.15 g/cm <sup>3</sup>	0.00016	$\pm$	0.00016	$3\sqrt{3}$	0.00003	$\pm$	0.00003	
3	-0.15 g/cm <sup>3</sup>	-0.00023	$\pm$	0.00016	$3\sqrt{3}$	-0.00004	$\pm$	0.00003	52,920
	+0.15 g/cm <sup>3</sup>	0.00000	$\pm$	0.00016	$3\sqrt{3}$	0.00000	$\pm$	0.00003	
4	-0.15 g/cm <sup>3</sup>	-0.00028	$\pm$	0.00017	$3\sqrt{3}$	0.00005	$\pm$	0.00003	52,920
	+0.15 g/cm <sup>3</sup>	0.00022	$\pm$	0.00017	$3\sqrt{3}$	0.00004	$\pm$	0.00003	
5	-0.15 g/cm <sup>3</sup>	-0.00011	$\pm$	0.00016	$3\sqrt{3}$	-0.00002	$\pm$	0.00003	59,850
	+0.15 g/cm <sup>3</sup>	0.00028	$\pm$	0.00016	$3\sqrt{3}$	0.00005	$\pm$	0.00003	

**Impurity**

The compact matrix impurity was varied from 0-5 ppm by weight of equivalent natural-boron content (Table 1.14 of [HTTR-GCR-RESR-001](#)) to determine the bounding uncertainty in  $k_{\text{eff}}$ . The nominal impurity is 0.82 ppm of natural boron by weight (Table 1.27 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.51.

The uncertainty in the fuel compact impurity is considered all systematic with no random component.

Table 2.51. Effect of Uncertainty in Compact Matrix Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	0.00007	$\pm$	0.00016	$\sqrt{3}$	0.00004	$\pm$	0.00009
	5 ppm	-0.00074	$\pm$	0.00017	$\sqrt{3}$	-0.00043	$\pm$	0.00010
2	0 ppm	0.00023	$\pm$	0.00016	$\sqrt{3}$	0.00013	$\pm$	0.00009
	5 ppm	-0.00072	$\pm$	0.00016	$\sqrt{3}$	-0.00042	$\pm$	0.00009
3	0 ppm	0.00008	$\pm$	0.00017	$\sqrt{3}$	0.00005	$\pm$	0.00010
	5 ppm	-0.00115	$\pm$	0.00016	$\sqrt{3}$	-0.00066	$\pm$	0.00009
4	0 ppm	0.00014	$\pm$	0.00017	$\sqrt{3}$	0.00008	$\pm$	0.00010
	5 ppm	-0.00104	$\pm$	0.00017	$\sqrt{3}$	-0.00060	$\pm$	0.00010
5	0 ppm	0.00003	$\pm$	0.00016	$\sqrt{3}$	0.000002	$\pm$	0.00009
	5 ppm	-0.00113	$\pm$	0.00016	$\sqrt{3}$	-0.00065	$\pm$	0.00009

**Free Uranium Content**

The free uranium fraction in the fuel compacts has a maximum bounding limit of 0.000150 (see Table 1.14 of [HTTR-GCR-RESR-001](#)). The bounding limit was multiplied by 10 in order to assess the uncertainty in  $k_{\text{eff}}$ , but the effects were still negligible. The free uranium was assumed to be 100 %  $^{235}\text{U}$  so as to assess the maximum uncertainty. The free uranium content in the graphite compact was not included in the benchmark model and a bias was not applied because the effect was negligible. Results are shown in Table 2.52.

The uncertainty in the free uranium content is considered all systematic with no random component.

Table 2.52. Effect of Uncertainty in Compact Free Uranium Content.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	1500 ppm	-0.00003	$\pm$	0.00016	$20\sqrt{3}$	0.00000	$\pm$	0.00000
2	1500 ppm	-0.00024	$\pm$	0.00016	$20\sqrt{3}$	-0.00001	$\pm$	0.00000
3	1500 ppm	-0.00012	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000
4	1500 ppm	0.00009	$\pm$	0.00017	$20\sqrt{3}$	0.00000	$\pm$	0.00000
5	1500 ppm	0.00020	$\pm$	0.00016	$20\sqrt{3}$	0.00001	$\pm$	0.00000

**2.1.3.3 Graphite Sleeves****Density**

The graphite sleeve density was varied an assumed  $\pm 0.03 \text{ g/cm}^3$  from the nominal value of  $1.770 \text{ g/cm}^3$  (Table 1.27 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . This value is the bounding limit. The graphite sleeves are composed of IG-110 graphite, and the assumed uncertainty of  $0.03 \text{ g/cm}^3$  encompasses the range of reported densities for IG-110 graphite throughout Section 1. Results are shown in Table 2.53.

The total number of graphite sleeves used in the fully-loaded core is 4,770. For determining the random component of the uncertainty, the results in Table 2.53 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.53.

Table 2.53. Effect of Uncertainty in Graphite Sleeve Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.03 g/cm <sup>3</sup>	-0.00036	$\pm$	0.00017	$\sqrt{3}$	-0.00021	$\pm$	0.00010	2,955
	+0.03 g/cm <sup>3</sup>	0.00030	$\pm$	0.00017	$\sqrt{3}$	0.00017	$\pm$	0.00010	
2	-0.03 g/cm <sup>3</sup>	-0.00024	$\pm$	0.00016	$\sqrt{3}$	-0.00014	$\pm$	0.00009	3,285
	+0.03 g/cm <sup>3</sup>	0.00022	$\pm$	0.00017	$\sqrt{3}$	0.00013	$\pm$	0.00010	
3	-0.03 g/cm <sup>3</sup>	-0.00052	$\pm$	0.00016	$\sqrt{3}$	-0.00030	$\pm$	0.00009	3,780
	+0.03 g/cm <sup>3</sup>	0.00026	$\pm$	0.00017	$\sqrt{3}$	0.00015	$\pm$	0.00010	
4	-0.03 g/cm <sup>3</sup>	-0.00086	$\pm$	0.00017	$\sqrt{3}$	-0.00050	$\pm$	0.00010	3,780
	+0.03 g/cm <sup>3</sup>	0.00042	$\pm$	0.00017	$\sqrt{3}$	0.00024	$\pm$	0.00010	
5	-0.03 g/cm <sup>3</sup>	-0.00038	$\pm$	0.00016	$\sqrt{3}$	-0.00022	$\pm$	0.00009	4,275
	+0.03 g/cm <sup>3</sup>	0.00030	$\pm$	0.00016	$\sqrt{3}$	0.00017	$\pm$	0.00009	

**Impurity**

The graphite sleeve impurity was varied from 0-1 ppm by weight of equivalent natural-boron content (Table 1.13 of [HTTR-GCR-RESR-001](#)) to determine the bounding uncertainty in  $k_{\text{eff}}$ . The nominal impurity is 0.37 ppm of natural boron by weight (Table 1.27 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.54.

The uncertainty in the graphite sleeve impurity is considered all systematic with no random component.

Table 2.54. Effect of Uncertainty in Graphite Sleeve Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	0.00007	$\pm$	0.00017	$\sqrt{3}$	0.00004	$\pm$	0.00010
	1 ppm	-0.00055	$\pm$	0.00017	$\sqrt{3}$	-0.00032	$\pm$	0.00010
2	0 ppm	0.00032	$\pm$	0.00016	$\sqrt{3}$	0.00018	$\pm$	0.00009
	1 ppm	-0.00037	$\pm$	0.00017	$\sqrt{3}$	-0.00021	$\pm$	0.00010
3	0 ppm	0.00011	$\pm$	0.00017	$\sqrt{3}$	0.00006	$\pm$	0.00010
	1 ppm	-0.00084	$\pm$	0.00017	$\sqrt{3}$	-0.00048	$\pm$	0.00010
4	0 ppm	0.00012	$\pm$	0.00016	$\sqrt{3}$	0.00007	$\pm$	0.00009
	1 ppm	-0.00058	$\pm$	0.00017	$\sqrt{3}$	-0.00033	$\pm$	0.00010
5	0 ppm	0.00054	$\pm$	0.00016	$\sqrt{3}$	0.00031	$\pm$	0.00009
	1 ppm	-0.00053	$\pm$	0.00016	$\sqrt{3}$	-0.00031	$\pm$	0.00009



#### 2.1.3.4 Burnable Poisons

##### **Absorber Density**

The absorber density was varied  $\pm 0.03 \text{ g/cm}^3$  from the average value of  $1.8 \text{ g/cm}^3$  to determine the effective uncertainty in  $k_{\text{eff}}$ . This value is the bounding limit. The density uncertainty is based upon uncertainty typically found in sintered  $\text{B}_4\text{C/C}$  pellets (Table 1.29 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.55.

The total number of burnable poison pellets used in the fully-loaded core is 5,520. For determining the random component of the uncertainty, the results in Table 2.55 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.55.

Table 2.55. Effect of Uncertainty in BP Absorber Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.03 $\text{g/cm}^3$	0.00085	$\pm$	0.00016	$\sqrt{3}$	0.00049	$\pm$	0.00009	3,496
	+0.03 $\text{g/cm}^3$	-0.00083	$\pm$	0.00017	$\sqrt{3}$	-0.00048	$\pm$	0.00010	
2	-0.03 $\text{g/cm}^3$	0.00101	$\pm$	0.00017	$\sqrt{3}$	0.00058	$\pm$	0.00010	3,864
	+0.03 $\text{g/cm}^3$	-0.00048	$\pm$	0.00017	$\sqrt{3}$	-0.00028	$\pm$	0.00010	
3	-0.03 $\text{g/cm}^3$	0.00066	$\pm$	0.00017	$\sqrt{3}$	0.00038	$\pm$	0.00010	4,416
	+0.03 $\text{g/cm}^3$	-0.00081	$\pm$	0.00017	$\sqrt{3}$	-0.00047	$\pm$	0.00010	
4	-0.03 $\text{g/cm}^3$	0.00064	$\pm$	0.00017	$\sqrt{3}$	0.00037	$\pm$	0.00010	4,416
	+0.03 $\text{g/cm}^3$	-0.00084	$\pm$	0.00016	$\sqrt{3}$	-0.00048	$\pm$	0.00009	
5	-0.03 $\text{g/cm}^3$	0.00065	$\pm$	0.00016	$\sqrt{3}$	0.00038	$\pm$	0.00009	4,968
	+0.03 $\text{g/cm}^3$	-0.00077	$\pm$	0.00016	$\sqrt{3}$	-0.00044	$\pm$	0.00009	

##### **Absorber Content**

The uncertainty in the absorber content was not provided and the variation provided in Table 1.29 of [HTTR-GCR-RESR-001](#) appears too excessive for the quantities utilized in the BP pellets. A variation of approximately  $\pm 0.25 \%$  by weight was assumed for each of the two absorber pellet types, and the effective uncertainty in  $k_{\text{eff}}$  was determined. This value is treated as a bounding limit. The uncertainty of  $\pm 0.25 \%$  is based upon the assumption that burnable poison pellets with boron contents between 1.75 and 2.25 wt.% would have an average content of 2.00 wt.% and boron contents between 2.25 and 2.75 wt.% would have an average content of 2.50 wt.%. Further information would be necessary to reduce the range of the uncertainty. Results are shown in Tables 2.56 and 2.57.

The total number of burnable poison pellets with weight percents of 2.00 and 2.50 used in the fully-loaded core is 3,600 and 1,920, respectively. For determining the random component of the uncertainty, the results in Tables 2.56 and 2.57 would be divided by their respective  $\sqrt{N}$  value, where N for each case is shown in Tables 2.56 and 2.57.

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.56. Effect of Uncertainty in BP Absorber Content (nominal 2.00 wt.%).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.25 wt. %	0.00265	$\pm$	0.00016	$\sqrt{3}$	0.000153	$\pm$	0.00009	2,280
	+0.25 wt. %	-0.00234	$\pm$	0.00017	$\sqrt{3}$	-0.00135	$\pm$	0.00010	
2	-0.25 wt. %	0.00304	$\pm$	0.00017	$\sqrt{3}$	0.00176	$\pm$	0.00010	2,520
	+0.25 wt. %	-0.00234	$\pm$	0.00016	$\sqrt{3}$	-0.00135	$\pm$	0.00009	
3	-0.25 wt. %	0.00394	$\pm$	0.00017	$\sqrt{3}$	0.00227	$\pm$	0.00010	2,880
	+0.25 wt. %	-0.00342	$\pm$	0.00017	$\sqrt{3}$	-0.00197	$\pm$	0.00010	
4	-0.25 wt. %	0.00379	$\pm$	0.00016	$\sqrt{3}$	-0.00219	$\pm$	0.00009	2,880
	+0.25 wt. %	-0.00346	$\pm$	0.00017	$\sqrt{3}$	-0.00200	$\pm$	0.00010	
5	-0.25 wt. %	0.00518	$\pm$	0.00016	$\sqrt{3}$	0.00299	$\pm$	0.00009	3,240
	+0.25 wt. %	-0.00455	$\pm$	0.00016	$\sqrt{3}$	-0.00263	$\pm$	0.00009	

Table 2.57. Effect of Uncertainty in BP Absorber Content (nominal 2.50 wt.%).

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.25 wt. %	0.00250	$\pm$	0.00017	$\sqrt{3}$	0.00144	$\pm$	0.00010	1,216
	+0.25 wt. %	-0.00240	$\pm$	0.00017	$\sqrt{3}$	-0.00139	$\pm$	0.00010	
2	-0.25 wt. %	0.00284	$\pm$	0.00016	$\sqrt{3}$	0.00164	$\pm$	0.00009	1,344
	+0.25 wt. %	-0.00249	$\pm$	0.00017	$\sqrt{3}$	-0.00144	$\pm$	0.00010	
3	-0.25 wt. %	0.00249	$\pm$	0.00017	$\sqrt{3}$	0.00144	$\pm$	0.00010	1,536
	+0.25 wt. %	-0.00240	$\pm$	0.00016	$\sqrt{3}$	-0.00139	$\pm$	0.00009	
4	-0.25 wt. %	0.00284	$\pm$	0.00017	$\sqrt{3}$	0.00164	$\pm$	0.00010	1,536
	+0.25 wt. %	-0.00251	$\pm$	0.00016	$\sqrt{3}$	-0.00145	$\pm$	0.00009	
5	-0.25 wt. %	0.00200	$\pm$	0.00016	$\sqrt{3}$	0.00115	$\pm$	0.00009	1,728
	+0.25 wt. %	-0.00187	$\pm$	0.00016	$\sqrt{3}$	-0.00108	$\pm$	0.00009	

**Absorber Impurity**

No information was available regarding any impurities present in the sintered B<sub>4</sub>C/C material for the BP pellets. However, the impurity limits provided in Table 1.29 of [HTTR-GCR-RESR-001](#) can be applied to approximate a rough estimate of the impact of additional impurities. Sodium and manganese were added with concentrations of 100 and 10 ppm (by weight), respectively. Concentrations of 1000 ppm (by weight) of aluminum, silicon, calcium, and titanium were also included. The effective uncertainty in  $k_{\text{eff}}$  was determined and is shown in Table 2.58. This value is treated as a bounding limit.

The uncertainty in the absorber impurity is considered all systematic with no random component.

Table 2.58. Effect of Uncertainty in Absorber Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	Added Impurities	0.00048	$\pm$	0.00016	$2\sqrt{3}$	0.00014	$\pm$	0.00005
2	Added Impurities	0.00081	$\pm$	0.00017	$2\sqrt{3}$	0.00023	$\pm$	0.00005
3	Added Impurities	0.00072	$\pm$	0.00016	$2\sqrt{3}$	0.00021	$\pm$	0.00005
4	Added Impurities	0.00064	$\pm$	0.00017	$2\sqrt{3}$	0.00018	$\pm$	0.00005
5	Added Impurities	0.00082	$\pm$	0.00016	$2\sqrt{3}$	0.00024	$\pm$	0.00004

### **Absorber Isotopic Abundance**

According to the 16<sup>th</sup> edition of the Chart of the Nuclides, the natural isotopic abundance of  $^{10}\text{B}$  has been measured between 19.1 and 20.3 at.% with a nominal value of 19.9 at.%.<sup>a</sup> The abundance of  $^{10}\text{B}$  in the BPs was therefore evaluated at the minimum and maximum bounding values to determine the effective uncertainty in  $k_{\text{eff}}$ . Table 1.28 of [HTTR-GCR-RESR-001](#) states that the abundance of  $^{10}\text{B}$  is 18.7 wt.%, which correlates to approximately 20.2 at.%. The benchmark model was evaluated at 19.9 at.%. Results are shown in Table 2.58.

The uncertainty in the absorber isotopic abundance is considered all systematic with no random component.

Table 2.58. Effect of Uncertainty in BP Isotopic Abundance of  $^{10}\text{B}$ .

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	19.1%	0.00178	$\pm$	0.00016	$\sqrt{3}$	0.00014	$\pm$	0.00005
	20.3%	-0.00101	$\pm$	0.00016	$\sqrt{3}$	-0.00058	$\pm$	0.00009
2	19.1%	0.00227	$\pm$	0.00017	$\sqrt{3}$	0.00131	$\pm$	0.00010
	20.3%	-0.00073	$\pm$	0.00017	$\sqrt{3}$	-0.00042	$\pm$	0.00010
3	19.1%	0.00219	$\pm$	0.00017	$\sqrt{3}$	0.00126	$\pm$	0.00010
	20.3%	-0.00107	$\pm$	0.00016	$\sqrt{3}$	-0.00062	$\pm$	0.00009
4	19.1%	0.00220	$\pm$	0.00016	$\sqrt{3}$	0.00127	$\pm$	0.00009
	20.3%	-0.00139	$\pm$	0.00017	$\sqrt{3}$	-0.00080	$\pm$	0.00010
5	19.1%	0.00236	$\pm$	0.00016	$\sqrt{3}$	0.00136	$\pm$	0.00009
	20.3%	-0.00133	$\pm$	0.00016	$\sqrt{3}$	-0.00077	$\pm$	0.00009

### **Graphite Disk Density**

An uncertainty in the density of the graphite disks was not reported. A variation of  $\pm 0.09 \text{ g/cm}^3$  was assumed and the effects on the uncertainty of  $k_{\text{eff}}$  were determined. This value is three times the bounding limit. The graphite disks are composed of IG-110 graphite, and the assumed uncertainty of

<sup>a</sup> Nuclides and Isotopes: Chart of the Nuclides, 16<sup>th</sup> edition, (2002).

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

0.03 g/cm<sup>3</sup> encompasses the range of reported densities for IG-110 graphite throughout Section 1 of [HTTR-GCR-RESR-001](#). Results are shown in Table 2.59.

The total number of graphite disk stacks used in the fully-loaded core is 300. For determining the random component of the uncertainty, the results in Table 2.59 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.59.

Table 2.59. Effect of Uncertainty in Graphite Disk Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.09 g/cm <sup>3</sup>	0.00015	$\pm$	0.00017	$3\sqrt{3}$	0.00003	$\pm$	0.00003	190
	+0.09 g/cm <sup>3</sup>	0.00003	$\pm$	0.00016	$3\sqrt{3}$	0.00001	$\pm$	0.00003	
2	-0.09 g/cm <sup>3</sup>	0.00008	$\pm$	0.00017	$3\sqrt{3}$	0.000004	$\pm$	0.00003	210
	+0.09 g/cm <sup>3</sup>	0.00022	$\pm$	0.00017	$3\sqrt{3}$	0.00004	$\pm$	0.00003	
3	-0.09 g/cm <sup>3</sup>	-0.00017	$\pm$	0.00017	$3\sqrt{3}$	-0.00003	$\pm$	0.00003	240
	+0.09 g/cm <sup>3</sup>	-0.00005	$\pm$	0.00017	$3\sqrt{3}$	-0.00001	$\pm$	0.00003	
4	-0.09 g/cm <sup>3</sup>	-0.00027	$\pm$	0.00017	$3\sqrt{3}$	-0.00005	$\pm$	0.00003	240
	+0.09 g/cm <sup>3</sup>	-0.00006	$\pm$	0.00017	$3\sqrt{3}$	-0.00001	$\pm$	0.00003	
5	-0.09 g/cm <sup>3</sup>	0.00001	$\pm$	0.00016	$3\sqrt{3}$	0.00000	$\pm$	0.00003	270
	+0.09 g/cm <sup>3</sup>	0.00001	$\pm$	0.00016	$3\sqrt{3}$	0.00000	$\pm$	0.00003	

**Graphite Disk Impurity**

The assumed graphite disk impurity was varied from 0-5 ppm by weight of equivalent natural-boron content to determine the bounding uncertainty in  $k_{\text{eff}}$ . The nominal impurity is 0.37 ppm of natural boron by weight (Table 1.28 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.60.

The uncertainty in the graphite disk impurity is considered all systematic with no random component.

Table 2.60. Effect of Uncertainty in Graphite Disk Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	-0.00018	$\pm$	0.00017	$\sqrt{3}$	-0.00010	$\pm$	0.00010
	5 ppm	-0.00006	$\pm$	0.00017	$\sqrt{3}$	-0.00003	$\pm$	0.00010
2	0 ppm	0.00004	$\pm$	0.00016	$\sqrt{3}$	0.00002	$\pm$	0.00009
	5 ppm	0.00016	$\pm$	0.00017	$\sqrt{3}$	0.00009	$\pm$	0.00010
3	0 ppm	-0.00016	$\pm$	0.00017	$\sqrt{3}$	-0.00009	$\pm$	0.00010
	5 ppm	-0.00017	$\pm$	0.00016	$\sqrt{3}$	-0.00010	$\pm$	0.00009
4	0 ppm	-0.00017	$\pm$	0.00017	$\sqrt{3}$	-0.00010	$\pm$	0.00010
	5 ppm	-0.00007	$\pm$	0.00017	$\sqrt{3}$	-0.00004	$\pm$	0.00010
5	0 ppm	-0.00001	$\pm$	0.00016	$\sqrt{3}$	-0.00001	$\pm$	0.00009
	5 ppm	-0.00011	$\pm$	0.00016	$\sqrt{3}$	-0.00006	$\pm$	0.00009

### 2.1.3.5 Control Rods

#### **Absorber Density**

The absorber density was varied  $\pm 0.09 \text{ g/cm}^3$  from the nominal value of  $1.9 \text{ g/cm}^3$  (Table 1.15 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . This value is three times the bounding limit. The uncertainty is taken from Table 1.29 of [HTTR-GCR-RESR-001](#). Results are shown in Table 2.46.

The total number of control rod absorber pellets used in the fully-loaded core is approximately 975, as approximately 30% of the control rods are actually inserted into the core. For determining the random component of the uncertainty, the results in Table 2.61 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.61.

Table 2.61. Effect of Uncertainty in CR Absorber Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.09 g/cm <sup>3</sup>	0.00004	$\pm$	0.00017	$3\sqrt{3}$	0.00001	$\pm$	0.00003	225
	+0.09 g/cm <sup>3</sup>	-0.00023	$\pm$	0.00016	$3\sqrt{3}$	0.00003	$\pm$	0.00003	
2	-0.09 g/cm <sup>3</sup>	0.00013	$\pm$	0.00016	$3\sqrt{3}$	0.00003	$\pm$	0.00003	585
	+0.09 g/cm <sup>3</sup>	0.00007	$\pm$	0.00016	$3\sqrt{3}$	0.00001	$\pm$	0.00003	
3	-0.09 g/cm <sup>3</sup>	0.00020	$\pm$	0.00016	$3\sqrt{3}$	0.00004	$\pm$	0.00003	780
	+0.09 g/cm <sup>3</sup>	-0.00009	$\pm$	0.00016	$3\sqrt{3}$	-0.00002	$\pm$	0.00003	
4	-0.09 g/cm <sup>3</sup>	-0.00002	$\pm$	0.00016	$3\sqrt{3}$	0.00000	$\pm$	0.00003	720
	+0.09 g/cm <sup>3</sup>	-0.00025	$\pm$	0.00016	$3\sqrt{3}$	-0.00005	$\pm$	0.00003	
5	-0.09 g/cm <sup>3</sup>	-0.00013	$\pm$	0.00016	$3\sqrt{3}$	-0.00003	$\pm$	0.00003	910
	+0.09 g/cm <sup>3</sup>	-0.00024	$\pm$	0.00016	$3\sqrt{3}$	-0.00005	$\pm$	0.00003	

**Absorber Content**

The boron content was varied  $\pm 9$  wt.% from the nominal value of 30 wt.% (Table 1.15 of [HTTR-GCR-RESR-001](#)) and the effect on the uncertainty in  $k_{\text{eff}}$  was determined. This value is three times the bounding limit. The uncertainty is taken from Table 1.29 of [HTTR-GCR-RESR-001](#). Results are shown in Table 2.62.

The total number of control rod absorber pellets used in the fully-loaded core is approximately 975, as approximately 30% of the control rods are actually inserted into the core. For determining the random component of the uncertainty, the results in Table 2.62 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.62.

Table 2.62. Effect of Uncertainty in CR Absorber Content.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-9 wt.%	0.00002	$\pm$	0.00017	$3\sqrt{3}$	0.00000	$\pm$	0.00003	225
	+9 wt.%	-0.00016	$\pm$	0.00017	$3\sqrt{3}$	-0.00003	$\pm$	0.00003	
2	-9 wt.%	0.00055	$\pm$	0.00017	$3\sqrt{3}$	0.00011	$\pm$	0.00003	585
	+9 wt.%	-0.00030	$\pm$	0.00016	$3\sqrt{3}$	-0.00006	$\pm$	0.00003	
3	-9 wt.%	0.00045	$\pm$	0.00017	$3\sqrt{3}$	0.00009	$\pm$	0.00003	780
	+9 wt.%	-0.00045	$\pm$	0.00017	$3\sqrt{3}$	-0.00009	$\pm$	0.00003	
4	-9 wt.%	0.00064	$\pm$	0.00017	$3\sqrt{3}$	0.00012	$\pm$	0.00003	720
	+9 wt.%	-0.00066	$\pm$	0.00017	$3\sqrt{3}$	-0.00013	$\pm$	0.00003	
5	-9 wt.%	0.00045	$\pm$	0.00016	$3\sqrt{3}$	0.00009	$\pm$	0.00003	910
	+9 wt.%	-0.00053	$\pm$	0.00016	$3\sqrt{3}$	-0.00010	$\pm$	0.00003	

**Absorber Impurity**

No information was available regarding any impurities present in the sintered  $B_4C/C$  material for the control rod absorbers. However, the impurity limits provided in Table 1.29 of [HTTR-GCR-RESR-001](#) can be applied to approximate a rough estimate of the impact of additional impurities. Sodium and manganese were added with a concentrations of 100 and 10 ppm (by weight), respectively. Concentrations of 1000 ppm (by weight) of aluminum, silicon, calcium, and titanium were also included. The effective uncertainty in  $k_{\text{eff}}$  was determined and is shown in Table 2.63. This value is treated as a bounding limit.

The uncertainty in the absorber impurity is considered all systematic with no random component.

Table 2.63. Effect of Uncertainty in Absorber Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	Added Impurities	-0.00007	$\pm$	0.00016	$2\sqrt{3}$	-0.00002	$\pm$	0.00005
2	Added Impurities	-0.00017	$\pm$	0.00016	$2\sqrt{3}$	-0.00005	$\pm$	0.00005
3	Added Impurities	-0.00009	$\pm$	0.00017	$2\sqrt{3}$	-0.00003	$\pm$	0.00005
4	Added Impurities	-0.00005	$\pm$	0.00017	$2\sqrt{3}$	-0.00013	$\pm$	0.00003
5	Added Impurities	-0.00005	$\pm$	0.00016	$2\sqrt{3}$	-0.00001	$\pm$	0.00004

### **Absorber Isotopic Abundance**

According to the 16<sup>th</sup> edition of the Chart of the Nuclides, the natural isotopic abundance of  $^{10}\text{B}$  has been measured between 19.1 and 20.3% with a nominal value of 19.9%.<sup>a</sup> The abundance of  $^{10}\text{B}$  in the control rods was therefore evaluated at the minimum and maximum bounding values to determine the effective uncertainty in  $k_{\text{eff}}$ . Table 1.28 of [HTTR-GCR-RESR-001](#) states that the abundance of  $^{10}\text{B}$  is 18.7 wt.%, which correlates to approximately 20.2 at.%. The model was not evaluated for a  $^{10}\text{B}$  abundance of 18.7 wt.%. The benchmark model was evaluated at 19.9 at.%. Results are shown in Table 2.64.

The uncertainty in the absorber isotopic abundance is considered all systematic with no random component.

Table 2.64. Effect of Uncertainty in CR Isotopic Abundance of  $^{10}\text{B}$ .

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	19.1%	0.00008	$\pm$	0.00017	$\sqrt{3}$	0.00005	$\pm$	0.00010
	20.3%	0.00013	$\pm$	0.00017	$\sqrt{3}$	0.00008	$\pm$	0.00010
2	19.1%	0.00009	$\pm$	0.00017	$\sqrt{3}$	0.00005	$\pm$	0.00010
	20.3%	0.00000	$\pm$	0.00017	$\sqrt{3}$	0.00000	$\pm$	0.00010
3	19.1%	0.00022	$\pm$	0.00016	$\sqrt{3}$	0.00013	$\pm$	0.00009
	20.3%	-0.00009	$\pm$	0.00016	$\sqrt{3}$	-0.00005	$\pm$	0.00009
4	19.1%	-0.00013	$\pm$	0.00017	$\sqrt{3}$	-0.00008	$\pm$	0.00010
	20.3%	-0.00018	$\pm$	0.00016	$\sqrt{3}$	-0.00010	$\pm$	0.00009
5	19.1%	-0.00011	$\pm$	0.00016	$\sqrt{3}$	-0.00006	$\pm$	0.00009
	20.3%	0.00036	$\pm$	0.00016	$\sqrt{3}$	0.00021	$\pm$	0.00009

<sup>a</sup> Nuclides and Isotopes: Chart of the Nuclides, 16<sup>th</sup> edition, (2002).



**Clad Density**

Two references were compared to confirm the composition and density of the Alloy 800H material.<sup>ab</sup> The density of Alloy 800H is taken to be 8.03 g/cm<sup>3</sup> with an estimated uncertainty of  $\pm 0.03$  g/cm<sup>3</sup>, which is the difference between the reported density values in the two references. This value is the bounding limit. The effective change in  $k_{\text{eff}}$  was determined. Results are shown in Table 2.65.

The total number of control rod sections used in the fully-loaded core is approximately 97.5, as approximately 30% of the control rods are actually inserted into the core. For determining the random component of the uncertainty, the results in Table 2.65 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.65.

Table 2.65. Effect of Uncertainty in Clad Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.03 g/cm <sup>3</sup> (1 $\sigma$ )	0.00028	$\pm$	0.00017	$\sqrt{3}$	0.00016	$\pm$	0.00010	22.5
	+0.03 g/cm <sup>3</sup> (1 $\sigma$ )	-0.00012	$\pm$	0.00016	$\sqrt{3}$	-0.00007	$\pm$	0.00009	
2	-0.03 g/cm <sup>3</sup> (1 $\sigma$ )	0.00012	$\pm$	0.00017	$\sqrt{3}$	0.00007	$\pm$	0.00010	58.5
	+0.03 g/cm <sup>3</sup> (1 $\sigma$ )	0.00001	$\pm$	0.00017	$\sqrt{3}$	0.00001	$\pm$	0.00010	
3	-0.03 g/cm <sup>3</sup> (1 $\sigma$ )	0.00006	$\pm$	0.00016	$\sqrt{3}$	0.00003	$\pm$	0.00009	78.0
	+0.03 g/cm <sup>3</sup> (1 $\sigma$ )	-0.00023	$\pm$	0.00016	$\sqrt{3}$	-0.00013	$\pm$	0.00009	
4	-0.03 g/cm <sup>3</sup> (1 $\sigma$ )	-0.00032	$\pm$	0.00017	$\sqrt{3}$	-0.00018	$\pm$	0.00010	72.0
	+0.03 g/cm <sup>3</sup> (1 $\sigma$ )	-0.00005	$\pm$	0.00017	$\sqrt{3}$	-0.00003	$\pm$	0.00010	
5	-0.03 g/cm <sup>3</sup> (1 $\sigma$ )	0.00004	$\pm$	0.00016	$\sqrt{3}$	0.00002	$\pm$	0.00009	91.0
	+0.03 g/cm <sup>3</sup> (1 $\sigma$ )	0.00007	$\pm$	0.00016	$\sqrt{3}$	0.00004	$\pm$	0.00009	

**Clad Composition**

The clad composition used in the benchmark model is derived from the aforementioned references for Alloy 800H, where the second reference provides a composition range and the first reference provides a nominal composition. A summary of the composition of Alloy 800H is provided in Table 2.66. The nominal distribution is used in the benchmark model. The composition of the clad material was varied from the nominal value. In the first case, the minimum compositions of all elements were used with iron as the remaining balance. The second case uses the maximum weights of all the elements with a reduction in the iron content until the minimum value is achieved; then nickel is reduced to achieve a total of 100 wt.%. The effective change in  $k_{\text{eff}}$  for these two cases was determined. Results are shown in Table 2.67.

The uncertainty in the clad composition is considered all systematic with no random component.

<sup>a</sup> Specification Sheet: Alloy 800, 800H, and 800AT, Sandmeyer Steel Company (April 2004).

<sup>b</sup> Material Characteristics: Alloy 800H, Philip Cornes, <http://www.cornes.com.sg/a800h.htm> (Accessed August 5, 2008).

Table 2.66. Composition of Alloy 800H.

Element	Minimum wt.%	Maximum wt.%	Nominal wt.%
C	0.06	0.1	0.08
Al	0.15	0.6	0.375
Si	--	1.0	0.35
P	--	--	0.02
S	--	0.015	0.01
Ti	0.15	0.6	0.375
Cr	19	23	21
Mn	--	1.5	1
Fe	39.5	--	43.99
Ni	30	35	32.5
Cu	--	0.75	0.3
Total	--	--	100.000

Table 2.67. Effect of Uncertainty in Clad Composition.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	Minimum Fe	-0.00010	$\pm$	0.00016	$\sqrt{3}$	-0.00006	$\pm$	0.00009
	Maximum Fe	-0.00004	$\pm$	0.00016	$\sqrt{3}$	-0.00002	$\pm$	0.00009
2	Minimum Fe	0.00014	$\pm$	0.00017	$\sqrt{3}$	0.00009	$\pm$	0.00010
	Maximum Fe	0.00016	$\pm$	0.00017	$\sqrt{3}$	0.00009	$\pm$	0.00010
3	Minimum Fe	-0.00009	$\pm$	0.00017	$\sqrt{3}$	-0.00005	$\pm$	0.00010
	Maximum Fe	-0.00020	$\pm$	0.00016	$\sqrt{3}$	-0.00012	$\pm$	0.00009
4	Minimum Fe	-0.00014	$\pm$	0.00017	$\sqrt{3}$	-0.00008	$\pm$	0.00010
	Maximum Fe	-0.00012	$\pm$	0.00017	$\sqrt{3}$	-0.00007	$\pm$	0.00010
5	Minimum Fe	-0.00012	$\pm$	0.00016	$\sqrt{3}$	-0.00007	$\pm$	0.00009
	Maximum Fe	-0.00007	$\pm$	0.00016	$\sqrt{3}$	-0.00004	$\pm$	0.00009

### Clad Impurity

No information was available regarding any impurities present in the Alloy 800H metal. Concentrations of minor and trace elements found commonly in nickel alloy<sup>a</sup> were added to the clad material in the benchmark model (a neutron cross-section library was unavailable for Ytterbium) to determine the effective uncertainty in  $k_{\text{eff}}$ . Because these impurities are not necessarily those that would have been in the alloy, and the total amount is ~10 wt.%, the atom density of the primary alloy composition was not

<sup>a</sup> J. H. Zaidi, S. Waheed, and S. Ahmed, "Determination of Trace Impurities in Nickel-Based Alloy using Neutron Activation Analysis," *J. Radioanal. Nucl. Ch.*, **242**: 259-263 (1999).

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

reduced. Thus the total atom density of the material was increased by including the additional materials. A list of the additional impurities is shown in Table 2.68, and results are shown in Table 2.69. This value is treated as a bounding limit.

The uncertainty in the clad impurity is considered all systematic with no random component.

Table 2.68. Concentration (by weight) of Minor and Trace Elements in Nickel Alloy.

Element	Concentration	Element	Concentration
As	63.7 µg/g	Mo	9.8 µg/g
Ba	215 µg/g	Na	0.45 %
Br	8.9 µg/g	Nd	16.2 µg/g
Ca	5.9 %	Rb	24 ng/g
Ce	0.33 %	Sb	2.2 µg/g
Co	9.96 µg/g	Sc	0.13 µg/g
Cs	4.34 µg/g	Se	0.16 µg/g
Dy	6.12 µg/g	Sm	0.23 µg/g
Er	2.8 µg/g	Sn	0.25 µg/g
Eu	1.17 µg/g	Sr	371 µg/g
Ga	107.5 µg/g	Ta	1.21 µg/g
Gd	1.7 µg/g	Tb	1.24 µg/g
Hf	19.5 µg/g	Th	18.3 µg/g
Hg	6 ng/g	U	4.3 µg/g
In	245 ng/g	Yb <sup>(a)</sup>	2.48 µg/g
La	2.34 µg/g	V	0.75 %
Lu	1.16 µg/g	Zn	93.4 µg/g
Mg	2.14 %		

(a) A neutron cross-section library was unavailable to include this element in the analysis.

Table 2.69. Effect of Uncertainty in Clad Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	Added Impurities	0.00015	$\pm$	0.00016	$2\sqrt{3}$	0.00004	$\pm$	0.00005
2	Added Impurities	-0.00005	$\pm$	0.00016	$2\sqrt{3}$	-0.00001	$\pm$	0.00005
3	Added Impurities	0.00015	$\pm$	0.00016	$2\sqrt{3}$	0.00004	$\pm$	0.00005
4	Added Impurities	-0.00001	$\pm$	0.00016	$2\sqrt{3}$	0.00000	$\pm$	0.00005
5	Added Impurities	-0.00002	$\pm$	0.00016	$2\sqrt{3}$	-0.00001	$\pm$	0.00004

### 2.1.3.6 Instrumentation

Insufficient information is available to model and comprehensively evaluate the uncertainties and biases related to the utility of instrumentation in the HTTR. A basic analysis of the general description of the instrumentation was performed, as discussed in Section 2.1.2.6.

### 2.1.3.7 Graphite Blocks

#### **Density**

The IG-110 graphite density was varied  $\pm 0.04 \text{ g/cm}^3$  from a nominal value selected as  $1.76 \text{ g/cm}^3$  (ranging from  $1.75$  to  $1.78 \text{ g/cm}^3$ , Tables 1.13, 1.19, and 1.27 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . A variation of  $0.03 \text{ g/cm}^3$  accounts for the difference in density between the various samples of IG-110 blocks, and a variation of  $0.01 \text{ g/cm}^3$  is assumed to encompass the variability in the volume fraction caused by eliminating various features such as the dowels, sockets, fuel handling position, and ridged features on the fuel rods. The assumed uncertainty of  $0.03 \text{ g/cm}^3$  for the IG-110 graphite encompasses the range of reported densities found throughout Section 1 of [HTTR-GCR-RESR-001](#). Results are shown in Table 2.70. This value is treated as a bounding limit.

Previous results<sup>a</sup> state that a graphite weight difference of less than 1% should result in a bias of  $-0.3 \%$   $\Delta k/k$ . Scaling the results provided in Table 2.70 provides an uncertainty comparable to the previously published information.

The total number of IG-110 graphite blocks used in the fully-loaded core is 549. For determining the random component of the uncertainty, the results in Table 2.70 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.70.

Table 2.70. Effect of Uncertainty in IG-110 Density in Graphite Blocks.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	$-0.04 \text{ g/cm}^3$	-0.00418	$\pm$	0.00016	$\sqrt{3}$	-0.00241	$\pm$	0.00009	494
	$+0.04 \text{ g/cm}^3$	0.00422	$\pm$	0.00017	$\sqrt{3}$	0.00244	$\pm$	0.00010	
2	$-0.04 \text{ g/cm}^3$	-0.00424	$\pm$	0.00016	$\sqrt{3}$	-0.00245	$\pm$	0.00009	504
	$+0.04 \text{ g/cm}^3$	0.00455	$\pm$	0.00016	$\sqrt{3}$	0.00263	$\pm$	0.00009	
3	$-0.04 \text{ g/cm}^3$	-0.00507	$\pm$	0.00016	$\sqrt{3}$	-0.00293	$\pm$	0.00009	519
	$+0.04 \text{ g/cm}^3$	0.00439	$\pm$	0.00016	$\sqrt{3}$	0.00253	$\pm$	0.00009	
4	$-0.04 \text{ g/cm}^3$	-0.00575	$\pm$	0.00017	$\sqrt{3}$	-0.00332	$\pm$	0.00010	519
	$+0.04 \text{ g/cm}^3$	0.00553	$\pm$	0.00016	$\sqrt{3}$	0.00319	$\pm$	0.00009	
5	$-0.04 \text{ g/cm}^3$	-0.00513	$\pm$	0.00016	$\sqrt{3}$	-0.00296	$\pm$	0.00009	534
	$+0.04 \text{ g/cm}^3$	0.00473	$\pm$	0.00016	$\sqrt{3}$	0.00273	$\pm$	0.00009	

<sup>a</sup> Fujimoto, N., Nakano, M., Takeuchi, M., Fujisaki, S., and Yamashita, K., "Start-Up Core Physics Tests of High Temperature Engineering Test Reactor (HTTR), (II): First Criticality by an Annular Form Fuel Loading and Its Criticality Prediction Method," *J. Atomic Energy Society Japan*, **42**(5), 458-464 (2000).

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE**Impurity**

The graphite block impurity was varied from 0-3 ppm by weight of equivalent natural-boron content (Table 1.13 of [HTTR-GCR-RESR-001](#)), where the 3 ppm value is 3 times the bounding limit, to determine the bounding uncertainty in  $k_{\text{eff}}$ . The nominal impurity is 0.40 ppm or 0.37 ppm of natural boron by weight for the fuel/control blocks and reflector blocks, respectively (Table 1.27 of [HTTR-GCR-RESR-001](#)). However, characterization of the graphite first loaded into the reactor determined the equivalent boron content for IG-110 graphite to be 0.59 ppm.<sup>a</sup> This latter value is used in the benchmark model. Results are shown in Table 2.71.

It has been reported that the estimated air content in the graphite blocks would provide -0.4 %  $\Delta k/k$  to the computational model.<sup>b</sup> Reference 1 states that an uncertainty factor of  $\sim 0.52$  %  $\Delta k/k$  should be used. The inclusion of air in the benchmark model did not produce a noticeable change in reactivity; this was done by modeling air, at atmospheric pressure, distributed throughout the block in the quantity equivalent to the volume fraction to the void space generated for the dowels, sockets, fuel handling position, and other miscellaneous block features. However, it is unclear exactly how much air would be entrapped within the graphite blocks. Air can be entrapped during the graphitization process or absorbed onto the graphite surface. Typically, significant contribution to the equivalent boron content in a graphite block is caused by impurities in the graphite. Methods to measure the impurity content in graphite have improved over the past several years, and the impurity content of the HTTR graphite may need to be reassessed.<sup>c</sup>

Graphite is also somewhat hygroscopic and can absorb water into its pores after fabrication. At low temperatures, the water would still be present in the graphite. Information regarding possible water content in the graphite blocks is unavailable, however.

The uncertainty in the graphite block impurity is considered all systematic with no random component.

Table 2.71. Effect of Uncertainty in IG-110 Impurity in Graphite Blocks.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	0.00921	$\pm$	0.00016	$\sqrt{3}$	0.00532	$\pm$	0.00009
	3 ppm	-0.03424	$\pm$	0.00016	$3\sqrt{3}$	-0.00659	$\pm$	0.00003
2	0 ppm	0.00842	$\pm$	0.00016	$\sqrt{3}$	0.00486	$\pm$	0.00009
	3 ppm	-0.03204	$\pm$	0.00016	$3\sqrt{3}$	-0.00617	$\pm$	0.00003
3	0 ppm	0.00800	$\pm$	0.00016	$\sqrt{3}$	0.00462	$\pm$	0.00009
	3 ppm	-0.03122	$\pm$	0.00016	$3\sqrt{3}$	-0.00601	$\pm$	0.00003
4	0 ppm	0.00727	$\pm$	0.00016	$\sqrt{3}$	0.00420	$\pm$	0.00009
	3 ppm	-0.02822	$\pm$	0.00017	$3\sqrt{3}$	-0.00543	$\pm$	0.00003
5	0 ppm	0.00848	$\pm$	0.00016	$\sqrt{3}$	0.00490	$\pm$	0.00009
	3 ppm	-0.03036	$\pm$	0.00016	$3\sqrt{3}$	-0.00584	$\pm$	0.00003

<sup>a</sup> Sumita, J., Shibata, T., Hanawa, S., Ishihara, M., Iyoku, T., and Sawa, K., "Characteristics of First Loaded IG-110 Graphite in HTTR Core," *JAEA Technol 2006-048*, October (2006).

<sup>b</sup> Fujimoto, N., Nakano, M., Takeuchi, M., Fujisaki, S., and Yamashita, K., "Start-Up Core Physics Tests of High Temperature Engineering Test Reactor (HTTR), (II): First Criticality by an Annular Form Fuel Loading and Its Criticality Prediction Method," *J. Atomic Energy Society Japan*, **42**(5), 458-464 (2000).

<sup>c</sup> Private communication with Rob Bratton at Idaho National Laboratory (November 20, 2008).

### 2.1.3.8 Permanent Reflectors

#### Density

The PGX graphite density was varied  $\pm 0.04 \text{ g/cm}^3$  from a nominal value selected as  $1.73 \text{ g/cm}^3$  (ranging from  $1.73$  to  $1.74 \text{ g/cm}^3$ , Tables 1.19, 1.20, and 1.27 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . A variation of  $0.03 \text{ g/cm}^3$  accounts for the PGX, and a variation of  $0.01 \text{ g/cm}^3$  is assumed to encompass the variability in the volume fraction, which is not provided. The assumed uncertainty of  $0.03 \text{ g/cm}^3$  for the PGX graphite encompasses the range of reported densities found throughout Section 1 of [HTTR-GCR-RESR-001](#). Results are shown in Table 2.72. This value is treated as a bounding limit.

The total number of permanent reflector blocks used in all core configurations is 96. For determining the random component of the uncertainty, the results in Table 2.72 would be divided by  $\sqrt{96}$ .

Table 2.72. Effect of Uncertainty in PGX Density in Permanent Reflector.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	$-0.04 \text{ g/cm}^3$	-0.00068	$\pm$	0.00017	$\sqrt{3}$	-0.00039	$\pm$	0.00010
	$+0.04 \text{ g/cm}^3$	0.00080	$\pm$	0.00016	$\sqrt{3}$	0.00046	$\pm$	0.00009
2	$-0.04 \text{ g/cm}^3$	-0.00070	$\pm$	0.00016	$\sqrt{3}$	-0.00040	$\pm$	0.00009
	$+0.04 \text{ g/cm}^3$	0.00098	$\pm$	0.00016	$\sqrt{3}$	0.00057	$\pm$	0.00009
3	$-0.04 \text{ g/cm}^3$	-0.00060	$\pm$	0.00016	$\sqrt{3}$	-0.00035	$\pm$	0.00009
	$+0.04 \text{ g/cm}^3$	0.00031	$\pm$	0.00016	$\sqrt{3}$	0.00018	$\pm$	0.00009
4	$-0.04 \text{ g/cm}^3$	-0.00047	$\pm$	0.00017	$\sqrt{3}$	-0.00027	$\pm$	0.00010
	$+0.04 \text{ g/cm}^3$	0.00033	$\pm$	0.00017	$\sqrt{3}$	0.00019	$\pm$	0.00010
5	$-0.04 \text{ g/cm}^3$	-0.00059	$\pm$	0.00016	$\sqrt{3}$	-0.00034	$\pm$	0.00009
	$+0.04 \text{ g/cm}^3$	0.00040	$\pm$	0.00016	$\sqrt{3}$	0.00023	$\pm$	0.00009

#### Impurity

The permanent reflector impurity was varied from 0-5 ppm by weight of equivalent natural-boron content (Table 1.16 of [HTTR-GCR-RESR-001](#)) to determine the bounding uncertainty in  $k_{\text{eff}}$ . The nominal impurity is 1.91 ppm of natural boron by weight (Table 1.27 of [HTTR-GCR-RESR-001](#)). Results are shown in Table 2.73.

The uncertainty in the permanent reflector impurity is considered all systematic with no random component.

Table 2.73. Effect of Uncertainty in PGX Impurity in Permanent Reflector.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	0.00765	$\pm$	0.00017	$\sqrt{3}$	0.00442	$\pm$	0.00010
	5 ppm	-0.01014	$\pm$	0.00016	$\sqrt{3}$	-0.00585	$\pm$	0.00009
2	0 ppm	0.00656	$\pm$	0.00016	$\sqrt{3}$	0.00379	$\pm$	0.00009
	5 ppm	-0.00864	$\pm$	0.00017	$\sqrt{3}$	-0.00499	$\pm$	0.00010
3	0 ppm	0.00543	$\pm$	0.00016	$\sqrt{3}$	0.00314	$\pm$	0.00009
	5 ppm	-0.00752	$\pm$	0.00017	$\sqrt{3}$	-0.00434	$\pm$	0.00010
4	0 ppm	0.00296	$\pm$	0.00016	$\sqrt{3}$	0.00171	$\pm$	0.00009
	5 ppm	-0.00427	$\pm$	0.00017	$\sqrt{3}$	-0.00247	$\pm$	0.00010
5	0 ppm	0.00466	$\pm$	0.00016	$\sqrt{3}$	0.00269	$\pm$	0.00009
	5 ppm	-0.00598	$\pm$	0.00016	$\sqrt{3}$	-0.00345	$\pm$	0.00009

#### 2.1.3.9 Dummy Blocks

##### **Density**

The IG-11 graphite density was varied  $\pm 0.04 \text{ g/cm}^3$  from a nominal value of  $1.75 \text{ g/cm}^3$  (Table 1.20 of [HTTR-GCR-RESR-001](#)) to determine the effective uncertainty in  $k_{\text{eff}}$ . A variation of  $0.03 \text{ g/cm}^3$  was selected as the density uncertainty because IG-11 graphite is essentially impure IG-110 graphite. An additional variation of  $0.01 \text{ g/cm}^3$  is assumed to encompass the variability in the volume fraction caused by eliminating various features such as the dowels, sockets, and fuel handling position. Results are shown in Table 2.74. This value is treated as a bounding limit.

The total number of IG-11 graphite blocks used in the fully-loaded core is approximately zero; there are IG-11 graphite blocks in the annular core configurations. For determining the random component of the uncertainty, the results in Table 2.74 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.74.

Table 2.74. Effect of Uncertainty in IG-11 Density in Dummy Blocks.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.04 g/cm <sup>3</sup>	0.00008	$\pm$	0.00017	$\sqrt{3}$	0.00005	$\pm$	0.00010	55
	+0.04 g/cm <sup>3</sup>	-0.00050	$\pm$	0.00017	$\sqrt{3}$	-0.00029	$\pm$	0.00010	
2	-0.04 g/cm <sup>3</sup>	0.00054	$\pm$	0.00017	$\sqrt{3}$	0.00031	$\pm$	0.00010	45
	+0.04 g/cm <sup>3</sup>	-0.00057	$\pm$	0.00016	$\sqrt{3}$	-0.00033	$\pm$	0.00009	
3	-0.04 g/cm <sup>3</sup>	0.00008	$\pm$	0.00016	$\sqrt{3}$	0.00005	$\pm$	0.00009	30
	+0.04 g/cm <sup>3</sup>	-0.00046	$\pm$	0.00017	$\sqrt{3}$	-0.00027	$\pm$	0.00010	
4	-0.04 g/cm <sup>3</sup>	0.00016	$\pm$	0.00017	$\sqrt{3}$	0.00009	$\pm$	0.00010	30
	+0.04 g/cm <sup>3</sup>	-0.00051	$\pm$	0.00017	$\sqrt{3}$	-0.00029	$\pm$	0.00010	
5	-0.04 g/cm <sup>3</sup>	-0.00016	$\pm$	0.00016	$\sqrt{3}$	0.00009	$\pm$	0.00009	15
	+0.04 g/cm <sup>3</sup>	-0.00011	$\pm$	0.00016	$\sqrt{3}$	-0.00006	$\pm$	0.00009	

### **Impurity**

The graphite block impurity was varied from 0-5 ppm by weight of equivalent natural-boron content to determine the bounding uncertainty in  $k_{\text{eff}}$ . The nominal impurity is 3.1 ppm natural boron by weight (Ref 1, p. 314). The dummy blocks in the HTTR are created from the same graphite material, IG-11, as the reflector graphite in the HTR-10 reactor.<sup>ab</sup> The maximum impurity content was derived from the reflector graphite in the HTR-10 reactor (HTR10-GCR-RESR-001), which has a nominal boron concentration of  $4.8366 \pm 0.09673$  ppm ( $\pm 2\%$ ). Results are shown in Table 2.75.

The uncertainty in the graphite block impurity is considered all systematic with no random component.

<sup>a</sup> L. Xiaowei, R. Jean-Charles, and Y. Suyuan, "Effect of Temperature on Graphite Oxidation Behavior," *Nucl. Eng. Des.*, **227**: 273-280 (2004).

<sup>b</sup> X. Luo, J-C. Robin, and S. Yu, "Comparison of Oxidation Behaviors of Different Grades of Nuclear Graphite," *Nucl. Sci. Eng.*, **151**, 121-127 (2005).



Table 2.75. Effect of Uncertainty in IG-11 Impurity in Dummy Blocks.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	0 ppm	0.01219	$\pm$	0.00017	$\sqrt{3}$	0.00704	$\pm$	0.00010
	5 ppm	-0.00671	$\pm$	0.00017	$\sqrt{3}$	-0.00387	$\pm$	0.00010
2	0 ppm	0.01278	$\pm$	0.00016	$\sqrt{3}$	0.00738	$\pm$	0.00009
	5 ppm	-0.00674	$\pm$	0.00017	$\sqrt{3}$	-0.00389	$\pm$	0.00010
3	0 ppm	0.00797	$\pm$	0.00017	$\sqrt{3}$	0.00460	$\pm$	0.00010
	5 ppm	-0.00457	$\pm$	0.00017	$\sqrt{3}$	-0.00264	$\pm$	0.00010
4	0 ppm	0.01037	$\pm$	0.00017	$\sqrt{3}$	0.00599	$\pm$	0.00010
	5 ppm	-0.00580	$\pm$	0.00017	$\sqrt{3}$	-0.00335	$\pm$	0.00010
5	0 ppm	0.00376	$\pm$	0.00016	$\sqrt{3}$	0.00217	$\pm$	0.00009
	5 ppm	-0.00215	$\pm$	0.00016	$\sqrt{3}$	-0.00124	$\pm$	0.00009

**Block Type**

There are two types of dummy blocks, one with a hole pattern similar to that of a control block, and the other with three holes but of smaller diameter (Ref. 2, p. 14). Elsewhere the source of eight types of dummy blocks are specified (most likely having one of the two hole patterns).<sup>a</sup> Because the true dimensions of the smaller hole design is unknown, the dummy blocks will all be modeled with the holes of the control blocks but an additional uncertainty will be assessed to account for this discrepancy. This uncertainty will be determined by completely filling the holes of the dummy blocks with IG-11 graphite material as a bounding limit (i.e., maximizing the amount of graphite material mass) representing the minimum dimensions of three infinitely thin holes in the dummy blocks. The volume fraction of the simulated control channels in a dummy blocks is approximately 31.76 %, representing an increase in graphite mass of 36 kg per block when the holes are completely filled (based on a graphite density of 1.75 g/cm<sup>3</sup> with an 0.005 % reduction for void volume). Results are shown in Table 2.76.

There are no IG-11 graphite blocks used in the fully-loaded core; there are IG-11 graphite blocks in the annular core configurations. For determining the random component of the uncertainty, the results in Table 2.76 would be divided by  $\sqrt{N}$ , where N for each case is shown in Table 2.76.

<sup>a</sup> N. Fujimoto, N. Nojiri, and K. Yamashita, "HTTR's Benchmark Calculation of Start-Up Core Physics Tests," Report of the 3<sup>rd</sup> Research Coordination Meeting on the CRP, IAEA, Oarai, Japan, March 12-16 (2001).

Table 2.76. Effect of Uncertainty in Dummy Blocks Type.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	Filled Holes	-0.00058	$\pm$	0.00017	$2\sqrt{3}$	-0.00017	$\pm$	0.00005	55
2	Filled Holes	-0.00507	$\pm$	0.00017	$2\sqrt{3}$	-0.00146	$\pm$	0.00005	45
3	Filled Holes	-0.00200	$\pm$	0.00017	$2\sqrt{3}$	-0.00058	$\pm$	0.00005	30
4	Filled Holes	-0.00893	$\pm$	0.00017	$2\sqrt{3}$	-0.00258	$\pm$	0.00005	30
5	Filled Holes	0.00234	$\pm$	0.00016	$2\sqrt{3}$	0.00068	$\pm$	0.00005	15

### 2.1.3.10 Helium Coolant

#### **Density**

The density of helium gas was evaluated using the ideal gas law,  $PV=nRT$ , at a pressure of 1 atm and temperature of 25 °C. The helium coolant was modeled with an atom density of  $2.4616 \times 10^{-4}$  atoms/b-cm (mass density of  $1.6361 \times 10^{-4}$  g/cm<sup>3</sup>).

The helium density was varied approximately  $\pm 35\%$  ( $10 \times$  bounding limit) to determine the effective uncertainty in  $k_{\text{eff}}$ . Results are shown in Table 2.77.

The effect of neglecting the helium content and replacing it with an empty void was also performed. The effective change in change in  $k_{\text{eff}}$  was determined. Results are shown in Table 2.77.

The uncertainty in the helium density is considered all systematic with no random component.

Table 2.77. Effect of Uncertainty in Helium Coolant Density.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	void	-0.00006	$\pm$	0.00016	1	-0.00006	$\pm$	0.00016
	-35% (10 $\sigma$ )	-0.00007	$\pm$	0.00017	10 $\sqrt{3}$	0.00000	$\pm$	0.00001
	+35% (10 $\sigma$ )	0.00005	$\pm$	0.00017	10 $\sqrt{3}$	0.00000	$\pm$	0.00001
2	void	0.00014	$\pm$	0.00017	1	0.00014	$\pm$	0.00017
	-35% (10 $\sigma$ )	0.00004	$\pm$	0.00017	10 $\sqrt{3}$	0.00000	$\pm$	0.00001
	+35% (10 $\sigma$ )	0.00021	$\pm$	0.00016	10 $\sqrt{3}$	0.00001	$\pm$	0.00001
3	void	-0.00014	$\pm$	0.00016	1	-0.00014	$\pm$	0.00016
	-35% (10 $\sigma$ )	-0.00003	$\pm$	0.00016	10 $\sqrt{3}$	0.00000	$\pm$	0.00000
	+35% (10 $\sigma$ )	0.00004	$\pm$	0.00017	10 $\sqrt{3}$	0.00000	$\pm$	0.00000
4	void	-0.00005	$\pm$	0.00016	1	-0.00005	$\pm$	0.00016
	-35% (10 $\sigma$ )	-0.00022	$\pm$	0.00017	10 $\sqrt{3}$	-0.00001	$\pm$	0.00001
	+35% (10 $\sigma$ )	-0.00016	$\pm$	0.00017	10 $\sqrt{3}$	-0.00001	$\pm$	0.00001
5	void	0.00018	$\pm$	0.00016	1	0.00018	$\pm$	0.00016
	-35% (10 $\sigma$ )	-0.00010	$\pm$	0.00016	10 $\sqrt{3}$	-0.00001	$\pm$	0.00001
	+35% (10 $\sigma$ )	0.00001	$\pm$	0.00016	10 $\sqrt{3}$	0.00000	$\pm$	0.00001

### Impurity

The upper impurity limit in the helium coolant was included in the model to determine its effect upon the uncertainty in  $k_{\text{eff}}$ . Upper concentration limits from Table 1.10 of [HTTR-GCR-RESR-001](#) were included although the impurity content in helium at room temperature would be considerably less (and practically nonexistent); therefore it will be treated as a bounding limit. The bounding limit was multiplied by 10 for each component in order to assess the uncertainty, but the effects were still negligible. Results are shown in Table 2.78.

The uncertainty in the helium impurity is considered all systematic with no random component.

Table 2.78. Effect of Uncertainty in Helium Coolant Impurity.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$
1	Added Impurities ( $\times 10$ )	-0.00004	$\pm$	0.00017	20 $\sqrt{3}$	0.00000	$\pm$	0.00000
2	Added Impurities ( $\times 10$ )	0.00024	$\pm$	0.00017	20 $\sqrt{3}$	0.00001	$\pm$	0.00000
3	Added Impurities ( $\times 10$ )	0.00011	$\pm$	0.00016	20 $\sqrt{3}$	0.00000	$\pm$	0.00000
4	Added Impurities ( $\times 10$ )	0.00003	$\pm$	0.00017	20 $\sqrt{3}$	0.00000	$\pm$	0.00000
5	Added Impurities ( $\times 10$ )	0.00005	$\pm$	0.00016	20 $\sqrt{3}$	0.00000	$\pm$	0.00000

## 2.1.4 Additional Analyses

### 2.1.4.1 Room Return

Insufficient information is available to model and evaluate the uncertainties and biases related to any room return effects in the HTTR. Shielding plugs, plates, and blocks are incorporated within the HTTR vessel and would considerably reduce room return effects from the surrounding reactor vessel, reactor internals, and HTTR infrastructure and facility due to the content of sintered B<sub>4</sub>C/C neutron absorber.

A conservative analysis of the HTTR benchmark model of the fully-loaded core ([HTTR-GCR-RESR-001](#)) surrounded by shielding material, steel, and concrete provided an insignificant effect because the slight increase in the effective multiplication factor was well below the range of statistical uncertainty for the analysis. Actual room return effects would be assumed quite negligible.

### 2.1.4.2 TRISO Particle Placement

Currently MCNP has a limited capability for modeling stochastic geometries. The HTTR core is unique in the fact that it has 12 different enrichments throughout the core. MCNP could effectively model randomness for only two types of TRISO particles at once because the URAN card used to create stochastic models has a maximum limit of two universes per model. A comparison of using the URAN analysis with multiple input decks to represent pairs of enriched TRISO particles was performed for the fully-loaded core configuration ([HTTR-GCR-RESR-001](#)) and shown to provide equivalent results to the approach performed below.

To approximate the bounding uncertainty in the effects of random TRISO placement, the fuel compacts were modeled with a uniform cell lattice of TRISO particles, which effectively creates partial particles along the compact borders. Figures 2.6 and 2.7 show a cross section of the fuel compacts with ordered and uniformly-filled TRISO distributions, respectively. The effective difference in the multiplication factor is shown in Table 2.79. The 30 vol. % packing fraction and uranium mass per fuel rod is conserved in this comparison. In order to conserve the uranium mass, the volume was estimated for the uranium kernels along the edges of the fuel compacts (using linear approximation of the cylindrical surface and spherical dome formulas)<sup>a</sup> to determine the approximate fuel content in each compact. Then the uniform cell lattice was adjusted such that the modeled fuel content matched the reported HTTR value. The reduction in resonance shielding effects in partial particles (i.e. fuel kernels not completely surrounded by graphite coatings) along the edges is not considered in this analysis. There is a slight mass uncertainty that is unaccounted for in this approximation. Because this is a bounding application, the results in Table 2.79 need to be divided by the square-root of three.

An analysis performed at the University of Michigan to look at the effects of explicitly modeling particle fuel in a very-high temperature gas-cooled reactor found that in a full core model, the effect of modeling with a uniform lattice and clipped TRISO particles would have a reduced  $k_{\text{eff}}$  of approximately 0.1 % compared to a heterogeneous core design containing only complete TRISO particles.<sup>b</sup> The results shown in Table 2.79 are approximately 0.1 % for the fully-loaded core configuration and slightly less for these annular configurations. The values calculated in Table 2.79 are used to represent the uncertainty in random TRISO particle placement in the HTTR. This uncertainty is treated as 100% systematic to capture the complete uncertainty in random particle placement.


A driver for this phenomenon might be explained by the Dancoff-Ginsberg factor, where in a lattice, the closer the lumps of fissionable material are to each other, the greater the shadowing effect and the smaller

<sup>a</sup> “Spherical and Ellipsoid Dome Formulas,” Monolithic Dome Institute, Italy, Texas (2001).

<sup>b</sup> W. Ji, J. L. Conlin, W. R. Martin, J. C. Lee, and F. B. Brown, “Explicit Modeling of Particle Fuel for the Very-High Temperature Gas-Cooled Reactor,” *Trans. Am. Nucl. Soc.*, **92** (June 2005).

the resonance integral for the interacting lattice, which results in an increase in the non-leakage probability and net increase in  $k_{\text{eff}}$ .<sup>a</sup>

A competing argument is that self-shielding and shadowing effects are quite negligible (2<sup>nd</sup>-order effect) and that small variations in fuel conservation actually lead to the difference in the calculated value of  $k_{\text{eff}}$ .<sup>bc</sup> Further discussion of the relevance of fuel particle parameters upon the reactivity of the system can be read elsewhere.<sup>d</sup> It remains up to the user's discretion to assess whether and how an uncertainty might apply to the modeling of this reactor system.



09-GAS0001-158-4


Figure 2.6. MCNP Ordered TRISO Lattice within the Fuel Compacts.

<sup>a</sup> J. R. Lamarsh, *Introduction to Nuclear Reactor Theory*, Addison-Wesley Publishing Company, Reading, Massachusetts, pp. 399-400 (1966).

<sup>b</sup> Personal communication between Luka Snoj and Forrest Brown from Los Alamos National Laboratory (November 20, 2008).

<sup>c</sup> F. B. Brown, "Monte Carlo Advances & Challenges," *Proc. Frederic Joliot and Otto Hahn Summer School 2005*, Karlsruhe, Germany, August 24 – September 2 (2005).

<sup>d</sup> L. Snoj and M. Ravnik, "Effect of Fuel Particles' Size and Position Variations on Multiplication Factor in Pebble-Bed Nuclear Reactors," *Kerntechnik*, **72** (2007).



09-GA50001-158-5

Figure 2.7. MCNP Uniformly-Filled TRISO Lattice within the Fuel Compacts.

Table 2.79. Comparison of Uniform and Organized TRISO Fill in Fuel Compacts.

Case	Organized Distribution (Figure 2.6)			Uniform Fill (Figure 2.7)			Bounding Difference			1 $\sigma$ Uncertainty		
	$k_{\text{eff}}$	$\pm$	$\sigma_k$	$k_{\text{eff}}$	$\pm$	$\sigma_k$	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	$\Delta k$	$\pm$	$\sigma_{\Delta k}$
1	1.03123	$\pm$	0.00012	1.03087	$\pm$	0.00011	0.00036	$\pm$	0.00016	0.00021	$\pm$	0.00009
2	1.03290	$\pm$	0.00012	1.03233	$\pm$	0.00011	0.00057	$\pm$	0.00016	0.00033	$\pm$	0.00009
3	1.02847	$\pm$	0.00012	1.02758	$\pm$	0.00012	0.00089	$\pm$	0.00017	0.00051	$\pm$	0.00010
4	1.03193	$\pm$	0.00012	1.03101	$\pm$	0.00012	0.00092	$\pm$	0.00017	0.00053	$\pm$	0.00009
5	1.02516	$\pm$	0.00011	1.02399	$\pm$	0.00012	0.00117	$\pm$	0.00016	0.00068	$\pm$	0.00009



### 2.1.4.3 Block Stack Alignment

As discussed in the previous section, MCNP has a limited capability for modeling stochastic geometries for systems with multiple unique components. Whereas the HTTR core model is comprised of 61 columns each containing 9 bricks, a comprehensive analysis of the stochastic nature of block stacking could not be easily evaluated.

### 2.1.4.4 MCNP Random Number Generation

The random number seed was changed for the benchmark model and compared with the original to determine the uncertainty in utilizing Monte Carlo analysis methods. Results are shown in Table 2.80. The uncertainty in the average is the standard deviation of the six averaged eigenvalues.

Table 2.80. Analysis of the Effect of Random Number Generation in MCNP.

Seed	Case 1			Case 2			Case 3		
	$k_{\text{eff}}$	$\pm$	$\sigma_{k_{\text{eff}}}$	$k_{\text{eff}}$	$\pm$	$\sigma_{k_{\text{eff}}}$	$k_{\text{eff}}$	$\pm$	$\sigma_{k_{\text{eff}}}$
123456787	1.03121	$\pm$	0.00012	1.03304	$\pm$	0.00012	1.02831	$\pm$	0.00012
9876543279	1.03145	$\pm$	0.00012	1.03292	$\pm$	0.00012	1.02850	$\pm$	0.00012
198765432799	1.03111	$\pm$	0.00011	1.03293	$\pm$	0.00012	1.02841	$\pm$	0.00011
17623486105893	1.03131	$\pm$	0.00011	1.03308	$\pm$	0.00012	1.02847	$\pm$	0.00012
19073486328125 <sup>(a)</sup>	1.03123	$\pm$	0.00012	1.03290	$\pm$	0.00012	1.02847	$\pm$	0.00012
32160231045432797	1.03107	$\pm$	0.00011	1.03291	$\pm$	0.00011	1.02844	$\pm$	0.00012
Average	1.03123	$\pm$	0.00014	1.03296	$\pm$	0.00008	1.02843	$\pm$	0.00007

Table 2.80 (cont'd.). Analysis of the Effect of Random Number Generation in MCNP.

Seed	Case 4			Case 5		
	$k_{\text{eff}}$	$\pm$	$\sigma_{k_{\text{eff}}}$	$k_{\text{eff}}$	$\pm$	$\sigma_{k_{\text{eff}}}$
123456787	1.03186	$\pm$	0.00012	1.02511	$\pm$	0.00011
9876543279	1.03169	$\pm$	0.00012	1.02495	$\pm$	0.00011
198765432799	1.03177	$\pm$	0.00012	1.02539	$\pm$	0.00012
17623486105893	1.03192	$\pm$	0.00012	1.02513	$\pm$	0.00012
19073486328125 <sup>(a)</sup>	1.03193	$\pm$	0.00012	1.02516	$\pm$	0.00011
32160231045432797	1.03204	$\pm$	0.00012	1.02536	$\pm$	0.00011
Average	1.03187	$\pm$	0.00012	1.02518	$\pm$	0.00017

(a) Primary seed value for evaluation.

### 2.1.4.5 Simplification Biases and Uncertainties

Whereas insufficient information is publicly available, a comprehensive analysis of simplification biases and their respective uncertainties could not be appropriately assessed. Currently only an approximate bias for the instrumentation components in the reactor has been assessed (Section 2.1.2.6). As additional

information becomes available, highly detailed and simplified benchmark models can be generated and their biases can be adequately determined.

### 2.1.5 Systematic Biases and Uncertainties

There was no information regarding systematic biases or uncertainties publicly available for these experiments. Previous efforts of the Japanese in analyzing the 19-fuel-column core (Case 1) obtained an analytical excess reactivity of 2.7 %  $\Delta k/k$ , with an estimated Monte Carlo calculation overestimate of 1.2 %  $\Delta k/k$ .<sup>a</sup> Additional information would be necessary to completely verify published results to generate an analytical bias for MCNP.

As discussed at the beginning of Section 2, all uncertainties are treated as 25% systematic, with no reduction in uncertainty due to the multiplicity of core components, and as 75% random.

### 2.1.6 Analysis of HTTR Uranium Content

The parameters (dimensions, density, etc.) of the TRISO particles fabricated during the manufacturing process are very normally distributed, except for any defective particles. The fuel content, or mass, is the most well-known specification and measured with the highest accuracy.<sup>b</sup>

Because of the overspecification of the TRISO particles in Table 1.14 of [HTTR-GCR-RESR-001](#) and the correlation of uranium kernel diameter, density, packing fraction, and mass, the effect of the uncertainties in the kernel diameter, density, and packing fraction are not included in the total uncertainty as separate entities. The uranium content of the fuel rods of  $188.58 \pm 5.66$  g (Table 1.14 of [HTTR-GCR-RESR-001](#)) is the parameter most likely known with the greatest accuracy. Therefore, the diameter of the kernels will be fixed at 600  $\mu\text{m}$ , and the density will be varied  $\pm 0.32$  g/cm<sup>3</sup> from a nominal value of 10.39 g/cm<sup>3</sup> to determine the effective uncertainty in  $k_{\text{eff}}$  due to the uranium mass uncertainty. Results are shown in Table 2.81. This value is treated as a bounding limit.

The total number of fuel rods used in the fully-loaded core is approximately 4,770. For determining the random component of the uncertainty, the results in Table 2.81 would be divided by  $\sqrt{N}$ .

---

<sup>a</sup> Fujimoto, N., Nakano, M., Takeuchi, M., Fujisaki, S., and Yamashita, K., "Start-Up Core Physics Tests of High Temperature Engineering Test Reactor (HTTR), (II): First Criticality by an Annular Form Fuel Loading and Its Criticality Prediction Method," *J. Atomic Energy Society Japan*, **42**(5), 458-464 (2000).

<sup>b</sup> Personal communication with David Petti from the Idaho National Laboratory (September 28, 2009).



Table 2.81. Effect of Uncertainty in Uranium Mass.

Case	Deviation	$\Delta k$	$\pm$	$\sigma_{\Delta k}$	Scaling Factor	$\Delta k_{\text{eff}} (1\sigma)$	$\pm$	$\sigma_{\Delta k_{\text{eff}}}$	N
1	-0.32 g/cm <sup>3</sup>	-0.00509	$\pm$	0.00017	$\sqrt{3}$	-0.00294	$\pm$	0.00010	2,955
	+0.32 g/cm <sup>3</sup>	0.00482	$\pm$	0.00016	$\sqrt{3}$	0.00278	$\pm$	0.00009	
2	-0.32 g/cm <sup>3</sup>	-0.00487	$\pm$	0.00017	$\sqrt{3}$	-0.00281	$\pm$	0.00010	3,285
	+0.32 g/cm <sup>3</sup>	0.00511	$\pm$	0.00017	$\sqrt{3}$	0.00295	$\pm$	0.00010	
3	-0.32 g/cm <sup>3</sup>	-0.00535	$\pm$	0.00017	$\sqrt{3}$	-0.00309	$\pm$	0.00010	3,780
	+0.32 g/cm <sup>3</sup>	0.00492	$\pm$	0.00017	$\sqrt{3}$	0.00284	$\pm$	0.00010	
4	-0.32 g/cm <sup>3</sup>	-0.00520	$\pm$	0.00017	$\sqrt{3}$	-0.00300	$\pm$	0.00010	3,780
	+0.32 g/cm <sup>3</sup>	0.00498	$\pm$	0.00017	$\sqrt{3}$	0.00288	$\pm$	0.00010	
5	-0.32 g/cm <sup>3</sup>	-0.00519	$\pm$	0.00016	$\sqrt{3}$	-0.00300	$\pm$	0.00009	4,275
	+0.32 g/cm <sup>3</sup>	0.00507	$\pm$	0.00016	$\sqrt{3}$	0.00293	$\pm$	0.00009	

### 2.1.7 Total Experimental Uncertainty

A compilation of the total evaluated uncertainty in the HTTR model is shown in Tables 2.82 through 2.86 for configurations 1 through 5, respectively. As discussed earlier, each of the evaluated uncertainties is divided into a systematic component (25%) and random component (75%), where appropriate. The random component is then divided by the square-root of the number of random objects reported in the subsection containing the calculated base uncertainty values. The root-mean square of each subcomponent is taken to determine the uncertainty in either the random or systematic components of the total evaluated uncertainty. The total evaluated uncertainty is then the root-mean square of the random and systematic uncertainties.

Uncertainties less than 0.00001 are reported as negligible (neg). When calculated uncertainties in  $\Delta k_{\text{eff}}$  are less than their statistical uncertainties, the statistical uncertainties are used in the calculation of the total uncertainty. Table listings where calculations were not performed or otherwise not available are labeled with 'NA'. For uncertainties where a random component is not applicable, the uncertainty is denoted with '--'.

The most significant contributions to the overall uncertainty from the systematic uncertainties include the impurities in the IG-110 graphite blocks, PGX graphite reflector blocks, and IG-11 graphite dummy blocks. All uncertainties providing at least 0.1 %  $\Delta k_{\text{eff}}$  are highlighted in gray in Tables 2.82 through 2.86. All of the random uncertainties are less than 0.1 %  $\Delta k_{\text{eff}}$ . The overall uncertainty is less than 1%  $\Delta k_{\text{eff}}$  (except for Cases 1 and 2); it is expected that the total uncertainty will be reduced as additional parameters that characterize the HTTR are obtained.

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.82. Total Experimental Uncertainty (Case 1).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$
Temperature	0.00013	-0.00013	--	--
Control Rod Positions	-0.00003	0.00003	-0.00002	0.00003
Measured Value of $k_{\text{eff}}$	neg	neg	neg	neg
Kernel Diameter	Correlated Parameter (see Section 2.1.6)			
Buffer Diameter	neg	neg	neg	neg
IPyC Diameter	neg	0.00001	neg	neg
SiC Diameter	0.00002	-0.00005	neg	neg
OPyC Diameter	neg	neg	neg	neg
Overcoat Diameter	NA	NA	NA	NA
Compact Inner Diameter	neg	neg	neg	neg
Compact Outer Diameter	-0.00002	0.00003	neg	neg
Compact Height	-0.00005	0.00005	neg	neg
Compact Packing Fraction	Correlated Parameter (see Section 2.1.6)			
Sleeve Inner Diameter	0.00002	-0.00003	neg	neg
Sleeve Outer Diameter	-0.00004	0.00004	neg	neg
Sleeve Height	-0.00001	0.00001	neg	neg
BP Diameter	0.00015	-0.00014	0.00001	-0.00001
BP Stack Height	0.00009	-0.00007	0.00001	-0.00001
BP Hole Diameter	0.00001	-0.00001	neg	neg
Graphite Disk Diameter	neg	neg	neg	neg
Disk Stack Height	0.00003	0.00003	neg	neg
CR Absorber Inner Diameter	neg	neg	neg	neg
CR Absorber Outer Diameter	neg	neg	neg	neg
CR Absorber Height	neg	neg	neg	neg
CR Clad Inner Diameter	neg	neg	neg	neg
CR Clad Outer Diameter	neg	neg	neg	neg
CR Clad Height	neg	neg	neg	neg
CR Spine Diameter	neg	neg	neg	neg
Instrumentation Dimensions	-0.00139	0.00139	--	--
Block Flat-to-Flat Distance	-0.00004	0.00003	neg	neg
Graphite Block Height	neg	neg	neg	neg
Dowel/Socket Dimensions	NA	NA	NA	NA
Fuel Channel Diameter	0.00004	-0.00005	neg	neg
Reflector Channel Diameter	neg	neg	neg	neg
Channel Pitch	-0.00004	0.00005	neg	neg

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.82 (cont'd.). Total Experimental Uncertainty (Case 1).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$
Handling Socket Dimensions	NA	NA	NA	NA
Column Pitch	0.00015	-0.00018	0.00006	-0.00007
CR Channel Diameter	neg	-0.00001	neg	neg
CR Channel Pitch	neg	neg	neg	neg
Permanent Reflector Diameter	-0.00117	0.00045	--	--
Dummy Block Dimensions	See Sections 2.1.2.7 and 2.1.3.9			
3.4 wt.% Enrichment	NA	NA	NA	NA
3.9 wt.% Enrichment	0.00005	0.00012	--	--
4.3 wt.% Enrichment	-0.00054	0.00054	--	--
4.8 wt.% Enrichment	-0.00023	0.00022	--	--
5.2 wt.% Enrichment	-0.00006	0.00008	--	--
5.9 wt.% Enrichment	-0.00063	0.00060	--	--
6.3 wt.% Enrichment	-0.00042	0.00034	--	--
6.7 wt.% Enrichment	NA	NA	NA	NA
7.2 wt.% Enrichment	-0.00074	0.00079	--	--
7.9 wt.% Enrichment	-0.00038	0.00048	--	--
9.4 wt.% Enrichment	-0.00055	0.00062	--	--
9.9 wt.% Enrichment	-0.00031	0.00027	--	--
Oxygen to Uranium Ratio	0.00008	-0.00009	--	--
UO <sub>2</sub> Density	Correlated Parameter (see Section 2.1.6)			
UO <sub>2</sub> Impurity	0.00032	-0.00056	--	--
Buffer Density	neg	neg	neg	neg
Buffer Impurity	0.00010	neg	--	--
IPyC Density	neg	neg	neg	neg
IPyC Impurity	0.00010	0.00010	--	--
SiC Density	NA	neg	NA	neg
SiC Impurity	0.00010	neg	--	--
OPyC Density	neg	neg	neg	neg
OPyC Impurity	0.00005	0.00010	--	--
Overcoat Density	-0.00001	0.00002	neg	neg
Overcoat Composition	NA	NA	NA	NA
Overcoat Impurity	0.00027	-0.00040	--	--
Compact Density	neg	neg	neg	neg
Compact Impurity	0.00009	-0.00043	--	--
Compact Free U Content	NA	neg	--	--

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.82 (cont'd.). Total Experimental Uncertainty (Case 1).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$
Sleeve Density	-0.00005	0.00004	neg	neg
Sleeve Impurity	0.00010	-0.00032	--	--
BP Absorber Density	0.00012	-0.00012	neg	neg
BP Absorber Content, 2.0 wt.%	0.00038	-0.00034	0.00002	-0.00002
BP Absorber Content, 2.5 wt.%	0.00036	-0.00035	0.00003	-0.00003
BP Absorber Impurity	NA	0.00014	--	--
BP Isotopic Abundance of $^{10}\text{B}$	0.00103	-0.00058	--	--
Graphite Disk Density	neg	neg	neg	neg
Graphite Disk Impurity	-0.00010	0.00010	--	--
CR Absorber Density	neg	-0.00001	neg	neg
CR Absorber Content	neg	neg	neg	neg
CR Absorber Impurity	NA	0.00005	--	--
CR Isotopic Abundance of $^{10}\text{B}$	0.00010	0.00010	--	--
CR Clad Density	0.00004	0.00002	0.00003	0.00003
CR Clad Composition	0.00009	0.00009	--	--
CR Clad Impurity	NA	0.00005	--	--
Instrumentation Composition	See Section 2.1.2.6			
IG-110 Density in Blocks	-0.00060	0.00061	-0.00008	0.00008
IG-110 Impurity in Blocks	0.00532	-0.00659	--	--
PGX Density	-0.00010	0.00012	-0.00003	0.00004
PGX Impurity	0.00442	-0.00585	--	--
Dummy Block Density	0.00002	-0.00007	neg	-0.00003
Dummy Block Impurity	0.00704	-0.00387	--	--
Dummy Block Type	NA	-0.00004	NA	-0.00003
Helium Coolant Density	neg	neg	--	--
Helium Coolant Impurity	NA	neg	--	--
Room Return	neg	neg	neg	neg
TRISO Particle Placement	0.00021	0.00021	neg	neg
Block Stack Alignment	NA	NA	NA	NA
MCNP Random Number Seed	--	--	0.00014	0.00014
Uranium Fuel Mass (Sec. 2.1.6)	-0.00073	0.00070	-0.00004	0.00004
Uncertainty of Components	0.01026	0.00997	0.00019	0.00019
<b>Total Evaluation Uncertainty</b>	<b>0.01026</b>	<b>0.00997</b>		

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.83. Total Experimental Uncertainty (Case 2).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$
Temperature	0.00013	-0.00013	--	--
Control Rod Positions	-0.00011	0.00012	-0.00008	0.00009
Measured Value of $k_{\text{eff}}$	neg	neg	neg	neg
Kernel Diameter	Correlated Parameter (see Section 2.1.6)			
Buffer Diameter	neg	0.00001	neg	neg
IPyC Diameter	neg	neg	neg	neg
SiC Diameter	0.00006	-0.00002	neg	neg
OPyC Diameter	0.00002	0.00003	neg	neg
Overcoat Diameter	NA	NA	NA	NA
Compact Inner Diameter	neg	neg	neg	neg
Compact Outer Diameter	-0.00002	0.00002	neg	neg
Compact Height	-0.00005	0.00004	neg	neg
Compact Packing Fraction	Correlated Parameter (see Section 2.1.6)			
Sleeve Inner Diameter	0.00002	-0.00002	neg	neg
Sleeve Outer Diameter	-0.00004	0.00004	neg	neg
Sleeve Height	-0.00001	0.00001	neg	neg
BP Diameter	0.00016	-0.00015	0.00001	-0.00001
BP Stack Height	0.00008	-0.00009	neg	neg
BP Hole Diameter	0.00002	-0.00001	neg	neg
Graphite Disk Diameter	neg	neg	neg	neg
Disk Stack Height	0.00002	0.00002	neg	neg
CR Absorber Inner Diameter	neg	neg	neg	neg
CR Absorber Outer Diameter	neg	neg	neg	neg
CR Absorber Height	0.00001	-0.00001	0.00001	-0.00001
CR Clad Inner Diameter	neg	neg	neg	neg
CR Clad Outer Diameter	neg	neg	neg	neg
CR Clad Height	-0.00003	-0.00003	-0.00001	-0.00001
CR Spine Diameter	neg	neg	neg	neg
Instrumentation Dimensions	-0.00116	0.00116	--	--
Block Flat-to-Flat Distance	-0.00003	0.00003	neg	neg
Graphite Block Height	neg	0.00002	neg	neg
Dowel/Socket Dimensions	NA	NA	NA	NA
Fuel Channel Diameter	0.00005	-0.00005	neg	neg
Reflector Channel Diameter	neg	neg	neg	neg
Channel Pitch	-0.00004	0.00004	neg	neg

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.83 (cont'd.). Total Experimental Uncertainty (Case 2).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$
Handling Socket Dimensions	NA	NA	NA	NA
Column Pitch	0.00016	-0.00017	0.00006	-0.00006
CR Channel Diameter	neg	neg	neg	neg
CR Channel Pitch	neg	neg	neg	neg
Permanent Reflector Diameter	-0.00083	0.00043	--	--
Dummy Block Dimensions	See Sections 2.1.2.7 and 2.1.3.9			
3.4 wt.% Enrichment	NA	NA	NA	NA
3.9 wt.% Enrichment	-0.00030	0.00023	--	--
4.3 wt.% Enrichment	-0.00081	0.00073	--	--
4.8 wt.% Enrichment	-0.00041	0.00037	--	--
5.2 wt.% Enrichment	-0.00033	0.00017	--	--
5.9 wt.% Enrichment	-0.00076	0.00076	--	--
6.3 wt.% Enrichment	-0.00067	0.00047	--	--
6.7 wt.% Enrichment	NA	NA	NA	NA
7.2 wt.% Enrichment	-0.00071	0.00060	--	--
7.9 wt.% Enrichment	-0.00038	0.00031	--	--
9.4 wt.% Enrichment	-0.00026	0.00016	--	--
9.9 wt.% Enrichment	-0.00015	0.00005	--	--
Oxygen to Uranium Ratio	0.00014	-0.00007	--	--
UO <sub>2</sub> Density	Correlated Parameter (see Section 2.1.6)			
UO <sub>2</sub> Impurity	0.00047	-0.00060	--	--
Buffer Density	neg	0.00001	neg	neg
Buffer Impurity	0.00010	neg	--	--
IPyC Density	neg	0.00001	neg	neg
IPyC Impurity	0.00009	0.00010	--	--
SiC Density	NA	neg	NA	neg
SiC Impurity	0.00010	0.00009	--	--
OPyC Density	neg	0.00001	neg	neg
OPyC Impurity	0.00024	-0.00015	--	--
Overcoat Density	neg	0.00002	neg	neg
Overcoat Composition	NA	NA	NA	NA
Overcoat Impurity	0.00030	-0.00059	--	--
Compact Density	neg	neg	neg	neg
Compact Impurity	0.00013	-0.00042	--	--
Compact Free U Content	NA	neg	--	--

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.83 (cont'd.). Total Experimental Uncertainty (Case 2).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$
Sleeve Density	-0.00003	0.00003	neg	neg
Sleeve Impurity	0.00018	-0.00021	--	--
BP Absorber Density	0.00015	-0.00007	neg	neg
BP Absorber Content, 2.0 wt.%	0.00044	-0.00034	0.00003	-0.00002
BP Absorber Content, 2.5 wt.%	0.00041	-0.00036	0.00003	-0.00003
BP Absorber Impurity	NA	0.00023	--	--
BP Isotopic Abundance of $^{10}\text{B}$	0.00131	-0.00042	--	--
Graphite Disk Density	neg	0.00001	neg	neg
Graphite Disk Impurity	0.00009	0.00010	--	--
CR Absorber Density	neg	neg	neg	neg
CR Absorber Content	0.00003	-0.00001	neg	neg
CR Absorber Impurity	NA	-0.00005	--	--
CR Isotopic Abundance of $^{10}\text{B}$	0.00010	neg	--	--
CR Clad Density	0.00002	neg	neg	neg
CR Clad Composition	0.00010	0.00010	--	--
CR Clad Impurity	NA	0.00005	--	--
Instrumentation Composition	See Section 2.1.2.6			
IG-110 Density in Blocks	-0.00061	0.00066	-0.00008	0.00009
IG-110 Impurity in Blocks	0.00486	-0.00617	--	--
PGX Density	-0.00010	0.00014	-0.00003	0.00004
PGX Impurity	0.00379	-0.00499	--	--
Dummy Block Density	0.00008	-0.00008	0.00003	-0.00004
Dummy Block Impurity	0.00738	-0.00389	--	--
Dummy Block Type	NA	-0.00037	NA	-0.00016
Helium Coolant Density	neg	0.00001	--	--
Helium Coolant Impurity	NA	neg	--	--
Room Return	neg	neg	neg	neg
TRISO Particle Placement	0.00033	0.00033	neg	neg
Block Stack Alignment	NA	NA	NA	NA
MCNP Random Number Seed	--	--	0.00008	0.00008
Uranium Fuel Mass (Sec. 2.1.6)	-0.00070	0.00074	-0.00004	0.00004
Uncertainty of Components	0.01005	0.00919	0.00017	0.00024
<b>Total Evaluation Uncertainty</b>	<b>0.01004</b>	<b>0.00919</b>		

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.84. Total Experimental Uncertainty (Case 3).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$
Temperature	0.00013	-0.00013	--	--
Control Rod Positions	-0.00015	0.00013	-0.00011	0.00010
Measured Value of $k_{\text{eff}}$	neg	neg	neg	neg
Kernel Diameter	Correlated Parameter (see Section 2.1.6)			
Buffer Diameter	-0.00002	0.00001	neg	neg
IPyC Diameter	-0.00001	neg	neg	neg
SiC Diameter	0.00005	-0.00005	neg	neg
OPyC Diameter	-0.00002	neg	neg	neg
Overcoat Diameter	NA	NA	NA	NA
Compact Inner Diameter	neg	neg	neg	neg
Compact Outer Diameter	-0.00004	0.00003	neg	neg
Compact Height	-0.00005	0.00004	neg	neg
Compact Packing Fraction	Correlated Parameter (see Section 2.1.6)			
Sleeve Inner Diameter	0.00002	-0.00003	neg	neg
Sleeve Outer Diameter	-0.00004	0.00005	neg	neg
Sleeve Height	-0.00001	0.00001	neg	neg
BP Diameter	0.00017	-0.00017	0.00001	-0.00001
BP Stack Height	0.00006	-0.00011	0.00001	-0.00002
BP Hole Diameter	0.00001	-0.00002	neg	neg
Graphite Disk Diameter	neg	neg	neg	neg
Disk Stack Height	neg	neg	neg	neg
CR Absorber Inner Diameter	neg	neg	neg	neg
CR Absorber Outer Diameter	neg	neg	neg	neg
CR Absorber Height	0.00001	-0.00001	neg	neg
CR Clad Inner Diameter	neg	neg	neg	neg
CR Clad Outer Diameter	-0.00001	0.00001	neg	neg
CR Clad Height	-0.00004	-0.00003	-0.00001	-0.00001
CR Spine Diameter	neg	neg	neg	neg
Instrumentation Dimensions	-0.00100	0.00100	--	--
Block Flat-to-Flat Distance	-0.00005	0.00004	-0.00001	neg
Graphite Block Height	neg	neg	neg	neg
Dowel/Socket Dimensions	NA	NA	NA	NA
Fuel Channel Diameter	0.00005	-0.00006	neg	neg
Reflector Channel Diameter	neg	neg	neg	neg
Channel Pitch	-0.00004	0.00003	neg	neg



## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.84 (cont'd.). Total Experimental Uncertainty (Case 3).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$
Handling Socket Dimensions	NA	NA	NA	NA
Column Pitch	0.00015	-0.00018	0.00006	-0.00007
CR Channel Diameter	0.00001	-0.00001	neg	neg
CR Channel Pitch	neg	neg	neg	neg
Permanent Reflector Diameter	-0.00084	0.00034	--	--
Dummy Block Dimensions	See Sections 2.1.2.7 and 2.1.3.9			
3.4 wt.% Enrichment	NA	NA	NA	NA
3.9 wt.% Enrichment	-0.00064	0.00077	--	--
4.3 wt.% Enrichment	-0.00092	0.00098	--	--
4.8 wt.% Enrichment	-0.00043	0.00052	--	--
5.2 wt.% Enrichment	-0.00046	0.00049	--	--
5.9 wt.% Enrichment	-0.00058	0.00071	--	--
6.3 wt.% Enrichment	-0.00045	0.00052	--	--
6.7 wt.% Enrichment	NA	NA	NA	NA
7.2 wt.% Enrichment	-0.00031	0.00036	--	--
7.9 wt.% Enrichment	-0.00011	0.00017	--	--
9.4 wt.% Enrichment	0.00005	0.00013	--	--
9.9 wt.% Enrichment	0.00005	0.00005	--	--
Oxygen to Uranium Ratio	0.00007	-0.00017	--	--
UO <sub>2</sub> Density	Correlated Parameter (see Section 2.1.6)			
UO <sub>2</sub> Impurity	0.00024	-0.00068	--	--
Buffer Density	-0.00001	neg	neg	neg
Buffer Impurity	0.00009	-0.00012	--	--
IPyC Density	neg	neg	neg	neg
IPyC Impurity	0.00011	-0.00016	--	--
SiC Density	NA	neg	NA	neg
SiC Impurity	0.00010	0.00010	--	--
OPyC Density	neg	-0.00001	neg	neg
OPyC Impurity	0.00005	0.00010	--	--
Overcoat Density	-0.00002	neg	neg	neg
Overcoat Composition	NA	NA	NA	NA
Overcoat Impurity	0.00044	-0.00070	--	--
Compact Density	-0.00001	neg	neg	neg
Compact Impurity	0.00010	-0.00066	--	--
Compact Free U Content	NA	neg	--	--

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.84 (cont'd.). Total Experimental Uncertainty (Case 3).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$
Sleeve Density	-0.00008	0.00004	neg	neg
Sleeve Impurity	0.00010	-0.00048	--	--
BP Absorber Density	0.00010	-0.00012	neg	neg
BP Absorber Content, 2.0 wt.%	0.00057	-0.00049	0.00003	-0.00003
BP Absorber Content, 2.5 wt.%	0.00036	-0.00035	0.00003	-0.00003
BP Absorber Impurity	NA	0.00021	--	--
BP Isotopic Abundance of $^{10}\text{B}$	0.00126	-0.00062	--	--
Graphite Disk Density	neg	neg	neg	neg
Graphite Disk Impurity	0.00010	-0.00010	--	--
CR Absorber Density	neg	neg	neg	neg
CR Absorber Content	0.00002	-0.00002	neg	neg
CR Absorber Impurity	NA	0.00005	--	--
CR Isotopic Abundance of $^{10}\text{B}$	0.00013	0.00009	--	--
CR Clad Density	neg	-0.00003	neg	-0.00001
CR Clad Composition	0.00010	-0.00012	--	--
CR Clad Impurity	NA	0.00005	--	--
Instrumentation Composition	See Section 2.1.2.6			
IG-110 Density in Blocks	-0.00073	0.00063	-0.00010	0.00008
IG-110 Impurity in Blocks	0.00462	-0.00601	--	--
PGX Density	-0.00009	0.00004	-0.00003	0.00001
PGX Impurity	0.00314	-0.00434	--	--
Dummy Block Density	0.00002	-0.00007	neg	-0.00004
Dummy Block Impurity	0.00460	-0.00264	--	--
Dummy Block Type	NA	-0.00014	NA	-0.00008
Helium Coolant Density	neg	neg	--	--
Helium Coolant Impurity	NA	neg	--	--
Room Return	neg	neg	neg	Neg
TRISO Particle Placement	0.00051	0.00051	neg	neg
Block Stack Alignment	NA	NA	NA	NA
MCNP Random Number Seed	--	--	0.00007	0.00007
Uranium Fuel Mass (Sec. 2.1.6)	-0.00077	0.00071	-0.00004	0.00003
Uncertainty of Components	0.00776	0.00836	0.00018	0.00019
<b>Total Evaluation Uncertainty</b>	<b>0.00777</b>	<b>0.00836</b>		

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.85. Total Experimental Uncertainty (Case 4).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$
Temperature	0.00013	-0.00013	--	--
Control Rod Positions	-0.00009	0.00006	-0.00007	0.00005
Measured Value of $k_{\text{eff}}$	neg	neg	neg	neg
Kernel Diameter	Correlated Parameter (see Section 2.1.6)			
Buffer Diameter	neg	-0.00004	neg	neg
IPyC Diameter	neg	neg	neg	neg
SiC Diameter	0.00002	-0.00007	neg	neg
OPyC Diameter	0.00001	-0.00003	neg	neg
Overcoat Diameter	NA	NA	NA	NA
Compact Inner Diameter	neg	-0.00002	neg	neg
Compact Outer Diameter	-0.00004	0.00003	neg	neg
Compact Height	-0.00006	0.00004	neg	neg
Compact Packing Fraction	Correlated Parameter (see Section 2.1.6)			
Sleeve Inner Diameter	0.00003	-0.00003	neg	neg
Sleeve Outer Diameter	-0.00005	0.00005	neg	neg
Sleeve Height	-0.00002	0.00001	neg	neg
BP Diameter	0.00017	-0.00017	0.00001	-0.00001
BP Stack Height	0.00007	-0.00013	0.00001	-0.00002
BP Hole Diameter	0.00001	-0.00002	neg	neg
Graphite Disk Diameter	neg	neg	neg	neg
Disk Stack Height	neg	0.00002	neg	neg
CR Absorber Inner Diameter	neg	neg	neg	neg
CR Absorber Outer Diameter	neg	neg	neg	neg
CR Absorber Height	0.00001	-0.00001	neg	neg
CR Clad Inner Diameter	neg	neg	neg	neg
CR Clad Outer Diameter	-0.00002	0.00002	neg	neg
CR Clad Height	-0.00002	-0.00002	neg	neg
CR Spine Diameter	neg	neg	neg	neg
Instrumentation Dimensions	-0.00091	0.00091	--	--
Block Flat-to-Flat Distance	-0.00006	0.00004	-0.00001	0.00001
Graphite Block Height	neg	neg	neg	neg
Dowel/Socket Dimensions	NA	NA	NA	NA
Fuel Channel Diameter	0.00006	-0.00007	neg	neg
Reflector Channel Diameter	neg	neg	neg	neg
Channel Pitch	-0.00004	0.00003	neg	neg

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.85 (cont'd.). Total Experimental Uncertainty (Case 4).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$
Handling Socket Dimensions	NA	NA	NA	NA
Column Pitch	0.00013	-0.00019	0.00005	-0.00007
CR Channel Diameter	0.00001	-0.00001	neg	neg
CR Channel Pitch	neg	neg	neg	neg
Permanent Reflector Diameter	-0.00054	0.00014	--	--
Dummy Block Dimensions	See Sections 2.1.2.7 and 2.1.3.9			
3.4 wt.% Enrichment	NA	NA	NA	NA
3.9 wt.% Enrichment	-0.00053	0.00059	--	--
4.3 wt.% Enrichment	-0.00064	0.00079	--	--
4.8 wt.% Enrichment	-0.00030	0.00036	--	--
5.2 wt.% Enrichment	-0.00045	0.00051	--	--
5.9 wt.% Enrichment	-0.00048	0.00041	--	--
6.3 wt.% Enrichment	-0.00063	0.00066	--	--
6.7 wt.% Enrichment	NA	NA	NA	NA
7.2 wt.% Enrichment	-0.00034	0.00033	--	--
7.9 wt.% Enrichment	-0.00037	0.00044	--	--
9.4 wt.% Enrichment	-0.00014	0.00018	--	--
9.9 wt.% Enrichment	0.00006	0.00011	--	--
Oxygen to Uranium Ratio	0.00011	-0.00012	--	--
UO <sub>2</sub> Density	Correlated Parameter (see Section 2.1.6)			
UO <sub>2</sub> Impurity	0.00026	-0.00063	--	--
Buffer Density	neg	neg	neg	neg
Buffer Impurity	0.00010	-0.00010	--	--
IPyC Density	neg	neg	neg	neg
IPyC Impurity	0.00010	0.00010	--	--
SiC Density	NA	neg	NA	neg
SiC Impurity	neg	-0.00011	--	--
OPyC Density	neg	neg	neg	neg
OPyC Impurity	-0.00012	0.00010	--	--
Overcoat Density	-0.00003	0.00002	neg	neg
Overcoat Composition	NA	NA	NA	NA
Overcoat Impurity	0.00025	-0.00076	--	--
Compact Density	-0.00001	0.00001	neg	neg
Compact Impurity	0.00010	-0.00060	--	--
Compact Free U Content	NA	neg	--	--

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.85 (cont'd.). Total Experimental Uncertainty (Case 4).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$
Sleeve Density	-0.00012	0.00006	neg	neg
Sleeve Impurity	0.00009	-0.00033	--	--
BP Absorber Density	0.00009	-0.00012	neg	neg
BP Absorber Content, 2.0 wt.%	0.00055	-0.00050	0.00003	-0.00003
BP Absorber Content, 2.5 wt.%	0.00041	-0.00036	0.00003	-0.00003
BP Absorber Impurity	NA	0.00018	--	--
BP Isotopic Abundance of $^{10}\text{B}$	0.00127	-0.00080	--	--
Graphite Disk Density	-0.00001	neg	neg	neg
Graphite Disk Impurity	-0.00010	0.00010	--	--
CR Absorber Density	neg	-0.00001	neg	neg
CR Absorber Content	0.00003	-0.00003	neg	neg
CR Absorber Impurity	NA	0.00005	--	--
CR Isotopic Abundance of $^{10}\text{B}$	0.00010	-0.00010	--	--
CR Clad Density	-0.00005	neg	-0.00002	neg
CR Clad Composition	0.00010	0.00010	--	--
CR Clad Impurity	NA	neg	--	--
Instrumentation Composition	See Section 2.1.2.6			
IG-110 Density in Blocks	-0.00083	0.00080	-0.00011	0.00011
IG-110 Impurity in Blocks	0.00420	-0.00543	--	--
PGX Density	-0.00007	0.00005	-0.00002	0.00001
PGX Impurity	0.00171	-0.00247	--	--
Dummy Block Density	0.00002	-0.00007	0.00001	-0.00004
Dummy Block Impurity	0.00599	-0.00335	--	--
Dummy Block Type	NA	-0.00064	NA	-0.00035
Helium Coolant Density	-0.00001	neg	--	--
Helium Coolant Impurity	NA	neg	--	--
Room Return	neg	neg	neg	neg
TRISO Particle Placement	0.00053	0.00053	neg	neg
Block Stack Alignment	NA	NA	NA	NA
MCNP Random Number Seed	--	--	0.00012	0.00012
Uranium Fuel Mass (Sec. 2.1.6)	-0.00075	0.00072	-0.00004	0.00004
Uncertainty of Components	0.00796	0.00739	0.00020	0.00040
<b>Total Evaluation Uncertainty</b>	<b>0.00796</b>	<b>0.00740</b>		

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.86. Total Experimental Uncertainty (Case 5).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$
Temperature	0.00013	-0.00013	--	--
Control Rod Positions	-0.00014	0.00016	-0.00011	0.00012
Measured Value of $k_{\text{eff}}$	neg	neg	neg	neg
Kernel Diameter	Correlated Parameter (see Section 2.1.6)			
Buffer Diameter	0.00002	-0.00002	neg	neg
IPyC Diameter	neg	neg	neg	neg
SiC Diameter	0.00006	-0.00006	neg	neg
OPyC Diameter	neg	neg	neg	neg
Overcoat Diameter	NA	NA	NA	NA
Compact Inner Diameter	0.00001	-0.00001	neg	neg
Compact Outer Diameter	-0.00003	0.00003	neg	neg
Compact Height	-0.00006	0.00004	neg	neg
Compact Packing Fraction	Correlated Parameter (see Section 2.1.6)			
Sleeve Inner Diameter	0.00003	-0.00004	neg	neg
Sleeve Outer Diameter	-0.00005	0.00005	neg	neg
Sleeve Height	-0.00002	0.00001	neg	neg
BP Diameter	0.00019	-0.00018	0.00001	-0.00001
BP Stack Height	0.00008	-0.00009	0.00001	-0.00001
BP Hole Diameter	0.00002	-0.00001	neg	neg
Graphite Disk Diameter	neg	neg	neg	neg
Disk Stack Height	0.00002	0.00003	neg	neg
CR Absorber Inner Diameter	neg	neg	neg	neg
CR Absorber Outer Diameter	neg	neg	neg	neg
CR Absorber Height	0.00001	-0.00002	0.00001	-0.00001
CR Clad Inner Diameter	neg	neg	neg	neg
CR Clad Outer Diameter	-0.00001	0.00001	neg	neg
CR Clad Height	-0.00003	-0.00004	-0.00001	-0.00001
CR Spine Diameter	neg	neg	neg	neg
Instrumentation Dimensions	-0.00084	0.00084	--	--
Block Flat-to-Flat Distance	-0.00006	0.00004	-0.00001	0.00001
Graphite Block Height	neg	neg	neg	neg
Dowel/Socket Dimensions	NA	NA	NA	NA
Fuel Channel Diameter	0.00006	-0.00006	neg	neg
Reflector Channel Diameter	neg	neg	neg	neg
Channel Pitch	-0.00003	0.00003	neg	neg

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.86 (cont'd.). Total Experimental Uncertainty (Case 5).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$	$-\Delta k_{\text{eff}}(1\sigma)$	$+\Delta k_{\text{eff}}(1\sigma)$
Handling Socket Dimensions	NA	NA	NA	NA
Column Pitch	0.00001	-0.00001	neg	neg
CR Channel Diameter	neg	neg	neg	neg
CR Channel Pitch	neg	neg	neg	neg
Permanent Reflector Diameter	-0.00083	0.00024	--	--
Dummy Block Dimensions	See Sections 2.1.2.7 and 2.1.3.9			
3.4 wt.% Enrichment	-0.00054	0.00042	--	--
3.9 wt.% Enrichment	-0.00079	0.00079	--	--
4.3 wt.% Enrichment	-0.00133	0.00133	--	--
4.8 wt.% Enrichment	-0.00052	0.00051	--	--
5.2 wt.% Enrichment	-0.00039	0.00037	--	--
5.9 wt.% Enrichment	-0.00052	0.00047	--	--
6.3 wt.% Enrichment	-0.00030	0.00026	--	--
6.7 wt.% Enrichment	0.00006	0.00005	--	--
7.2 wt.% Enrichment	-0.00012	0.00011	--	--
7.9 wt.% Enrichment	-0.00008	0.00006	--	--
9.4 wt.% Enrichment	0.00006	0.00005	--	--
9.9 wt.% Enrichment	0.00006	0.00007	--	--
Oxygen to Uranium Ratio	0.00009	-0.00012	--	--
UO <sub>2</sub> Density	Correlated Parameter (see Section 2.1.6)			
UO <sub>2</sub> Impurity	0.00047	-0.00073	--	--
Buffer Density	neg	neg	neg	neg
Buffer Impurity	0.00009	-0.00012	--	--
IPyC Density	neg	neg	neg	neg
IPyC Impurity	0.00013	0.00009	--	--
SiC Density	NA	neg	NA	neg
SiC Impurity	neg	-0.00016	--	--
OPyC Density	neg	neg	neg	neg
OPyC Impurity	0.00020	-0.00023	--	--
Overcoat Density	-0.00001	0.00001	neg	neg
Overcoat Composition	NA	NA	NA	NA
Overcoat Impurity	0.00032	-0.00069	--	--
Compact Density	neg	0.00001	neg	neg
Compact Impurity	0.00009	-0.00065	--	--
Compact Free U Content	NA	neg	--	--

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 2.86 (cont'd.). Total Experimental Uncertainty (Case 5).

Varied Parameter	Systematic Uncertainty		Random Uncertainty	
	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$	$-\Delta k_{\text{eff}} (1\sigma)$	$+\Delta k_{\text{eff}} (1\sigma)$
Sleeve Density	-0.00005	0.00004	neg	neg
Sleeve Impurity	0.00031	-0.00031	--	--
BP Absorber Density	0.00009	-0.00011	neg	neg
BP Absorber Content, 2.0 wt.%	0.00075	-0.00066	0.00004	-0.00003
BP Absorber Content, 2.5 wt.%	0.00029	-0.00027	0.00002	-0.00002
BP Absorber Impurity	NA	0.00024	--	--
BP Isotopic Abundance of $^{10}\text{B}$	0.00136	-0.00077	--	--
Graphite Disk Density	neg	neg	neg	neg
Graphite Disk Impurity	neg	0.00009	--	--
CR Absorber Density	neg	-0.00001	neg	neg
CR Absorber Content	0.00002	-0.00003	neg	neg
CR Absorber Impurity	NA	0.00004	--	--
CR Isotopic Abundance of $^{10}\text{B}$	0.00009	0.00021	--	--
CR Clad Density	neg	0.00002	neg	neg
CR Clad Composition	0.00009	0.00009	--	--
CR Clad Impurity	NA	neg	--	--
Instrumentation Composition	See Section 2.1.2.6			
IG-110 Density in Blocks	-0.00074	0.00068	-0.00010	0.00009
IG-110 Impurity in Blocks	0.00490	-0.00584	--	--
PGX Density	-0.00009	0.00006	-0.00003	0.00002
PGX Impurity	0.00269	-0.00345	--	--
Dummy Block Density	0.00002	0.00002	-0.00002	-0.00001
Dummy Block Impurity	0.00217	-0.00124	--	--
Dummy Block Type	NA	0.00017	NA	0.00013
Helium Coolant Density	neg	neg	--	--
Helium Coolant Impurity	NA	neg	--	--
Room Return	neg	neg	neg	neg
TRISO Particle Placement	0.00068	0.00068	neg	neg
Block Stack Alignment	NA	NA	NA	NA
MCNP Random Number Seed	--	--	0.00017	0.00017
Uranium Fuel Mass (Sec. 2.1.6)	-0.00075	0.00073	-0.00003	0.00003
Uncertainty of Components	0.00675	0.00749	0.00024	0.00027
<b>Total Evaluation Uncertainty</b>	<b>0.00675</b>	<b>0.00750</b>		



## **2.2 Evaluation of Buckling and Extrapolation Length Data**

Buckling and extrapolation length measurements were not made.

## **2.3 Evaluation of Spectral Characteristics Data**

Spectral characteristics measurements were not made.

## **2.4 Evaluation of Reactivity Effects Data**

Evaluation of the excess reactivity measurements of the HTTR annular core configurations is provided in Section 2.4.1 of [HTTR-GCR-RESR-001](#).

## **2.5 Evaluation of Reactivity Coefficient Data**

Reactivity coefficient measurements were not made.

## **2.6 Evaluation of Kinetics Measurements Data**

Kinetics measurements were not made.

## **2.7 Evaluation of Reaction-Rate Distributions**

The benchmark model for the critical configuration analyzed in Section 2.1 and described in Section 3.1 was utilized in the analysis of the reactor physics experiments in Section 1.7.

Monte Carlo n-Particle (MCNP) version 5.1.40 was utilized to predict the biases and uncertainties associated with the experimental results for HTTR critical configurations in this evaluation. MCNP is a general-purpose, continuous-energy, generalized-geometry, time-dependent, coupled n-particle, Monte Carlo transport code. The Evaluated Neutron Data File library, ENDF/B-VII.0, was utilized in analysis of the benchmark model biases and uncertainties.

It should be noted that the neutron flux could not be measured directly in the core, but the fission chambers (FCs), containing  $^{235}\text{U}$ , were used to indirectly measure the flux as fission reaction rates. A fixed FC in one of the instrumentation columns was used to normalize the reaction-rate measurements from the FC that was moved to various positions in another column. This was to account for variation in the flux due to movement effects of the detector and its respective components.

### **2.7.1 Axial Reaction Rate Distribution**

The axial fission neutron reaction-rate distribution in Figures 1.5 for the two annular 24-fuel-column cores were digitized and renormalized to allow for further comparative analysis with computational results. The digitization of the charts was performed by Chris White at the Idaho National Laboratory using Marisoft Digitizer.<sup>a</sup> The chart is imported into the program and bound within a grid system; each individual data point is then marked and exported as numerical data. Table 2.87 and Figures 2.8 and 2.9 represent the digitized data. A comprehensive analysis of the axial neutron reaction-rate distribution in the instrumentation columns of the fully-loaded, 30-fuel-column core has already been performed

---

<sup>a</sup> M. Mitchell, Marisoft Digitizer Application Version 3.3, <http://digitizer.sourceforge.net/>, © 1997.

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

(Section 2.7.1 of [HTTR-GCR-RESR-001](#)). The uncertainty in the reaction-rate measurements of the fully-loaded core were used to generate an estimate of the uncertainties in the 24-fuel-column core measurements by fitting the data to a trend, as shown in Figure 2.10. The uncertainty in the normalized reaction rates is proportional to the magnitude of the ratio. There is less uncertainty in values near the peak of the neutron flux and significantly more uncertainty for lower fluxes near the edge of the core. A log trend fit is obtained to approximate the uncertainty as a function of normalized reaction rate. The uncertainties in the 24-fuel-column core reaction rates were then estimated using this trend and provided in Table 2.87.

Table 2.87. Axial Neutron Fission Reaction-Rate Distribution Data for the Annular 24-Fuel-Column Core Configurations.

Data Point	Configuration 3 <sup>(a)</sup>					Configuration 4 <sup>(a)</sup>				
	Normalized Reaction Rate	$\pm$	$1\sigma$	$1\sigma$ (%)	Height (cm) <sup>(b)</sup>	Normalized Reaction Rate	$\pm$	$1\sigma$	$1\sigma$ (%)	Height (cm) <sup>(b)</sup>
1	0.6946	$\pm$	0.0199	2.87	18.89	0.7030	$\pm$	0.0199	2.83	18.79
2	0.7304	$\pm$	0.0198	2.70	27.86	0.7383	$\pm$	0.0197	2.67	28.40
3	0.9555	$\pm$	0.0173	1.81	86.07	0.9523	$\pm$	0.0174	1.83	86.36
4	1.0000	$\pm$	0.0166	1.66	130.96	1.0000	$\pm$	0.0166	1.66	115.79
5	0.9854	$\pm$	0.0169	1.71	137.15	0.9749	$\pm$	0.0170	1.75	137.45
6	0.9750	$\pm$	0.0170	1.75	143.96	0.9562	$\pm$	0.0173	1.81	144.57
7	0.6735	$\pm$	0.0200	2.97	202.48	0.7915	$\pm$	0.0193	2.44	202.72
8	0.2818	$\pm$	0.0165	5.86	260.99	0.5582	$\pm$	0.0201	3.59	260.85
9	0.1041	$\pm$	0.0095	9.16	318.58	0.3312	$\pm$	0.0176	5.32	318.37

(a) The 24-fuel-column core reaction-rate data are from the top and middle charts, respectively, in Figure 1.6.

(b) The height is in reference to the position relative to the bottom of the fifth layer of fuel.




Figure 2.8. Axial Neutron Reaction-Rate Distribution for the Annular 24-Fuel-Column Core (Configuration 3).




Figure 2.9. Axial Neutron Reaction-Rate Distribution for the Annular 24-Fuel-Column Core (Configuration 4).




Figure 2.10. Uncertainty Trend Estimated with HTTR Fully-Loaded-Core Analysis.

The axial neutron fission reaction rate in the instrumentation columns were calculated by taking the benchmark model of the 24-fuel-column cores (configurations 3 and 4) in Section 3.1 and superimposing a flux tally over each of the instrumentation column positions: E05, E13, and E21. The flux was computed for 6.15-cm radius discs with a thickness of 1 cm located at the center of one instrumentation channel in each instrumentation column (see Figure 2.11). A total of 522 cm, representing the total height of the core fuel and reflector blocks, was modeled. The (x, y) coordinates used for columns E05, E13, and E21, are (114.6005, 72.4), (5.4, -135.447), and (-120, 63.04693), respectively, where the origin is located at the radial center of the core.

The F4 flux tally is used in MCNP, which determines the flux across a cell volume by tabulating the average track length of the neutrons.<sup>a</sup> The tally is then modified by a tally multiplier card, Fm, that accounts for the total fission cross section of <sup>235</sup>U, the fissile material in the fission chambers, to obtain the neutron reaction-rate in each instrumentation column.


The calculated neutron fission reaction rates are obtained by taking the variance-weighted average of results obtained using six variations of the input deck (Appendix A.1) with different random number seeds and tallies of the neutron reaction rate (Appendix A.3). This approach was used to reduce the statistical uncertainty in the neutron flux tallies because the relative error values obtained can underpredict the true uncertainty in the calculated neutron flux.<sup>b</sup> Therefore, the final calculated values are obtained from a total of 18 reaction-rate tallies (6 input decks with 3 instrumentation columns each).

<sup>a</sup> X-5 Monte Carlo Team, "MCNP – A General Monte Carlo N-Particle Transport Code, Version 5, Volume II: User's Guide," LA-CP-03-0245 (April 24, 2003; revised October 2, 2005).

<sup>b</sup> F. B. Brown, "A Review of Best Practices for Monte Carlo Criticality Calculations," *Proc. NCSD 2009*, Richland, WA, September 13-17 (2009).

The average of the neutron reaction rate in each position is taken and normalized to represent the calculated axial neutron reaction-rate profile.

$$\phi(z)_{normalized} = \frac{\phi(z)}{\phi_{maximum}},$$



Dimensions in mm

09-GA50001-103

Fig 2.11. Placement of Axial Flux Tally in the Instrumentation Column.

## **2.8    Evaluation of Power Distribution Data**

Power distribution measurements were not made.

## **2.9    Evaluation of Isotopic Measurements**

Isotopic measurements were not made.

## **2.10   Evaluation of Other Miscellaneous Types of Measurements**

Other miscellaneous types of measurements were not made.

### 3.0 BENCHMARK SPECIFICATIONS

#### 3.1 Benchmark-Model Specifications for Critical and / or Subcritical Measurements

Whereas insufficient information is publicly available, a finely-detailed benchmark model could not be established. A benchmark of the HTTR was prepared and analyzed with as much detail as feasible. The simplification bias for this model could also not be fully determined. However, the uncertainties in the benchmark model are believed to be of sufficient magnitude to encompass any biases incurred due to the simplification process of the benchmark model and a bias for the removal of the core instrumentation has been estimated. It is currently difficult to obtain the necessary information to improve the confidence in the benchmark model; the necessary data is proprietary and its release is being restricted, because the benchmark configuration of the HTTR core is the same that is currently in operation. Once this information is made available, the HTTR benchmark can be adjusted as appropriate.

Models for all five configurations of the annular HTTR core are provided. The five configurations, or cases, in this benchmark analysis use four core layouts, with the third core layout implementing two different control rod positionings. Configuration 1 has 19 fuel columns. Configuration 2 has 21 fuel columns. Configurations 3 and 4 have 24 fuel columns. Configuration 5 has 27 fuel columns. Analysis of the fully-loaded, 30-fuel-column, core can be found in [HTTR-GCR-RESR-001](#).

##### 3.1.1 Description of the Benchmark Model Simplifications

Significant simplifications were incurred to develop a benchmark model of the HTTR because of a lack of information publicly available to determine dimensions and compositions. Simplifications will be discussed where applicable in the descriptions of the dimension and material properties of the model.

As stated previously, biases of the model were not assessed but will be addressed as additional HTTR information becomes available. Biases that have been partially investigated are listed in Section 3.1.1.1.

The fuel handling positions, dowels, and sockets were not included in the model due to insufficient data specifications, but were accounted for with a void fraction of 0.5 % reduction in graphite density (based upon volume calculations using dimensions provided in Figure 1.52 of [HTTR-GCR-RESR-001](#)). The burnable poison insertion holes were placed on the same pitch as the fuel channels to simplify the model.

It is apparent from a comparison of Figures 1.65 and 1.67 of [HTTR-GCR-RESR-001](#) that the depth to which the control rod, reserve shutdown system, and instrumentation holes are drilled varies. A depth of 1060 mm above the bottom of the core was selected for all positions to simplify the model. No bias was assessed.

Insufficient information was available to model the bottom-most reflector block according to actual design; therefore it was modeled with the same design as the two top reflector blocks and the other bottom reflector block. The top and bottom of each coolant channel is expected to taper from the 21-mm diameter to the 41-mm diameter of the fuel assemblies, but information was unavailable to describe the taper in the model. Therefore channels in the reflector blocks were modeled with 21-mm diameters.

Individual sections of the dodecagon-block-shaped permanent reflector were not modeled due to insufficient information. It was modeled as a cylindrical region surrounding the core columns. A bias could not be assessed.

Insufficient information was available to model the shielding blocks surrounding the core and shielding plugs in the core. Therefore, they were not included in the benchmark model. It is assumed that all neutrons reaching the core boundaries are lost and not scattered back by the shielding material. A conservative estimate of room-return effects demonstrated a negligible change in  $k_{\text{eff}}$ .

In the materials section, impurity contents in the materials are based upon natural boron equivalency. In the model, however, only the  $^{10}\text{B}$  component is included, as the effect of the  $^{11}\text{B}$  content would be insignificant.

The density is the same ( $1.80 \text{ g/cm}^3$ ) for both types of burnable poison pellets. The boron content in the pellets is based on the reported weight percents instead of the atomic percents.

Partially-withdrawn control rod positions represent the average height of the values reported in Table 1.1, which are reported in Table 1.2 except for configuration 4. The average height for the partially-withdrawn rods in configuration 4 is taken to be 1592 mm. Fully-withdrawn rod positions are 4050 mm for all rods except those in the R2 positions; their maximum withdrawal height is 3325 mm.

Too much information was available to specify parameters for the TRISO particle fuel. Because the fuel mass of an individual rod would most probably be the most accurate measured parameter, it was preserved in the benchmark model with some variation to other parameters as necessary. The TRISO kernel diameter is maintained at the nominal value of  $600 \mu\text{m}$  and the density of the fuel is  $10.39 \text{ g/cm}^3$ , which is within approximately 95% of the theoretical density of  $\text{UO}_2$ . The number of TRISO particles in a given compact was reduced from 13,000 to 12,987, with a packing fraction of 30 %, in order to conserve a nominal fuel mass per rod of 188.58 g.

#### 3.1.1.1 Assessed Biases

Although some biases have been partially investigated, there is incomplete information regarding the HTTR to properly address simplification biases in order to adjust the benchmark  $k_{\text{eff}}$ . As stated previously, a conservative estimate of potential room-return effects provided negligible results. As shown in Section 2.1.3.2 in Table 2.52, the effect of neglecting the free uranium content of the fuel compacts was negligible. Finally, the effect of modeling the helium coolant as void material was also negligible (as shown in Section 2.1.3.10, Table 2.77). The reported literature bias for air content in the graphite could not be verified (Section 2.1.3.7).

Previous efforts of the Japanese in analyzing the 19-fuel-column core (Case 1) obtained an analytical excess reactivity of 2.7 %  $\Delta k/k$ , with an estimated Monte Carlo calculation overestimate of 1.2 %  $\Delta k/k$ .<sup>a</sup> Additional information would be necessary to completely verify published results

An approximate bias for the removal of reactor instrumentation from the three instrumentation columns in the core was calculated, as discussed in Section 2.1.2.6. Calculated biases with uncertainties are shown in Table 3.1.

---

<sup>a</sup> Fujimoto, N., Nakano, M., Takeuchi, M., Fujisaki, S., and Yamashita, K., "Start-Up Core Physics Tests of High Temperature Engineering Test Reactor (HTTR), (II): First Criticality by an Annular Form Fuel Loading and Its Criticality Prediction Method," *J. Atomic Energy Society Japan*, **42**(5), 458-464 (2000).



Table 3.1. Estimated Bias for the Removal  
of Instrumentation Components.

Case	$\Delta k$	$\pm$	$\sigma_{\Delta k}$
1	0.00483	$\pm$	0.00139
2	0.00403	$\pm$	0.00116
3	0.00348	$\pm$	0.00100
4	0.00315	$\pm$	0.00091
5	0.00291	$\pm$	0.00084

### 3.1.2 Dimensions

#### 3.1.2.1 Prismatic Pin-in-Block Fuel

##### TRISO Particles

The basic ingredient for HTTR fuel is the TRISO particle. A  $\text{UO}_2$  kernel is surrounded by four coatings: a low density porous pyrolytic carbon (PyC) buffer layer, a high density inner isotropic PyC layer, a SiC layer, and a final outer PyC layer. A resinated graphite overcoat is then deposited around each TRISO particle. Figure 3.1 depicts the TRISO layers and their respective dimensions.




Figure 3.1. TRISO-Coated Fuel Particle.

### **Compacts**

All fourteen fuel compacts in a single fuel pin are modeled as a single unit filled with the TRISO lattice. The stacked compacts have an inner diameter of 1 cm, an outer diameter of 2.6 cm, and an overall height of 54.6 cm.

A horizontal cross section of the compacts is shown in Figure 3.2. In the benchmark model, 12,987 TRISO particles are randomly distributed throughout the compact matrix in a single compact. For a stack of 14 compacts, as modeled in this benchmark, the total number of TRISO particles is 181,818.

A key parameter is that the total fuel mass of a single fuel rod (14 stacked compacts) is approximately 188.58 g.

While the benchmark model retains randomness in distribution, many computer codes cannot properly model such configurations. It is up to the user to determine which method is most appropriate while accounting for its impact on the reactivity of the model. Example means for analyzing this model are provided in Section 4.1. The difference in methods for accurately modeling random TRISO particles in a full-core reactor has been discussed in Section 2.1.4.2.




Figure 3.2. Fuel Compact Filled with Randomly Distributed TRISO Particles (Particles Not Shown).

**Fuel Element**

A description of the HTTR fuel element is modeled (Figure 3.3).





Figure 3.3. Benchmark HTTR Fuel Element.

### 3.1.2.2 Burnable Poisons

The burnable poison pellets and graphite disks were modeled as individual stacks contained within a pin position in the fuel blocks (Figure 3.4). Each fuel block contained two BP pins and one empty pin position.



Drawing not to scale  
Dimensions in mm

Figure 3.4. Burnable Poison Pin (Left) and Empty Pin Position (Right).

08-GA50017-166-2

### 3.1.2.3 Fuel Blocks

The HTTR contains two types of regular hexagonal fuel blocks: 33-pin (Zones 1 and 2) and 31-pin (Zones 3 and 4). Diagrams of each fuel block design implemented in the benchmark model are shown in Figures 3.5 and 3.6, respectively. The pitch for all positions is 51.5 mm.






Figure 3.6. Fuel Block for 31-Pin Fuel Assembly. Dxx represents the diameter in xx (mm).

### 3.1.2.4 Dummy Blocks

The HTTR contains regular hexagonal dummy blocks. A diagram of the dummy block design implemented in the benchmark model is shown in Figure 3.7.





Figure 3.7. Dummy Block. Dxx represents the diameter in xx (mm).

### 3.1.2.5 Control Rod System

#### **Control Rods**

A diagram of a control rod section is shown in Figure 3.8. The absorber compacts are modeled as a single unit. Detailed dimensions regarding the cladding infrastructure for each section was unavailable, and the clad is therefore modeled without detail. A single control rod is comprised of ten sections (Figure 3.9) with a total height of 3.1 m.

The control rods are divided up into four sets: center position (C), ring 1 (R1), ring 2 (R2), and ring 3 (R3). The center position contains two control rods. The other rings are comprised of six, six, and three positions, containing a total of twelve, twelve, and six control rods, respectively. Control rods in each set are synchronously moved.








Figure 3.9. Control Rod Comprised of Ten Sections.

**Control Rod Columns**

Individual control rod blocks were not modeled. A single control rod column was modeled with three holes to accommodate two control rods and an empty position (for the reserved shutdown system). A diagram of a generic control column (without control rods) is shown in Figure 3.10. The holes in the control rod and instrumentation columns are equidistant from each other, with an angle of  $120^\circ$ .




Figure 3.10. Control Rod Column. Dxx represents the diameter in xx (mm).

### 3.1.2.6 Instrumentation

#### Instrumentation Components

Instrumentation was not included in the benchmark model of the HTTR. An approximate bias with uncertainty was determined applied to the benchmark model (see Sections 2.1.2.6 and 3.1.1.1).

#### Instrumentation Columns

Instrumentation columns are modeled as a single unit without blocks, similar to the control rod columns. However, all three positions are empty (Figure 3.11).





Figure 3.11. Instrumentation Column. Dxx represents the diameter in xx (mm).

### 3.1.2.7 Replaceable Reflector Columns

The replaceable reflector columns are modeled as a solid unit and not as individual blocks, similar to the control rod and instrumentation columns but without any channels (Figure 3.12).



Dimensions in mm

08-GA50017-151-11

Figure 3.12. Replaceable Reflector Column.

### 3.1.2.8 Replaceable Reflector Blocks in Fuel Columns

The replaceable reflector blocks, located at the top and the bottom fuel columns, are shown in Figures 3.13 and 3.14, for the 33-pin and 31-pin fuel assemblies, respectively. The replaceable reflector blocks have the same regular hexagonal shape and pitch as described for the fuel blocks.






Figure 3.13. Replaceable Reflector Block for 33-Pin Fuel Assembly.  
Dxx represents the diameter in xx (mm).



Dimensions in mm


08-GA50017-151-10

Figure 3.14. Replaceable Reflector Block for 31-Pin Fuel Assembly.

Dxx represents the diameter in xx (mm).

## 3.1.2.9 Fuel Columns

The fuel columns are separated into four zones (as shown in Figure 1.46 of [HTTR-GCR-RESR-001](#)). Each zone has a specified pattern of uranium enrichment. Each column contains two top replaceable reflector blocks (Figure 3.13 for Zones 1 and 2 or Figure 3.14 for Zones 3 and 4), five fuel blocks (Figure 3.5 for Zones 1 and 2 and Figure 3.6 for Zones 3 and 4), and two bottom replaceable reflector blocks (Figure 3.13 for Zones 1 and 2 or Figure 3.14 for Zones 3 and 4). The second and third fuel blocks from the top contain burnable poison pellets that are more enriched than the pellets in the other three positions. Figure 3.15 shows the enrichment of the uranium (wt.%) in the TRISO fuel (upper left) and the natural boron content (wt.%) in the burnable pellets (lower right).



08-GA50017-167-1

Figure 3.15. HTTR Fuel Zones.

### 3.1.2.10 Dummy Fuel Columns

The dummy fuel columns are similar to the fuel columns shown in Figure 3.15 except that the fueled blocks are replaced with dummy fuel blocks. Each column therefore contains two top replaceable reflector blocks (Figures 3.13 or 3.14 if replacing Zones 1 and 2 or Zones 3 and 4, respectively), five dummy blocks (Figure 3.7), and two bottom replaceable reflector blocks (Figures 3.13 or 3.14). A dummy fuel column is shown in Figure 3.16.



Figure 3.16. HTTR Dummy Fuel Zone.




### 3.1.2.11 Reactor Core Configuration

Figures 3.17 through 3.20 are included to provide an understanding of the final configuration of the reactor. All of the annular core configurations have the same configuration and orientation as the fully-loaded core, but with dummy fuel columns in place of some of the fuel columns, as shown in Figures 3.21 through 3.24.

The HTTR fully-loaded, 30-fuel-column, core configuration ([HTTR-GCR-RESR-001](#)) is shown in Figures 3.17, 3.18, 3.19. The first figure identifies the positions in the core for a given column type. The second figure provides the orientation of each column within its respective position in the core. The third figure shows the column identification number for each position in the core. Figure 3.20 shows a basic cross section of the HTTR fully-loaded core generated in MCNP.

The five configurations in this benchmark analysis use four core layouts, with the third core layout implementing two different control rod positions. Configuration 1 (Figure 3.21) has 19 fuel columns and 11 dummy fuel columns. Configuration 2 (Figure 3.22) has 21 fuel columns and 9 dummy fuel columns. Configurations 3 and 4 (Figure 3.23) have 24 fuel columns and 6 dummy fuel columns. Configuration 5 (Figure 3.24) has 27 fuel columns and 3 dummy fuel columns.

The permanent reflector surrounding the core has been circularized with a radius of 2125 mm and height of 5220 mm.



Revision: 0  
Date: March 31, 2010




Figure 3.18. Fuel and Control Rod Column Orientations.




Figure 3.19. HTTR Column Identification.




Figure 3.20. Cross Section of the HTTR Fully-Loaded, 30-Fuel-Column Core.

09-GA50001-158-1





Figure 3.21. HTTR Core Positions (Configuration 1, 19-Fuel-Columns).






Figure 3.22. HTTR Core Positions (Configuration 2, 21-Fuel-Columns).




Figure 3.23. HTTR Core Positions (Configurations 3 and 4, 24-Fuel-Columns).






Figure 3.24. HTTR Core Positions (Configuration 5, 27-Fuel-Columns).

## 3.1.2.12 Critical Rod Positions

The critical rod positions for configurations 1 through 5 are shown in Figures 3.25 through 3.29, respectively. Control rod positions are described with the zero position defined as level with the bottom place of the lowest fuel block (i.e. 1160 mm from the bottom of the core graphite, the lowest fuel block). These figures provide reference between the various column types in the core and the control rod positions; the dummy fuel column and fuel column are interchangeable in these figures, with no change in the dimensions.




Figure 3.25. Axial Profile of Columns and Control Rod Positions (Configuration 1).

## Gas Cooled (Thermal) Reactor - GCR


HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Figure 3.26. Axial Profile of Columns and Control Rod Positions (Configuration 2).

## Gas Cooled (Thermal) Reactor - GCR


HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Figure 3.27. Axial Profile of Columns and Control Rod Positions (Configuration 3).

## Gas Cooled (Thermal) Reactor - GCR


HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Figure 3.28. Axial Profile of Columns and Control Rod Positions (Configuration 4).

## Gas Cooled (Thermal) Reactor - GCR


HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Figure 3.29. Axial Profile of Columns and Control Rod Positions (Configuration 5).

### 3.1.3 Material Data

#### 3.1.3.1 Pin-in-Block Fuel

##### TRISO Particles

The mass density of the TRISO-coated  $\text{UO}_2$  fuel kernels is  $10.40363 \text{ g/cm}^3$  (such that the total uranium mass per fuel rod is 188.58 g) with an O/U ratio of  $\sim 2.00$  and an equivalent natural-boron impurity content of 0.00015 wt.%. A summary of the atomic densities and compositions for the twelve enrichments found throughout the core are provided in Table 3.2.

Table 3.2. Atomic Densities (atoms/b-cm) of the  $\text{UO}_2$  Kernels for Varying Enrichments.

Isotope	3.40 wt.%	3.90 wt.%	4.30 wt.%	4.80 wt.%	5.20 wt.%	5.90 wt.%
$^{10}\text{B}$	1.7299E-07	1.7299E-07	1.7299E-07	1.7299E-07	1.7299E-07	1.7299E-07
O	4.6404E-02	4.6404E-02	4.6404E-02	4.6404E-02	4.6404E-02	4.6404E-02
$^{234}\text{U}$	6.1026E-06	7.0000E-06	7.7180E-06	8.6154E-06	9.3334E-06	1.0590E-05
$^{235}\text{U}$	7.9888E-04	9.1637E-04	1.0104E-03	1.1278E-03	1.2218E-03	1.3863E-03
$^{238}\text{U}$	2.2405E-02	2.2288E-02	2.2195E-02	2.2078E-02	2.1984E-02	2.1821E-02
Total	6.9614E-02	6.9616E-02	6.9617E-02	6.9618E-02	6.9619E-02	6.9622E-02

Table 3.2 (cont'd.). Atomic Densities (atoms/b-cm) of the  $\text{UO}_2$  Kernels for Varying Enrichments.

Isotope	6.30 wt.%	6.70 wt.%	7.20 wt.%	7.90 wt.%	9.40 wt.%	9.90 wt.%
$^{10}\text{B}$	1.7299E-07	1.7299E-07	1.7299E-07	1.7299E-07	1.7299E-07	1.7299E-07
O	4.6404E-02	4.6404E-02	4.6404E-02	4.6404E-02	4.6404E-02	4.6404E-02
$^{234}\text{U}$	1.1308E-05	1.2026E-05	1.2923E-05	1.4180E-05	1.6872E-05	1.7769E-05
$^{235}\text{U}$	1.4803E-03	1.5743E-03	1.6918E-03	1.8562E-03	2.2087E-03	2.3262E-03
$^{238}\text{U}$	2.1727E-02	2.1634E-02	2.1517E-02	2.1353E-02	2.1002E-02	2.0886E-02
Total	6.9623E-02	6.9624E-02	6.9625E-02	6.9628E-02	6.9632E-02	6.9634E-02

The material properties of the TRISO layers and graphite overcoat are provided in Table 3.3.

Table 3.3. Material Properties of the TRISO Coatings and Graphite Overcoat.

Property	Buffer	IPyC	SiC	OPyC	Overcoat
Mass Density ( $\text{g/cm}^3$ )	1.1	1.85	3.2	1.85	1.7
B-nat Impurity (wppm)	1.5	1.5	1.5	1.5	1.5
Atomic Density (atoms/b-cm)	5.5153E-02	9.2758E-02	9.6122E-02	9.2758E-02	8.5237E-02
$^{10}\text{B}$	1.8290E-08	3.0761E-08	5.3208E-08	3.0761E-08	2.8267E-08
C-nat	5.5153E-02	9.2758E-02	4.8061E-02	9.2758E-02	8.5237E-02
Si	--	--	4.8061E-02	--	--

**Compacts**

A key parameter is that the total fuel mass of a single fuel rod (14 stacked compacts) is approximately 188.58 g.

The mass density of the fuel compact graphite matrix is 1.7 g/cm<sup>3</sup> with an equivalent natural-boron impurity content of 0.000082 wt.%. The atomic density and composition of the compact matrix is shown in Table 3.4.

Table 3.4. Atomic Densities of the  
Fuel Compact Graphite Matrix.

Isotope	Atoms/b-cm
<sup>10</sup> B	1.5452E-08
C-nat	8.5237E-02
Total	8.5237E-02

**Fuel Element**

The IG-110 graphite sleeve and end caps for the fuel pins have a mass density of 1.77 g/cm<sup>3</sup> and an equivalent natural-boron content of 0.000037 wt.%. The atomic density and composition of the graphite used in the fuel element is shown in Table 3.5.

Table 3.5. Atomic Densities of the  
Graphite Fuel Sleeve.

Isotope	Atoms/b-cm
<sup>10</sup> B	7.2596E-09
C-nat	8.8747E-02
Total	8.8747E-02

***3.1.3.2 Burnable Poisons***

The burnable poison pellets have a mass density of 1.80 g/cm<sup>3</sup>; a summary of the atomic densities and compositions for the two natural-boron concentrations employed in the core are provided in Table 3.6. The mass density of the graphite disks used to separate the burnable poison pellets is 1.77 g/cm<sup>3</sup> with an equivalent natural-boron content of 0.000037 wt.%. The atomic density and composition of the graphite disks is also found in Table 3.6



## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 3.6. Atomic Densities (atoms/b-cm) of the Burnable Poison Pellets and Graphite Disks.

Isotope	2.00 wt.%	2.50 wt.%	Disks
<sup>10</sup> B	3.9906E-04	4.9882E-04	7.2596E-09
<sup>11</sup> B	1.6063E-03	2.0078E-03	--
C-nat	8.8446E-02	8.7995E-02	8.8747E-02
Total	9.0451E-02	9.0501E-02	8.8747E-02

**3.1.3.3 Fuel Blocks**

The IG-110 graphite fuel blocks have a mass density of 1.7512 g/cm<sup>3</sup> (1.76 g/cm<sup>3</sup> base density decreased by a calculated 0.5 % void fraction) and an equivalent natural-boron content of 0.000059 wt.%. The atomic density and composition of the graphite fuel blocks is shown in Table 3.7.

Table 3.7. Atomic Densities of the Graphite Fuel Blocks.

Isotope	Atoms/b-cm
<sup>10</sup> B	1.1453E-08
C-nat	8.7804E-02
Total	8.7804E-02

**3.1.3.4 Dummy Blocks**

The IG-11 graphite fuel blocks have a mass density of 1.7413 g/cm<sup>3</sup> (1.75 g/cm<sup>3</sup> base density decreased by a calculated 0.5 % void fraction) and an equivalent natural-boron content of 0.00031 wt.%. The atomic density and composition of the graphite dummy blocks is shown in Table 3.8.

Table 3.8. Atomic Densities of the Graphite Dummy Blocks.

Isotope	Atoms/b-cm
<sup>10</sup> B	5.9835E-08
C-nat	8.7305E-02
Total	8.7305E-02

**3.1.3.5 Control Rod System****Control Rods**

The absorber compacts have a mass density of 1.9 g/cm<sup>3</sup> and have a composition and atomic density as described in Table 3.9.

Table 3.9. Atomic Densities of the  
Absorber Compacts.

Isotope	Atoms/b-cm
<sup>10</sup> B	6.3184E-03
<sup>11</sup> B	2.5432E-02
C-nat	6.6685E-02
Total	9.8436E-02

The Alloy 800H cladding of the control rods has a mass density of 8.03 g/cm<sup>3</sup> with a composition and atomic density as shown in Table 3.10.

Table 3.10. Atomic Densities of the  
Alloy 800H Clad.

Isotope	Atoms/b-cm
C-nat	3.2210E-04
Al	6.7209E-04
Si	6.0263E-04
P	3.1225E-05
S	1.5081E-05
Ti	3.7884E-04
Cr	1.9530E-02
Mn	8.8022E-04
Fe	3.8092E-02
Ni	2.6777E-02
Cu	2.2830E-04
Total	8.7530E-02

### **Control Rod Columns**

The IG-110 graphite fuel columns are modeled with the same physical properties as the fuel blocks in Section 3.1.3.3 and Table 3.7.

#### *3.1.3.6 Instrumentation*

### **Instrumentation Components**

Insufficient information was available to adequately model instrumentation in the HTTR. An approximate bias with uncertainty was determined applied to the benchmark model (see Sections 2.1.2.6 and 3.1.1.1).

**Instrumentation Columns**

The IG-110 graphite instrumentation columns are modeled with the same physical properties as the fuel blocks in Section 3.1.3.3 and Table 3.7.

***3.1.3.7 Replaceable Reflector Columns***

The IG-110 replaceable reflector columns are modeled with the same physical properties as the fuel blocks in Section 3.1.3.3 and Table 3.7.

***3.1.3.8 Replaceable Reflectors Blocks in Fuel Columns***

The IG-110 replaceable reflector blocks are modeled with the same physical properties as the fuel blocks in Section 3.1.3.3 and Table 3.7.

***3.1.3.9 Permanent Reflector***

The PGX graphite permanent reflector has a mass density of 1.71789 g/cm<sup>3</sup> (1.76 g/cm<sup>3</sup> base density decreased by a provided 0.7 % void fraction) and an equivalent natural-boron content of 0.000191 wt.%. The atomic density and composition of the permanent reflector is shown in Table 3.11.

Table 3.11. Atomic Densities of the Permanent Reflector.

Isotope	Atoms/b-cm
<sup>10</sup> B	3.6372E-08
C-nat	8.6134E-02
Total	8.6134E-02

***3.1.3.10 Helium Coolant***

The helium coolant has an atomic density of 2.4616E-05 atoms/b-cm (mass density of  $1.6361 \times 10^{-4}$  g/cm<sup>3</sup>). No impurities are modeled in the coolant.

$$\frac{n}{V} = \frac{P \cdot N_A}{R \cdot T} = \frac{(1 \text{ atm}) \cdot \left( 0.60221 \frac{\text{atoms} \cdot \text{cm}^2}{\text{mol} \cdot \text{b}} \right)}{\left( 0.082054 \frac{\text{L} \cdot \text{atm}}{\text{mol} \cdot \text{K}} \right) \cdot (298.15 \text{ K})} \cdot \left( \frac{1 \text{ L}}{1000 \text{ cm}^3} \right) = 2.4616 \times 10^{-5} \frac{\text{atoms}}{\text{b} \cdot \text{cm}}.$$

$$\rho = \frac{n}{V} \cdot \frac{M}{N_A} = 2.4616 \times 10^{-5} \frac{\text{atoms}}{\text{b} \cdot \text{cm}} \cdot \frac{4.002602 \frac{\text{g}}{\text{mol}}}{\left( 0.60221 \frac{\text{atoms} \cdot \text{cm}^2}{\text{mol} \cdot \text{b}} \right)} = 1.6361 \times 10^{-4} \frac{\text{g}}{\text{cm}^3}.$$

### 3.1.4 Temperature Data

The benchmark model temperature is 300 K.

### 3.1.5 Experimental and Benchmark-Model $k_{\text{eff}}$ and / or Subcritical Parameters

The experimental  $k_{\text{eff}}$  was approximately at unity, made to delayed critical. A comprehensive bias assessment could not be performed; therefore, the experimental  $k_{\text{eff}}$  values were adjusted only for the bias incurred by removing the instrumentation in the core (Table 3.1). Furthermore, the uncertainty in the benchmark models (Tables 2.64 through 2.68) is the same as the uncertainty evaluated for the experimental, as the bias uncertainty for instrumentation has already been included. The benchmark eigenvalues for the annular HTTR core loadings are shown in Table 3.12.

Table 3.12. HTTR Benchmark Values.

Case	Fuel Columns	Control <sup>(a)</sup>	$k_{\text{eff}}$	$-\sigma$	$+\sigma$
1	19	C	1.0048	0.0103	0.0100
2	21	FS	1.0040	0.0100	0.0092
3	24	FS	1.0035	0.0078	0.0084
4	24	F23	1.0032	0.0080	0.0074
5	27	FS	1.0029	0.0068	0.0075

(a) C = criticality obtained using central control rod only.  
 FS = flat standard pattern where C, R1, and R2 CRs were inserted into the core at the same levels while R3 CRs were fully withdrawn.  
 F23 = only R2 and R3 CRs were used for control while C and R1 CRs were fully withdrawn.

### 3.2 Benchmark-Model Specifications for Buckling and Extrapolation-Length Measurements

Buckling and extrapolation length measurements were not made.

### 3.3 Benchmark-Model Specifications for Spectral Characteristics Measurements

Spectral characteristics measurements were not made.

### 3.4 Benchmark-Model Specifications for Reactivity Effects Measurements

Benchmark specifications for the excess reactivity measurements pertaining to the annular core configurations are provided in Section 3.4 of [HTTR-GCR-RESR-001](#).

### 3.5 Benchmark-Model Specifications for Reactivity Coefficient Measurements

Reactivity coefficient measurements were not made.

### 3.6 Benchmark-Model Specifications for Kinetics Measurements

Kinetics measurements were not made.

### 3.7 Benchmark-Model Specifications for Reaction-Rate Distribution Measurements

#### 3.7.1 Description of the Benchmark Model Simplifications

The simplifications of the benchmark model for determination of the axial neutron fission reaction-rate in the instrumentation columns of the HTTR (described in Section 1.7) are identical to those of the critical annular 24-fuel-column core configurations 3 and 4 described in Section 3.1.1.

#### 3.7.2 Dimensions

The dimensions of the benchmark model for determination of the axial neutron reaction-rate in the instrumentation columns of the HTTR are identical to those of the critical annular 24-fuel-column core configurations 3 and 4 described in Section 3.1.2.

The axial neutron fission reaction-rate in the instrumentation columns is calculated by taking the benchmark model of the fully-loaded 30-fuel-column core and superimposing a flux tally over one of the instrumentation column positions: E05, E13, or E21. The flux is computed for 6.15-cm radius discs with a thickness of 1 cm located at the center of one instrumentation channel in each instrumentation column (see Figure 3.30). A total of 522 cm, representing the total height of the core fuel and reflector blocks, was modeled. The (x, y) coordinates used for columns E05, E13, and E21, are (114.6005, 72.4), (5.4, -135.447), and (-120, 63.04693), respectively, where the origin is located at the radial center of the core.

The F4 flux tally is used in MCNP, which determines the flux across a cell volume by tabulating the average track length of the neutrons.<sup>a</sup> The tally is then modified by a tally multiplier card, Fm, that accounts for the total fission cross section of <sup>235</sup>U, the fissile material in the fission chambers, to obtain the neutron reaction-rate in each instrumentation column.

The calculated neutron fission reaction rates are obtained by taking the variance-weighted average of results obtained using six variations of the input deck (Appendix A.1) with different random number seeds and tallies of the neutron reaction rate (Appendix A.3). This approach was used to reduce the statistical uncertainty in the neutron flux tallies because the relative error values obtained can underpredict the true uncertainty in the calculated neutron flux.<sup>b</sup> Therefore, the final calculated values are obtained from a total of 18 reaction-rate tallies (6 input decks with 3 instrumentation columns each).

The average of the neutron reaction-rate in each position is taken and normalized to represent the calculated axial neutron reaction-rate profile:


$$\phi(z)_{normalized} = \frac{\phi(z)}{\phi_{maximum}},$$

---

<sup>a</sup> X-5 Monte Carlo Team, "MCNP – A General Monte Carlo N-Particle Transport Code, Version 5, Volume II: User's Guide," LA-CP-03-0245 (April 24, 2003; revised October 2, 2005).

<sup>b</sup> F. B. Brown, "A Review of Best Practices for Monte Carlo Criticality Calculations," *Proc. NCSD 2009*, Richland, WA, September 13-17 (2009).

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Dimensions in mm

09-GA50001-103

Figure 3.30. Placement of Axial Flux Tally in the Instrumentation Column

**3.7.3 Material Data**

The materials in the benchmark model for determination of the axial neutron reaction-rate in the instrumentation columns of the HTTR are identical to those in the critical annular 24-fuel-column core configurations 3 and 4 described in Section 3.1.3.

### 3.7.4 Temperature Data

The benchmark model temperature is 300 K.

### 3.7.5 Benchmark-Model Specification for Reaction-Rate Distribution Measurements

The expected benchmark values for the normalized axial neutron reaction-rate in the instrumentation columns of the HTTR, with their respective uncertainties (from Section 2.7.1), are shown in Table 3.13 and 3.14 for core configurations 3 and 4, respectively. The normalization is to the highest reaction-rate value, which is data point 4 at a height of 130.96 and 115.79 cm for core configurations 3 and 4, respectively.

Table 3.13. Axial Neutron Fission Reaction Rate in the Instrumentation Columns of the HTTR (Configuration 3).

Data Point	Height (cm) <sup>(a)</sup>	Normalized Benchmark Reaction Rate	$\pm$	$1\sigma$	$1\sigma$ (%)
1	18.89	0.6946	$\pm$	0.0199	2.87
2	27.86	0.7304	$\pm$	0.0198	2.70
3	86.07	0.9555	$\pm$	0.0173	1.81
4	130.96	1.0000	$\pm$	0.0166	1.66
5	137.15	0.9854	$\pm$	0.0169	1.71
6	143.96	0.9750	$\pm$	0.0170	1.75
7	202.48	0.6735	$\pm$	0.0200	2.97
8	260.99	0.2818	$\pm$	0.0165	5.86
9	318.58	0.1041	$\pm$	0.0095	9.16

(a) The height is in reference to the position relative to the bottom of the fifth layer of fuel.

Table 3.14. Axial Neutron Fission Reaction Rate in the Instrumentation Columns of the HTTR (Configuration 4).

Data Point	Height (cm) <sup>(a)</sup>	Normalized Benchmark Reaction Rate	$\pm$	$1\sigma$	$1\sigma$ (%)
1	18.79	0.7030	$\pm$	0.0199	2.83
2	28.40	0.7383	$\pm$	0.0197	2.67
3	86.36	0.9523	$\pm$	0.0174	1.83
4	115.79	1.0000	$\pm$	0.0166	1.66
5	137.45	0.9749	$\pm$	0.0170	1.75
6	144.57	0.9562	$\pm$	0.0173	1.81
7	202.72	0.7915	$\pm$	0.0193	2.44
8	260.85	0.5582	$\pm$	0.0201	3.59
9	318.37	0.3312	$\pm$	0.0176	5.32

(a) The height is in reference to the position relative to the bottom of the fifth layer of fuel.

### 3.8 Benchmark-Model Specifications for Power Distribution Measurements

Power distribution measurements were not made.

### 3.9 Benchmark-Model Specifications for Isotopic Measurements

Isotopic measurements were not made.

### 3.10 Benchmark-Model Specifications for Other Miscellaneous Types of Measurements

Other miscellaneous types of measurements were not made.



## 4.0 RESULTS OF SAMPLE CALCULATIONS

### 4.1 Results of Calculations of the Critical or Subcritical Configurations

Random particles cannot be easily modeled in MCNP. Therefore an ordered-lattice approach for modeling the benchmark was implemented, and results are provided

The computed  $k_{\text{eff}}$  values for the benchmark model of the annular cores were evaluated with MCNP using the ENDF/B-V.2, -VI.8, and -VII.0, JEFF-3.1, and JENDL-3.3 cross section libraries. All benchmark model calculations are compared against the expected benchmark value reported in Section 3.1.5. The total uncertainty in the expected value of  $k_{\text{eff}}$  is taken from Section 2.1.7. The JENDL-3.3 analysis was performed with the inclusion of ENDF/B-VII.0 thermal neutron scattering data because it was not included in the JENDL-3.3 library. Thermal neutron scattering, or  $S(\alpha, \beta)$ , adjusts the neutron cross sections for neutron upscatter at thermal energies and provides scattering data for elements bound within specific materials. The  $k_{\text{eff}}$  values were also calculated using ENDF/B-VII.0 and MCNPX. The MCNP5 calculations were performed with 1,050 generations (skipping the first 50) and 50,000 neutrons per generation.

It is currently difficult to obtain the necessary information to further improve the confidence in the benchmark model and effectively reduce the overall uncertainty; the necessary data is proprietary and its released is being restricted, because the benchmark configuration of the HTTR core is the same that is currently in operation. Once this information is made available, the HTTR benchmark can be adjusted as appropriate.

#### 4.1.1 Ordered TRISO Lattice within the Fuel Compacts

The TRISO particles are modeled in rectangular lattices with the dimensions of 0.106 cm (length)  $\times$  0.106 cm (width)  $\times$  0.1 cm (height) to generate a volumetric packing fraction of 30 % (not including the graphite overcoat) when only complete particles are placed within the compact. A cross-sectional view of the TRISO lattice block is shown in Figure 4.1. The graphite overcoat isn't completely represented in the lattice.

A horizontal cross section of the compacts is shown in Figure 4.2. As can be seen, selective placement of TRISO particles was necessary to conserve the fuel rod mass of 188.58 g. For the current configuration, 12,987 TRISO particles are present within a standard fuel compact; this value is slightly less than the reported value of approximately 13,000.

The effective multiplication factor for configurations 1 through 5 are shown in Table 4.1 through 4.5, respectively. Calculated values of  $k_{\text{eff}}$  differ from the benchmark model values by between 1.4 to 2.7 %. Reevaluation of the HTTR model as additional information becomes available might improve the quality of this benchmark. The benchmark models are most sensitive to graphite impurities, and graphite cross section data may also contributed to the bias.




Figure 4.1. MCNP TRISO Lattice Unit Cell.




Figure 4.2. MCNP Ordered TRISO Lattice within the Fuel Compacts.

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 4.1. Final Results for the HTTR Benchmark Model Evaluation using an Ordered Lattice (Configuration 1).

Neutron Cross-Section Library	Calculated			Benchmark $k_{\text{eff}}$	Uncertainty		(C-E)/E (%)
	$k_{\text{eff}}$	$\pm$	$\sigma$		$-\sigma$ (%)	$+\sigma$ (%)	
ENDF/B-V.2	1.0250	$\pm$	0.0001	1.0048 <sup>(a)</sup>	0.0103	0.0100	2.00
ENDF/B-VI.8	1.0267	$\pm$	0.0001	1.0048 <sup>(a)</sup>	0.0103	0.0100	2.17
END/B-VII.0	1.0276	$\pm$	0.0001	1.0048 <sup>(a)</sup>	0.0103	0.0100	2.27
JEFF-3.1	1.0280	$\pm$	0.0001	1.0048 <sup>(a)</sup>	0.0103	0.0100	2.31
JENDL-3.3 with ENDF/B-VII.0 S( $\alpha,\beta$ )	1.0222	$\pm$	0.0001	1.0048 <sup>(a)</sup>	0.0103	0.0100	1.73
ENDF/B-VII.0 (MCNPX)	1.0273	$\pm$	0.0001	1.0048 <sup>(a)</sup>	0.0103	0.0100	2.24

(a) No biases have been currently evaluated for correcting the expected experimental  $k_{\text{eff}}$ , besides the bias for removing the reactor instrumentation in the instrumentation columns.

Table 4.2. Final Results for the HTTR Benchmark Model Evaluation using an Ordered Lattice (Configuration 2).

Neutron Cross-Section Library	Calculated			Benchmark $k_{\text{eff}}$	Uncertainty		(C-E)/E (%)
	$k_{\text{eff}}$	$\pm$	$\sigma$		$-\sigma$ (%)	$+\sigma$ (%)	
ENDF/B-V.2	1.0268	$\pm$	0.0001	1.0040 <sup>(a)</sup>	0.0100	0.0092	2.27
ENDF/B-VI.8	1.0289	$\pm$	0.0001	1.0040 <sup>(a)</sup>	0.0100	0.0092	2.48
END/B-VII.0	1.0297	$\pm$	0.0001	1.0040 <sup>(a)</sup>	0.0100	0.0092	2.55
JEFF-3.1	1.0301	$\pm$	0.0001	1.0040 <sup>(a)</sup>	0.0100	0.0092	2.60
JENDL-3.3 with ENDF/B-VII.0 S( $\alpha,\beta$ )	1.0241	$\pm$	0.0001	1.0040 <sup>(a)</sup>	0.0100	0.0092	1.99
ENDF/B-VII.0 (MCNPX)	1.0291	$\pm$	0.0001	1.0040 <sup>(a)</sup>	0.0100	0.0092	2.50

(a) No biases have been currently evaluated for correcting the expected experimental  $k_{\text{eff}}$ , besides the bias for removing the reactor instrumentation in the instrumentation columns.

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 4.3. Final Results for the HTTR Benchmark Model Evaluation using an Ordered Lattice (Configuration 3).

Neutron Cross-Section Library	Calculated			Benchmark $k_{\text{eff}}$	Uncertainty		(C-E)/E (%)
	$k_{\text{eff}}$	$\pm$	$\sigma$		$-\sigma$ (%)	$+\sigma$ (%)	
ENDF/B-V.2	1.0224	$\pm$	0.0001	1.0035 <sup>(a)</sup>	0.0078	0.0084	1.89
ENDF/B-VI.8	1.0243	$\pm$	0.0001	1.0035 <sup>(a)</sup>	0.0078	0.0084	2.07
END/B-VII.0	1.0249	$\pm$	0.0001	1.0035 <sup>(a)</sup>	0.0078	0.0084	2.13
JEFF-3.1	1.0257	$\pm$	0.0001	1.0035 <sup>(a)</sup>	0.0078	0.0084	2.21
JENDL-3.3 with ENDF/B-VII.0 S( $\alpha,\beta$ )	1.0198	$\pm$	0.0001	1.0035 <sup>(a)</sup>	0.0078	0.0084	1.62
ENDF/B-VII.0 (MCNPX)	1.0249	$\pm$	0.0001	1.0035 <sup>(a)</sup>	0.0078	0.0084	2.13

(a) No biases have been currently evaluated for correcting the expected experimental  $k_{\text{eff}}$ , besides the bias for removing the reactor instrumentation in the instrumentation columns.

Table 4.4. Final Results for the HTTR Benchmark Model Evaluation using an Ordered Lattice (Configuration 4).

Neutron Cross-Section Library	Calculated			Benchmark $k_{\text{eff}}$	Uncertainty		(C-E)/E (%)
	$k_{\text{eff}}$	$\pm$	$\sigma$		$-\sigma$ (%)	$+\sigma$ (%)	
ENDF/B-V.2	1.0261	$\pm$	0.0001	1.0032 <sup>(a)</sup>	0.0080	0.0074	2.29
ENDF/B-VI.8	1.0284	$\pm$	0.0001	1.0032 <sup>(a)</sup>	0.0080	0.0074	2.52
END/B-VII.0	1.0287	$\pm$	0.0001	1.0032 <sup>(a)</sup>	0.0080	0.0074	2.54
JEFF-3.1	1.0298	$\pm$	0.0001	1.0032 <sup>(a)</sup>	0.0080	0.0074	2.65
JENDL-3.3 with ENDF/B-VII.0 S( $\alpha,\beta$ )	1.0239	$\pm$	0.0001	1.0032 <sup>(a)</sup>	0.0080	0.0074	2.07
ENDF/B-VII.0 (MCNPX)	1.0287	$\pm$	0.0001	1.0032 <sup>(a)</sup>	0.0080	0.0074	2.55

(a) No biases have been currently evaluated for correcting the expected experimental  $k_{\text{eff}}$ , besides the bias for removing the reactor instrumentation in the instrumentation columns.

Table 4.5. Final Results for the HTTR Benchmark Model Evaluation using an Ordered Lattice (Configuration 5).

Neutron Cross-Section Library	Calculated			Benchmark $k_{\text{eff}}$	Uncertainty		(C-E)/E (%)
	$k_{\text{eff}}$	$\pm$	$\sigma$		$-\sigma$ (%)	$+\sigma$ (%)	
ENDF/B-V.2	1.0189	$\pm$	0.0001	1.0029 <sup>(a)</sup>	0.0068	0.0075	1.60
ENDF/B-VI.8	1.0211	$\pm$	0.0001	1.0029 <sup>(a)</sup>	0.0068	0.0075	1.82
END/B-VII.0	1.0218	$\pm$	0.0001	1.0029 <sup>(a)</sup>	0.0068	0.0075	1.88
JEFF-3.1	1.0224	$\pm$	0.0001	1.0029 <sup>(a)</sup>	0.0068	0.0075	1.94
JENDL-3.3 with ENDF/B-VII.0 S( $\alpha,\beta$ )	1.0167	$\pm$	0.0001	1.0029 <sup>(a)</sup>	0.0068	0.0075	1.37
ENDF/B-VII.0 (MCNPX)	1.0217	$\pm$	0.0001	1.0029 <sup>(a)</sup>	0.0068	0.0075	1.88

(a) No biases have been currently evaluated for correcting the expected experimental  $k_{\text{eff}}$ , besides the bias for removing the reactor instrumentation in the instrumentation columns.

#### 4.2 Results of Buckling and Extrapolation Length Calculations

Buckling and extrapolation length measurements were not made.

#### 4.3 Results of Spectral-Characteristics Calculations

Spectral characteristics measurements were not made.

#### 4.4 Results of Reactivity-Effects Calculations

Sample calculation results for the excess reactivity measurements of the annular core configurations are provided in Section 4.4.1 of [HTTR-GCR-RESR-001](#).

**4.5 Results of Reactivity Coefficient Calculations**

Reactivity coefficient measurements were not made.

**4.6 Results of Kinetics Parameter Calculations**

Kinetics measurements were not made.

**4.7 Results of Reaction-Rate Distribution Calculations****4.7.1 Axial Reaction Rate Distribution**

The benchmark model for the critical annular 24-fuel-column configurations 3 and 4 described in Section 3.1 was utilized in the analysis of the reactor physics experiments in Section 1.7. The modeling approach described in Section 4.1 applies to the analysis in this section except that all calculations were performed only using the ENDF/B-VII.0 neutron cross-section library. Computed axial neutron reaction-rates in the instrumentation columns of the HTTR, averaged and normalized from tallies across the three columns from input decks using six different random number seeds, are summarized in Tables 4.6 and 4.7 as well as depicted in Figures 4.3 and 4.4 for configurations 3 and 4, respectively. The calculated flux with uncertainty bars is shown in Figures 4.5 and 4.6, respectively.

The calculated reaction rates are renormalized such that at data point 4, both the benchmark and calculated values are 1.0000, using Equations 4.1 and 4.2, where the normalized flux at the  $i^{\text{th}}$  position,  $\varphi_{i,n}$ , is obtained by dividing the reaction rate at that position by the maximum flux,  $\varphi_{i,\text{max}}$ . Then the calculated reaction rate, subscript C, is renormalized to the maximum reaction rate of the benchmark experiment, subscript E.

$$\varphi_{i,n} = \frac{\varphi_i}{\varphi_{i,\text{max}}} . \quad (4.1)$$

$$\varphi_{i,n,C} = \frac{\varphi_{i,n,C}}{\varphi_{i,n,\text{max},E}} . \quad (4.2)$$

The calculated axial neutron fission reaction-rate values appear to be in good agreement with the experimental measurements; all values are within  $2\sigma$ . The values reported in the right-hand column of Tables 4.6 and 4.7 represent the difference between the calculated (C) and the expected benchmark (E) values.

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

Table 4.6. Calculated Axial Neutron Fission Reaction Rate in the Instrumentation Columns of the HTTR (Configuration 3).

Data Point	Height (cm) <sup>(a)</sup>	Benchmark Flux	±	1σ	Calculated Flux	±	1σ	C/E
1	18.89	0.6946	±	0.0199	0.6914	±	0.0014	0.995
2	27.86	0.7304	±	0.0198	0.7326	±	0.0014	1.003
3	86.07	0.9555	±	0.0173	0.9650	±	0.0016	1.010
4	130.96	1.0000	±	0.0166	1.0000	±	0.0016	1.000
5	137.15	0.9854	±	0.0169	0.9892	±	0.0016	1.004
6	143.96	0.9750	±	0.0170	0.9761	±	0.0016	1.001
7	202.48	0.6735	±	0.0200	0.6894	±	0.0014	1.024
8	260.99	0.2818	±	0.0165	0.3043	±	0.0009	1.080
9	318.58	0.1041	±	0.0095	0.1111	±	0.0005	1.068

(a) The height is in reference to the position relative to the bottom of the fifth layer of fuel.

Table 4.7. Calculated Axial Neutron Fission Reaction Rate in the Instrumentation Columns of the HTTR (Configuration 4).

Data Point	Height (cm) <sup>(a)</sup>	Benchmark Reaction Rate	±	1σ	Calculated Reaction Rate	±	1σ	C/E
1	18.79	0.7030	±	0.0199	0.6932	±	0.0015	0.986
2	28.40	0.7383	±	0.0197	0.7380	±	0.0016	1.000
3	86.36	0.9523	±	0.0174	0.9625	±	0.0018	1.011
4	115.79	1.0000	±	0.0166	1.0000	±	0.0018	1.000
5	137.45	0.9749	±	0.0170	0.9704	±	0.0018	0.995
6	144.57	0.9562	±	0.0173	0.9569	±	0.0018	1.001
7	202.72	0.7915	±	0.0193	0.7905	±	0.0016	0.999
8	260.85	0.5582	±	0.0201	0.5625	±	0.0014	1.008
9	318.37	0.3312	±	0.0176	0.3417	±	0.0011	1.032

(a) The height is in reference to the position relative to the bottom of the fifth layer of fuel.

### Axial Neutron Reaction-Rate in the Instrumentation Columns of the Annular 24(FS)-Fuel-Column HTTR Core




Figure 4.3. Calculated Axial Neutron Reaction Rate in the Instrumentation Columns of the HTTR (Configuration 3).






Figure 4.4. Calculated Axial Neutron Reaction Rate in the Instrumentation Columns of the HTTR (Configuration 4).

### Axial Neutron Reaction-Rate in the Instrumentation Columns of the Annular 24(FS)-Fuel-Column HTTR Core





Figure 4.5. Calculated Axial Neutron Reaction Rate with Uncertainty ( $1\sigma$ ) for Configuration 3.

Figure 4.6. Calculated Axial Neutron Reaction Rate with Uncertainty ( $1\sigma$ ) for Configuration 4.

#### **4.8     Results of Power Distribution Calculations**

Power distribution measurements were not made.

#### **4.9     Results of Isotopic Calculations**

Isotopic measurements were not made.

#### **4.10   Results of Calculations for Other Miscellaneous Types of Measurements**

Other miscellaneous types of measurements were not made.

## 5.0 REFERENCES

1. N. Fujimoto, K. Yamashita, N. Nojiri, M. Takeuchi, and S. Fujisaki, "Annular Core Experiments in HTTR's Start-Up Core Physics Tests," *Nucl. Sci. Eng.*, **150**, 310-321 (2005).
2. "Evaluation of High Temperature Gas Cooled Reactor Performance: Benchmark Analysis Related to Initial Testing of the HTTR and HTR-10," IAEA-TECDOC-1382, International Atomic Energy Agency, Vienna, November 2003.
3. S. Shiozawa, S. Fujikawa, T. Iyoku, K. Kunitomi, and Y. Tachibana, "Overview of HTTR Design Features," *Nucl. Eng. Des.*, **233**:11-21 (2004).
4. N. Nojiri, S. Shimakawa, N. Fujimoto, and M. Goto, "Characteristic Test of Initial HTTR Core," *Nucl. Eng. Des.*, **233**: 283-290 (2004).

**APPENDIX A: COMPUTER CODES, CROSS SECTIONS, AND TYPICAL INPUT LISTINGS****A.1 Critical Configuration****A.1.1 Name(s) of code system(s) used.**

1. Monte Carlo n-Particle, version 5.1.40 (MCNP5)
2. Monte Carlo n-Particle Extensions, version 2.5.0 (MCNPX)

**A.1.2 Bibliographic references for the codes used.**

1. X-5 Monte Carlo Team, "MCNP – a General Monte Carlo n-Particle Transport Code, version 5," LA-UR-03-1987, Los Alamos National Laboratory (2003).
2. J. S. Hendricks, et al., "MCNPX Extensions," LA-UR-05-2675, Los Alamos National Laboratory (April 2005).

**A.1.3 Origin of cross-section data.**

The Evaluated Neutron Data File library, ENDF/B-VII.0,<sup>a</sup> was utilized in the benchmark model analysis. Other versions, including ENDF/B-V.2<sup>b</sup> and ENDF/B-VI.8,<sup>c</sup> were used with the benchmark model for a baseline comparison. The European Joint Evaluated Fission and Fusion File, JEFF-3.1<sup>d</sup> and the Japanese Evaluated Nuclear Data Library, JENDL-3.3,<sup>e</sup> were also included for a basic evaluative comparison. Such comparisons are typical.<sup>fg</sup> The JENDL-3.3 analysis was performed with the inclusion of ENDF/B-VII.0 thermal neutron scattering data because it was not included in the JENDL-3.3 library. Thermal neutron scattering, or  $S(\alpha, \beta)$ , adjusts the neutron cross sections for neutron upscatter at thermal energies and provides scattering data for elements bound within specific materials.

**A.1.4 Spectral calculations and data reduction methods used.**

Not applicable

**A.1.5 Number of energy groups or if continuous-energy cross sections are used in the different phases of the calculation.**

Continuous-energy cross sections

---

<sup>a</sup> M. B. Chadwick, et al., "ENDF/B-VII.0: Next Generation Evaluated Nuclear Data Library for Nuclear Science and Technology," *Nucl. Data Sheets*, **107**: 2931-3060 (2006).

<sup>b</sup> R. Kinsey, Ed., ENDF/B Summary Documentation, BNL-NCS-17542 (ENDF-201), 3<sup>rd</sup> ed., Brookhaven National Laboratory (1979).

<sup>c</sup> H. D. Lemmel, P. K. McLaughlin, and V. G. Pronyaev, "ENDF/B-VI Release 8 (Last Release of ENDF/B-VI) the U.S. Evaluated Nuclear Data Library for Neutron Reaction Data," IAEA-NDS-100 Rev. 11, International Atomic Energy Agency, Vienna (November 2001).

<sup>d</sup> A. Koning, R. Forrest, M. Kellett, R. Mills, H. Henriksson, and Y. Rugama, "The JEFF-3.1 Nuclear Data Library," JEFF Report 21, Organisation for Economic Co-operation and Development, Paris (2006).

<sup>e</sup> K. Shibata, et al., "Japanese Evaluated Nuclear Data Library Version 3 Revision-3: JENDL-3.3," *J. Nucl. Sci. Tech.*, **39**(11): 1125-1136 (November 2002).

<sup>f</sup> A. C. Kahler, "Monte Carlo Eigenvalue Calculations with ENDF/B-VI.8, JEFF-3.0, and JENDL-3.3 Cross Sections for a Selection of International Criticality Safety Benchmark Evaluation Project Handbook Benchmarks," *Nucl. Sci. Eng.*, **145**: 213-224 (2003).

<sup>g</sup> M. Goto, N. Nojiri, and S. Shimakawa, "Neutronics Calculations of HTTR with Several Nuclear Data Libraries," *J. Nucl. Sci. Tech.*, **43**(10): 1237-1244 (2006).

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE**A.1.6 Component calculations.**

- Type of cell calculation – Reactor core and reflectors
- Geometry – Cylindrical
- Theory used – Not applicable
- Method used – Monte Carlo
- Calculation characteristics – histories/cycles/cycles skipped = 50,000/1,050/50  
continuous-energy cross sections

**A.1.7 Other assumptions and characteristics.**

Not applicable

**A.1.8 Typical input listings.***MCNP5 and MCNPX Input Deck for the 27-fuel-column core, configuration 5, of the HTTR:*

```

HTTR Start-Up Core Critical (27 fuel columns, Configuration 5) --
c
c John Darrell Bess - Idaho National Laboratory
c Last Updated: November 13, 2009
c
c Cell Cards *****
c --- Fuel Column -----
c ----- TRISO Particles -----
1  1  6.9614E-02  -1 imp:n=1 u=13 $ 3.4% kernel
2  13 5.5153E-02  1 -2 imp:n=1 u=13 $ buffer
3  14 9.2758E-02  2 -3 imp:n=1 u=13 $ IPyC
4  15 9.6122E-02  3 -4 imp:n=1 u=13 $ SiC
5  16 9.2758E-02  4 -5 imp:n=1 u=13 $ OPyC
6  17 8.5237E-02  5 -6 imp:n=1 u=13 $ overcoat
7  18 8.5237E-02  6 901 -902 903 -904 905 -906 imp:n=1 u=13 $ compact fill
11 like 1 but mat=2 u=14 rho=6.9616E-02 $ 3.9% kernel ---
12 like 2 but u=14 $ buffer
13 like 3 but u=14 $ IPyC
14 like 4 but u=14 $ SiC
15 like 5 but u=14 $ OPyC
16 like 6 but u=14 $ overcoat
17 like 7 but u=14 $ compact fill
21 like 1 but mat=3 u=15 rho=6.9617E-02 $ 4.3% kernel ---
22 like 2 but u=15 $ buffer
23 like 3 but u=15 $ IPyC
24 like 4 but u=15 $ SiC
25 like 5 but u=15 $ OPyC
26 like 6 but u=15 $ overcoat
27 like 7 but u=15 $ compact fill
31 like 1 but mat=4 u=16 rho=6.9618E-02 $ 4.8% kernel ---
32 like 2 but u=16 $ buffer
33 like 3 but u=16 $ IPyC
34 like 4 but u=16 $ SiC
35 like 5 but u=16 $ OPyC
36 like 6 but u=16 $ overcoat
37 like 7 but u=16 $ compact fill
41 like 1 but mat=5 u=17 rho=6.9619E-02 $ 5.2% kernel ---
42 like 2 but u=17 $ buffer
43 like 3 but u=17 $ IPyC
44 like 4 but u=17 $ SiC
45 like 5 but u=17 $ OPyC
46 like 6 but u=17 $ overcoat
47 like 7 but u=17 $ compact fill
51 like 1 but mat=6 u=18 rho=6.9622E-02 $ 5.9% kernel ---
52 like 2 but u=18 $ buffer
53 like 3 but u=18 $ IPyC
54 like 4 but u=18 $ SiC
55 like 5 but u=18 $ OPyC
56 like 6 but u=18 $ overcoat
57 like 7 but u=18 $ compact fill
61 like 1 but mat=7 u=19 rho=6.9623E-02 $ 6.3% kernel ---
62 like 2 but u=19 $ buffer

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

63  like 3 but u=19 $ IPyC
64  like 4 but u=19 $ SiC
65  like 5 but u=19 $ OPyC
66  like 6 but u=19 $ overcoat
67  like 7 but u=19 $ compact fill
71  like 1 but mat=8 u=20 rho=6.9624E-02 $ 6.7% kernel ---
72  like 2 but u=20 $ buffer
73  like 3 but u=20 $ IPyC
74  like 4 but u=20 $ SiC
75  like 5 but u=20 $ OPyC
76  like 6 but u=20 $ overcoat
77  like 7 but u=20 $ compact fill
81  like 1 but mat=9 u=21 rho=6.9625E-02 $ 7.2% kernel ---
82  like 2 but u=21 $ buffer
83  like 3 but u=21 $ IPyC
84  like 4 but u=21 $ SiC
85  like 5 but u=21 $ OPyC
86  like 6 but u=21 $ overcoat
87  like 7 but u=21 $ compact fill
91  like 1 but mat=10 u=22 rho=6.9628E-02 $ 7.9% kernel ---
92  like 2 but u=22 $ buffer
93  like 3 but u=22 $ IPyC
94  like 4 but u=22 $ SiC
95  like 5 but u=22 $ OPyC
96  like 6 but u=22 $ overcoat
97  like 7 but u=22 $ compact fill
101 like 1 but mat=11 u=23 rho=6.9632E-02 $ 9.4% kernel ---
102 like 2 but u=23 $ buffer
103 like 3 but u=23 $ IPyC
104 like 4 but u=23 $ SiC
105 like 5 but u=23 $ OPyC
106 like 6 but u=23 $ overcoat
107 like 7 but u=23 $ compact fill
111 like 1 but mat=12 u=24 rho=6.9634E-02 $ 9.9% kernel ---
112 like 2 but u=24 $ buffer
113 like 3 but u=24 $ IPyC
114 like 4 but u=24 $ SiC
115 like 5 but u=24 $ OPyC
116 like 6 but u=24 $ overcoat
117 like 7 but u=24 $ compact fill
c
c ----- Compacts -----
120 18 8.5237E-02 901 -902 903 -904 905 -906 imp:n=1 u=300 $ compact fill
163 0 911 -912 913 -914 915 -916 imp:n=1 u=25 lat=1 fill=-13:13 -13:13 0:0
    300 26r 300 26r 300 9r 13 6r 300 9r 300 7r 13 10r 300 7r
    300 5r 13 14r 300 5r 300 4r 13 16r 300 4r 300 3r 13 18r 300 3r
    300 3r 13 18r 300 3r 300 2r 13 8r 300 2r 13 8r 300 2r
    300 1r 13 7r 300 6r 13 6r 300 2r 300 1r 13 6r 300 8r 13 6r 300 1r
    300 1r 13 6r 300 8r 13 6r 300 1r 300 1r 13 5r 300 10r 13 5r 300 1r
    300 1r 13 5r 300 10r 13 5r 300 1r 300 1r 13 5r 300 10r 13 5r 300 1r
    300 1r 13 6r 300 8r 13 6r 300 1r 300 1r 13 6r 300 8r 13 6r 300 1r
    300 2r 13 6r 300 6r 13 6r 300 2r 300 2r 13 8r 300 2r 13 8r 300 2r
    300 3r 13 18r 300 3r 300 3r 13 18r 300 3r 300 4r 13 16r 300 4r
    300 5r 13 14r 300 5r 300 7r 13 10r 300 7r 300 9r 13 6r 300 9r
    300 26r 300 26r
164 like 163 but u=26 fill=-13:13 -13:13 0:0
    300 26r 300 26r 300 9r 14 6r 300 9r 300 7r 14 10r 300 7r
    300 5r 14 14r 300 5r 300 4r 14 16r 300 4r 300 3r 14 18r 300 3r
    300 3r 14 18r 300 3r 300 2r 14 8r 300 2r 14 8r 300 2r
    300 1r 14 7r 300 6r 14 6r 300 2r 300 1r 14 6r 300 8r 14 6r 300 1r
    300 1r 14 6r 300 8r 14 6r 300 1r 300 1r 14 5r 300 10r 14 5r 300 1r
    300 1r 14 5r 300 10r 14 5r 300 1r 300 1r 14 5r 300 10r 14 5r 300 1r
    300 1r 14 6r 300 8r 14 6r 300 1r 300 1r 14 6r 300 8r 14 6r 300 1r
    300 2r 14 6r 300 6r 14 6r 300 2r 300 2r 14 8r 300 2r 14 8r 300 2r
    300 3r 14 18r 300 3r 300 3r 14 18r 300 3r 300 4r 14 16r 300 4r
    300 5r 14 14r 300 5r 300 7r 14 10r 300 7r 300 9r 14 6r 300 9r
    300 26r 300 26r
165 like 163 but u=27 fill=-13:13 -13:13 0:0
    300 26r 300 26r 300 9r 15 6r 300 9r 300 7r 15 10r 300 7r
    300 5r 15 14r 300 5r 300 4r 15 16r 300 4r 300 3r 15 18r 300 3r
    300 3r 15 18r 300 3r 300 2r 15 8r 300 2r 15 8r 300 2r
    300 1r 15 7r 300 6r 15 6r 300 2r 300 1r 15 6r 300 8r 15 6r 300 1r
    300 1r 15 6r 300 8r 15 6r 300 1r 300 1r 15 5r 300 10r 15 5r 300 1r
    300 1r 15 5r 300 10r 15 5r 300 1r 300 1r 15 5r 300 10r 15 5r 300 1r
    300 1r 15 6r 300 8r 15 6r 300 1r 300 1r 15 6r 300 8r 15 6r 300 1r
    300 2r 15 6r 300 6r 15 6r 300 2r 300 2r 15 8r 300 2r 15 8r 300 2r

```



## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```
300 3r 15 18r 300 3r 300 3r 15 18r 300 3r 300 4r 15 16r 300 4r
300 5r 15 14r 300 5r 300 7r 15 10r 300 7r 300 9r 15 6r 300 9r
300 26r 300 26r
166 like 163 but u=28 fill=-13:13 -13:13 0:0
300 26r 300 26r 300 9r 16 6r 300 9r 300 7r 16 10r 300 7r
300 5r 16 14r 300 5r 300 4r 16 16r 300 4r 300 3r 16 18r 300 3r
300 3r 16 18r 300 3r 300 2r 16 8r 300 2r 16 8r 300 2r
300 1r 16 7r 300 6r 16 6r 300 2r 300 1r 16 6r 300 8r 16 6r 300 1r
300 1r 16 6r 300 8r 16 6r 300 1r 300 1r 16 5r 300 10r 16 5r 300 1r
300 1r 16 5r 300 10r 16 5r 300 1r 300 1r 16 5r 300 10r 16 5r 300 1r
300 1r 16 6r 300 8r 16 6r 300 1r 300 1r 16 6r 300 8r 16 6r 300 1r
300 2r 16 6r 300 6r 16 6r 300 2r 300 2r 16 8r 300 2r 16 8r 300 2r
300 3r 16 18r 300 3r 300 3r 16 18r 300 3r 300 4r 16 16r 300 4r
300 5r 16 14r 300 5r 300 7r 16 10r 300 7r 300 9r 16 6r 300 9r
300 26r 300 26r
167 like 163 but u=29 fill=-13:13 -13:13 0:0
300 26r 300 26r 300 9r 17 6r 300 9r 300 7r 17 10r 300 7r
300 5r 17 14r 300 5r 300 4r 17 16r 300 4r 300 3r 17 18r 300 3r
300 3r 17 18r 300 3r 300 2r 17 8r 300 2r 17 8r 300 2r
300 1r 17 7r 300 6r 17 6r 300 2r 300 1r 17 6r 300 8r 17 6r 300 1r
300 1r 17 6r 300 8r 17 6r 300 1r 300 1r 17 5r 300 10r 17 5r 300 1r
300 1r 17 5r 300 10r 17 5r 300 1r 300 1r 17 5r 300 10r 17 5r 300 1r
300 1r 17 6r 300 8r 17 6r 300 1r 300 1r 17 6r 300 8r 17 6r 300 1r
300 2r 17 6r 300 6r 17 6r 300 2r 300 2r 17 8r 300 2r 17 8r 300 2r
300 3r 17 18r 300 3r 300 3r 17 18r 300 3r 300 4r 17 16r 300 4r
300 5r 17 14r 300 5r 300 7r 17 10r 300 7r 300 9r 17 6r 300 9r
300 26r 300 26r
168 like 163 but u=30 fill=-13:13 -13:13 0:0
300 26r 300 26r 300 9r 18 6r 300 9r 300 7r 18 10r 300 7r
300 5r 18 14r 300 5r 300 4r 18 16r 300 4r 300 3r 18 18r 300 3r
300 3r 18 18r 300 3r 300 2r 18 8r 300 2r 18 8r 300 2r
300 1r 18 7r 300 6r 18 6r 300 2r 300 1r 18 6r 300 8r 18 6r 300 1r
300 1r 18 6r 300 8r 18 6r 300 1r 300 1r 18 5r 300 10r 18 5r 300 1r
300 1r 18 5r 300 10r 18 5r 300 1r 300 1r 18 5r 300 10r 18 5r 300 1r
300 1r 18 6r 300 8r 18 6r 300 1r 300 1r 18 6r 300 8r 18 6r 300 1r
300 2r 18 6r 300 6r 18 6r 300 2r 300 2r 18 8r 300 2r 18 8r 300 2r
300 3r 18 18r 300 3r 300 3r 18 18r 300 3r 300 4r 18 16r 300 4r
300 5r 18 14r 300 5r 300 7r 18 10r 300 7r 300 9r 18 6r 300 9r
300 26r 300 26r
169 like 163 but u=31 fill=-13:13 -13:13 0:0
300 26r 300 26r 300 9r 19 6r 300 9r 300 7r 19 10r 300 7r
300 5r 19 14r 300 5r 300 4r 19 16r 300 4r 300 3r 19 18r 300 3r
300 3r 19 18r 300 3r 300 2r 19 8r 300 2r 19 8r 300 2r
300 1r 19 7r 300 6r 19 6r 300 2r 300 1r 19 6r 300 8r 19 6r 300 1r
300 1r 19 6r 300 8r 19 6r 300 1r 300 1r 19 5r 300 10r 19 5r 300 1r
300 1r 19 5r 300 10r 19 5r 300 1r 300 1r 19 5r 300 10r 19 5r 300 1r
300 1r 19 6r 300 8r 19 6r 300 1r 300 1r 19 6r 300 8r 19 6r 300 1r
300 2r 19 6r 300 6r 19 6r 300 2r 300 2r 19 8r 300 2r 19 8r 300 2r
300 3r 19 18r 300 3r 300 3r 19 18r 300 3r 300 4r 19 16r 300 4r
300 5r 19 14r 300 5r 300 7r 19 10r 300 7r 300 9r 19 6r 300 9r
300 26r 300 26r
180 like 163 but u=32 fill=-13:13 -13:13 0:0
300 26r 300 26r 300 9r 20 6r 300 9r 300 7r 20 10r 300 7r
300 5r 20 14r 300 5r 300 4r 20 16r 300 4r 300 3r 20 18r 300 3r
300 3r 20 18r 300 3r 300 2r 20 8r 300 2r 20 8r 300 2r
300 1r 20 7r 300 6r 20 6r 300 2r 300 1r 20 6r 300 8r 20 6r 300 1r
300 1r 20 6r 300 8r 20 6r 300 1r 300 1r 20 5r 300 10r 20 5r 300 1r
300 1r 20 5r 300 10r 20 5r 300 1r 300 1r 20 5r 300 10r 20 5r 300 1r
300 1r 20 6r 300 8r 20 6r 300 1r 300 1r 20 6r 300 8r 20 6r 300 1r
300 2r 20 6r 300 6r 20 6r 300 2r 300 2r 20 8r 300 2r 20 8r 300 2r
300 3r 20 18r 300 3r 300 3r 20 18r 300 3r 300 4r 20 16r 300 4r
300 5r 20 14r 300 5r 300 7r 20 10r 300 7r 300 9r 20 6r 300 9r
300 26r 300 26r
181 like 163 but u=33 fill=-13:13 -13:13 0:0
300 26r 300 26r 300 9r 21 6r 300 9r 300 7r 21 10r 300 7r
300 5r 21 14r 300 5r 300 4r 21 16r 300 4r 300 3r 21 18r 300 3r
300 3r 21 18r 300 3r 300 2r 21 8r 300 2r 21 8r 300 2r
300 1r 21 7r 300 6r 21 6r 300 2r 300 1r 21 6r 300 8r 21 6r 300 1r
300 1r 21 6r 300 8r 21 6r 300 1r 300 1r 21 5r 300 10r 21 5r 300 1r
300 1r 21 5r 300 10r 21 5r 300 1r 300 1r 21 5r 300 10r 21 5r 300 1r
300 1r 21 6r 300 8r 21 6r 300 1r 300 1r 21 6r 300 8r 21 6r 300 1r
300 2r 21 6r 300 6r 21 6r 300 2r 300 2r 21 8r 300 2r 21 8r 300 2r
300 3r 21 18r 300 3r 300 3r 21 18r 300 3r 300 4r 21 16r 300 4r
300 5r 21 14r 300 5r 300 7r 21 10r 300 7r 300 9r 21 6r 300 9r
300 26r 300 26r
182 like 163 but u=34 fill=-13:13 -13:13 0:0
```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

300 26r 300 26r 300 9r 22 6r 300 9r 300 7r 22 10r 300 7r
300 5r 22 14r 300 5r 300 4r 22 16r 300 4r 300 3r 22 18r 300 3r
300 3r 22 18r 300 3r 300 2r 22 8r 300 2r 22 8r 300 2r
300 1r 22 7r 300 6r 22 6r 300 2r 300 1r 22 6r 300 8r 22 6r 300 1r
300 1r 22 6r 300 8r 22 6r 300 1r 300 1r 22 5r 300 10r 22 5r 300 1r
300 1r 22 5r 300 10r 22 5r 300 1r 300 1r 22 5r 300 10r 22 5r 300 1r
300 1r 22 6r 300 8r 22 6r 300 1r 300 1r 22 6r 300 8r 22 6r 300 1r
300 2r 22 6r 300 6r 22 6r 300 2r 300 2r 22 8r 300 2r 22 8r 300 2r
300 3r 22 18r 300 3r 300 3r 22 18r 300 3r 300 4r 22 16r 300 4r
300 5r 22 14r 300 5r 300 7r 22 10r 300 7r 300 9r 22 6r 300 9r
300 26r 300 26r
183 like 163 but u=35 fill=-13:13 -13:13 0:0
300 26r 300 26r 300 9r 23 6r 300 9r 300 7r 23 10r 300 7r
300 5r 23 14r 300 5r 300 4r 23 16r 300 4r 300 3r 23 18r 300 3r
300 3r 23 18r 300 3r 300 2r 23 8r 300 2r 23 8r 300 2r
300 1r 23 7r 300 6r 23 6r 300 2r 300 1r 23 6r 300 8r 23 6r 300 1r
300 1r 23 6r 300 8r 23 6r 300 1r 300 1r 23 5r 300 10r 23 5r 300 1r
300 1r 23 5r 300 10r 23 5r 300 1r 300 1r 23 5r 300 10r 23 5r 300 1r
300 1r 23 6r 300 8r 23 6r 300 1r 300 1r 23 6r 300 8r 23 6r 300 1r
300 2r 23 6r 300 6r 23 6r 300 2r 300 2r 23 8r 300 2r 23 8r 300 2r
300 3r 23 18r 300 3r 300 3r 23 18r 300 3r 300 4r 23 16r 300 4r
300 5r 23 14r 300 5r 300 7r 23 10r 300 7r 300 9r 23 6r 300 9r
300 26r 300 26r
184 like 163 but u=36 fill=-13:13 -13:13 0:0
300 26r 300 26r 300 9r 24 6r 300 9r 300 7r 24 10r 300 7r
300 5r 24 14r 300 5r 300 4r 24 16r 300 4r 300 3r 24 18r 300 3r
300 3r 24 18r 300 3r 300 2r 24 8r 300 2r 24 8r 300 2r
300 1r 24 7r 300 6r 24 6r 300 2r 300 1r 24 6r 300 8r 24 6r 300 1r
300 1r 24 6r 300 8r 24 6r 300 1r 300 1r 24 5r 300 10r 24 5r 300 1r
300 1r 24 5r 300 10r 24 5r 300 1r 300 1r 24 5r 300 10r 24 5r 300 1r
300 1r 24 6r 300 8r 24 6r 300 1r 300 1r 24 6r 300 8r 24 6r 300 1r
300 2r 24 6r 300 6r 24 6r 300 2r 300 2r 24 8r 300 2r 24 8r 300 2r
300 3r 24 18r 300 3r 300 3r 24 18r 300 3r 300 4r 24 16r 300 4r
300 5r 24 14r 300 5r 300 7r 24 10r 300 7r 300 9r 24 6r 300 9r
300 26r 300 26r
9163 0 921 -922 923 -924 925 -926 imp:n=1 u=925 lat=1 fill=25
9164 like 9163 but u=926 fill=26
9165 like 9163 but u=927 fill=27
9166 like 9163 but u=928 fill=28
9167 like 9163 but u=929 fill=29
9168 like 9163 but u=930 fill=30
9169 like 9163 but u=931 fill=31
9180 like 9163 but u=932 fill=32
9181 like 9163 but u=933 fill=33
9182 like 9163 but u=934 fill=34
9183 like 9163 but u=935 fill=35
9184 like 9163 but u=936 fill=36
185 0 12 -13 imp:n=1 u=37 fill=925
186 like 185 but u=38 fill=926
187 like 185 but u=39 fill=927
188 like 185 but u=40 fill=928
189 like 185 but u=41 fill=929
190 like 185 but u=42 fill=930
191 like 185 but u=43 fill=931
192 like 185 but u=44 fill=932
193 like 185 but u=45 fill=933
194 like 185 but u=46 fill=934
195 like 185 but u=47 fill=935
196 like 185 but u=48 fill=936
c
c ----- Fuel Pins -----
251 27 2.4616E-05 -12 imp:n=1 u=37 $ central hole
252 like 251 but u=38
253 like 251 but u=39
254 like 251 but u=40
255 like 251 but u=41
256 like 251 but u=42
257 like 251 but u=43
258 like 251 but u=44
259 like 251 but u=45
260 like 251 but u=46
261 like 251 but u=47
262 like 251 but u=48
263 27 2.4616E-05 13 -21 imp:n=1 u=37 $ annulus between compact and sleeve
264 like 263 but u=38
265 like 263 but u=39

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

266 like 263 but u=40
267 like 263 but u=41
268 like 263 but u=42
269 like 263 but u=43
270 like 263 but u=44
271 like 263 but u=45
272 like 263 but u=46
273 like 263 but u=47
274 like 263 but u=48
275 19 8.8747E-02 21 -22 imp:n=1 u=37 $ graphite sleeve
1275 like 275 but u=38
276 like 275 but u=39
277 like 275 but u=40
278 like 275 but u=41
279 like 275 but u=42
280 like 275 but u=43
281 like 275 but u=44
282 like 275 but u=45
283 like 275 but u=46
284 like 275 but u=47
285 like 275 but u=48
c
c ----- Coolant Channels -----
286 27 2.4616E-05 22 -31 imp:n=1 u=37 $ annulus between sleeve and block
287 like 286 but u=38
288 like 286 but u=39
289 like 286 but u=40
290 like 286 but u=41
291 like 286 but u=42
292 like 286 but u=43
293 like 286 but u=44
294 like 286 but u=45
295 like 286 but u=46
296 like 286 but u=47
297 like 286 but u=48
298 25 8.7804E-02 31 imp:n=1 u=37 $ graphite block
299 like 298 but u=38
300 like 298 but u=39
301 like 298 but u=40
302 like 298 but u=41
303 like 298 but u=42
304 like 298 but u=43
305 like 298 but u=44
306 like 298 but u=45
307 like 298 but u=46
308 like 298 but u=47
309 like 298 but u=48
c
c ----- BP Pins -----
351 20 9.0451E-02 -41 imp:n=1 u=50 $ 2.0%
352 like 351 but mat=21 rho=9.0501E-02 u=51 $ 2.5%
353 22 8.8747E-02 -42 imp:n=1 u=50 $ graphite disks
354 like 353 but u=51
355 20 9.0451E-02 -43 imp:n=1 u=50 $ 2.0%
356 like 355 but mat=21 rho=9.0501E-02 u=51 $ 2.5%
357 27 2.4616E-05 41 42 43 -44 imp:n=1 u=50 $ pin gap
358 like 357 but u=51
359 27 2.4616E-05 -44 imp:n=1 u=52 $ empty pin position
360 25 8.7804E-02 44 imp:n=1 u=50 $ graphite block
361 like 360 but u=51
362 like 360 but u=52
c
c ----- Dummy Blocks -----
380 27 2.4616E-05 -301 imp:n=1 u=400
381 27 2.4616E-05 -302 imp:n=1 u=400
382 27 2.4616E-05 -303 imp:n=1 u=400
383 28 8.7305E-02 301 302 303 -502 imp:n=1 u=400
384 27 2.4616E-05 502 imp:n=1 u=400
c
c ----- Blocks -----
401 25 8.7804E-02 -501 imp:n=1 u=61 lat=2 fill= -5:5 -5:5 0:0 $ Zone 1 Lvl 4/5
    61 10r
    61 10r
    61 4r      50 37 37 37      61 1r
    61 3r      37 37 37 37 37    61 1r
    61 2r      37 37 37 37 37 37 61 1r

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

61 1r 37 37 37 61 37 37 52 61 1r
61 1r 37 37 37 37 37 37 61 2r
61 1r 37 37 37 37 37 61 3r
61 1r 50 37 37 37 61 4r
61 10r
61 10r
402 25 8.7804E-02 -501 imp:n=1 u=62 lat=2 fill= -5:5 -5:5 0:0 $ Zone 1 Lvl 3
62 10r
62 10r
62 4r 51 39 39 39 62 1r
62 3r 39 39 39 39 39 62 1r
62 2r 39 39 39 39 39 39 62 1r
62 1r 39 39 39 62 39 39 52 62 1r
62 1r 39 39 39 39 39 39 62 2r
62 1r 39 39 39 39 39 62 3r
62 1r 51 39 39 39 62 4r
62 10r
62 10r
403 25 8.7804E-02 -501 imp:n=1 u=63 lat=2 fill= -5:5 -5:5 0:0 $ Zone 1 Lvl 2
63 10r
63 10r
63 4r 51 41 41 41 63 1r
63 3r 41 41 41 41 41 63 1r
63 2r 41 41 41 41 41 41 63 1r
63 1r 41 41 41 63 41 41 52 63 1r
63 1r 41 41 41 41 41 41 63 2r
63 1r 41 41 41 41 41 63 3r
63 1r 51 41 41 41 63 4r
63 10r
63 10r
404 25 8.7804E-02 -501 imp:n=1 u=64 lat=2 fill= -5:5 -5:5 0:0 $ Zone 1 Lvl 1
64 10r
64 10r
64 4r 50 44 44 44 64 1r
64 3r 44 44 44 44 44 64 1r
64 2r 44 44 44 44 44 44 64 1r
64 1r 44 44 44 64 44 44 52 64 1r
64 1r 44 44 44 44 44 44 64 2r
64 1r 44 44 44 44 44 64 3r
64 1r 50 44 44 44 64 4r
64 10r
64 10r
405 25 8.7804E-02 -501 imp:n=1 u=65 lat=2 fill= -5:5 -5:5 0:0 $ Zone 2 Lvl 4/5
65 10r
65 10r
65 4r 50 38 38 38 65 1r
65 3r 38 38 38 38 38 65 1r
65 2r 38 38 38 38 38 38 65 1r
65 1r 38 38 38 65 38 38 52 65 1r
65 1r 38 38 38 38 38 38 65 2r
65 1r 38 38 38 38 38 65 3r
65 1r 50 38 38 38 65 4r
65 10r
65 10r
406 25 8.7804E-02 -501 imp:n=1 u=66 lat=2 fill= -5:5 -5:5 0:0 $ Zone 2 Lvl 3
66 10r
66 10r
66 4r 51 41 41 41 66 1r
66 3r 41 41 41 41 41 66 1r
66 2r 41 41 41 41 41 41 66 1r
66 1r 41 41 41 66 41 41 52 66 1r
66 1r 41 41 41 41 41 41 66 2r
66 1r 41 41 41 41 41 66 3r
66 1r 51 41 41 41 66 4r
66 10r
66 10r
407 25 8.7804E-02 -501 imp:n=1 u=67 lat=2 fill= -5:5 -5:5 0:0 $ Zone 2 Lvl 2
67 10r
67 10r
67 4r 51 43 43 43 67 1r
67 3r 43 43 43 43 43 67 1r
67 2r 43 43 43 43 43 43 67 1r
67 1r 43 43 43 67 43 43 52 67 1r
67 1r 43 43 43 43 43 43 67 2r
67 1r 43 43 43 43 43 67 3r
67 1r 51 43 43 43 67 4r

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

67 10r
67 10r
408 25 8.7804E-02 -501 imp:n=1 u=68 lat=2 fill= -5:5 -5:5 0:0 $ Zone 2 Lvl 1
68 10r
68 10r
68 4r      50 46 46 46      68 1r
68 3r      46 46 46 46 46    68 1r
68 2r      46 46 46 46 46 46 68 1r
68 1r 46 46 46 46 68 46 46 52 68 1r
68 1r 46 46 46 46 46 46 68 2r
68 1r      46 46 46 46 46    68 3r
68 1r      50 46 46 46      68 4r
68 10r
68 10r
409 25 8.7804E-02 -501 imp:n=1 u=69 lat=2 fill= -5:5 -5:5 0:0 $ Zone 3 Lvl 4/5
69 10r
69 10r
69 4r      50 39 39 69      69 1r
69 3r      39 39 39 39 39    69 1r
69 2r      39 39 39 39 39 39 69 1r
69 1r 39 39 39 69 39 39 52 69 1r
69 1r 39 39 39 39 39 39 69 2r
69 1r      39 39 39 39 39    69 3r
69 1r      50 39 39 69      69 4r
69 10r
69 10r
410 25 8.7804E-02 -501 imp:n=1 u=70 lat=2 fill= -5:5 -5:5 0:0 $ Zone 3 Lvl 3
70 10r
70 10r
70 4r      51 42 42 70      70 1r
70 3r      42 42 42 42 42    70 1r
70 2r      42 42 42 42 42 42 70 1r
70 1r 42 42 42 70 42 42 52 70 1r
70 1r 42 42 42 42 42 42 70 2r
70 1r      42 42 42 42 42    70 3r
70 1r      51 42 42 70      70 4r
70 10r
70 10r
411 25 8.7804E-02 -501 imp:n=1 u=71 lat=2 fill= -5:5 -5:5 0:0 $ Zone 3 Lvl 2
71 10r
71 10r
71 4r      51 45 45 71      71 1r
71 3r      45 45 45 45 45    71 1r
71 2r      45 45 45 45 45 45 71 1r
71 1r 45 45 45 71 45 45 52 71 1r
71 1r 45 45 45 45 45 45 71 2r
71 1r      45 45 45 45 45    71 3r
71 1r      51 45 45 71      71 4r
71 10r
71 10r
412 25 8.7804E-02 -501 imp:n=1 u=72 lat=2 fill= -5:5 -5:5 0:0 $ Zone 3 Lvl 1
72 10r
72 10r
72 4r      50 47 47 72      72 1r
72 3r      47 47 47 47 47    72 1r
72 2r      47 47 47 47 47 47 72 1r
72 1r 47 47 47 72 47 47 52 72 1r
72 1r 47 47 47 47 47 47 72 2r
72 1r      47 47 47 47 47    72 3r
72 1r      50 47 47 72      72 4r
72 10r
72 10r
413 25 8.7804E-02 -501 imp:n=1 u=73 lat=2 fill= -5:5 -5:5 0:0 $ Zone 4 Lvl 4/5
73 10r
73 10r
73 4r      50 40 40 73      73 1r
73 3r      40 40 40 40 40    73 1r
73 2r      40 40 40 40 40 40 73 1r
73 1r 40 40 40 73 40 40 52 73 1r
73 1r 40 40 40 40 40 40 73 2r
73 1r      40 40 40 40 40    73 3r
73 1r      50 40 40 73      73 4r
73 10r
73 10r
414 25 8.7804E-02 -501 imp:n=1 u=74 lat=2 fill= -5:5 -5:5 0:0 $ Zone 4 Lvl 3
74 10r

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

74 10r
74 4r      51 43 43 74      74 1r
74 3r      43 43 43 43 43    74 1r
74 2r      43 43 43 43 43    74 1r
74 1r 43 43 43 43 74 43 43 52 74 1r
74 1r      43 43 43 43 43    74 2r
74 1r      43 43 43 43 43    74 3r
74 1r      51 43 43 74      74 4r
74 10r
74 10r
415 25 8.7804E-02 -501 imp:n=1 u=75 lat=2 fill= -5:5 -5:5 0:0 $ Zone 4 Lvl 2
75 10r
75 10r
75 4r      51 46 46 75      75 1r
75 3r      46 46 46 46 46    75 1r
75 2r      46 46 46 46 46    75 1r
75 1r 46 46 46 75 46 46 52 75 1r
75 1r      46 46 46 46 46    75 2r
75 1r      46 46 46 46 46    75 3r
75 1r      51 46 46 75      75 4r
75 10r
75 10r
416 25 8.7804E-02 -501 imp:n=1 u=76 lat=2 fill= -5:5 -5:5 0:0 $ Zone 4 Lvl 1
76 10r
76 10r
76 4r      50 48 48 76      76 1r
76 3r      48 48 48 48 48    76 1r
76 2r      48 48 48 48 48    76 1r
76 1r 48 48 48 76 48 48 52 76 1r
76 1r      48 48 48 48 48    76 2r
76 1r      48 48 48 48 48    76 3r
76 1r      50 48 48 76      76 4r
76 10r
76 10r
451 0 -502 imp:n=1 u=81 fill=61
452 like 451 but u=82 fill=62
453 like 451 but u=83 fill=63
454 like 451 but u=84 fill=64
455 like 451 but u=85 fill=65
456 like 451 but u=86 fill=66
457 like 451 but u=87 fill=67
458 like 451 but u=88 fill=68
459 like 451 but u=89 fill=69
460 like 451 but u=90 fill=70
461 like 451 but u=91 fill=71
462 like 451 but u=92 fill=72
463 like 451 but u=93 fill=73
464 like 451 but u=94 fill=74
465 like 451 but u=95 fill=75
466 like 451 but u=96 fill=76
467 27 2.4616E-05 502 imp:n=1 u=81
468 like 467 but u=82
469 like 467 but u=83
470 like 467 but u=84
471 like 467 but u=85
472 like 467 but u=86
473 like 467 but u=87
474 like 467 but u=88
475 like 467 but u=89
476 like 467 but u=90
477 like 467 but u=91
478 like 467 but u=92
479 like 467 but u=93
480 like 467 but u=94
481 like 467 but u=95
482 like 467 but u=96
c
c ----- Reflectors -----
483 27 2.4616E-05 -201 imp:n=1 u=97 $ coolant channels
484 25 8.7804E-02 201 imp:n=1 u=97 $ graphite block
485 25 8.7804E-02 -501 imp:n=1 u=98 lat=2 fill= -5:5 -5:5 0:0 $ 33-hole
98 10r
98 10r
98 4r      98 97 97 97      98 1r
98 3r      97 97 97 97 97    98 1r
98 2r      97 97 97 97 97    98 1r

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

98 1r 97 97 97 98 97 97 98 98 1r
98 1r 97 97 97 97 97 97 98 2r
98 1r 97 97 97 97 97 98 3r
98 1r 98 97 97 97 98 4r
98 10r
98 10r
486 25 8.7804E-02 -501 imp:n=1 u=99 lat=2 fill= -5:5 -5:5 0:0 $ 31-hole
99 10r
99 10r
99 4r 99 97 97 99 99 1r
99 3r 97 97 97 97 97 99 1r
99 2r 97 97 97 97 97 97 99 1r
99 1r 97 97 97 99 97 97 99 99 1r
99 1r 97 97 97 97 97 97 99 2r
99 1r 97 97 97 97 97 99 3r
99 1r 99 97 97 99 99 4r
99 10r
99 10r
489 0 -502 imp:n=1 u=100 fill=98
490 0 -502 imp:n=1 u=101 fill=99
491 like 467 but u=100
492 like 467 but u=101
c
c ----- Columns -----
500 27 2.4616E-05 -503 imp:n=1 u=401 lat=2 fill= -1:1 -1:1 -5:5 $ Dummy Zone
401 401 401 401 401 401 401 401 401
401 401 401 401 100 401 401 401 401
401 401 401 401 100 401 401 401 401
401 401 401 401 400 401 401 401 401
401 401 401 401 400 401 401 401 401
401 401 401 401 400 401 401 401 401
401 401 401 401 400 401 401 401 401
401 401 401 401 400 401 401 401 401
401 401 401 401 100 401 401 401 401
401 401 401 401 100 401 401 401 401
401 401 401 401 401 401 401 401 401
501 27 2.4616E-05 -503 imp:n=1 u=121 lat=2 fill= -1:1 -1:1 -5:5 $ Zone 1
121 121 121 121 121 121 121 121 121
121 121 121 121 100 121 121 121 121
121 121 121 121 100 121 121 121 121
121 121 121 121 81 121 121 121 121
121 121 121 121 81 121 121 121 121
121 121 121 121 82 121 121 121 121
121 121 121 121 83 121 121 121 121
121 121 121 121 84 121 121 121 121
121 121 121 121 100 121 121 121 121
121 121 121 121 100 121 121 121 121
121 121 121 121 121 121 121 121 121
502 27 2.4616E-05 -503 imp:n=1 u=122 lat=2 fill= -1:1 -1:1 -5:5 $ Zone 2
122 122 122 122 122 122 122 122 122
122 122 122 122 100 122 122 122 122
122 122 122 122 100 122 122 122 122
122 122 122 122 85 122 122 122 122
122 122 122 122 85 122 122 122 122
122 122 122 122 86 122 122 122 122
122 122 122 122 87 122 122 122 122
122 122 122 122 88 122 122 122 122
122 122 122 122 100 122 122 122 122
122 122 122 122 100 122 122 122 122
122 122 122 122 122 122 122 122 122
503 27 2.4616E-05 -503 imp:n=1 u=123 lat=2 fill= -1:1 -1:1 -5:5 $ Zone 3
123 123 123 123 123 123 123 123 123
123 123 123 123 100 123 123 123 123
123 123 123 123 100 123 123 123 123
123 123 123 123 89 123 123 123 123
123 123 123 123 89 123 123 123 123
123 123 123 123 90 123 123 123 123
123 123 123 123 91 123 123 123 123
123 123 123 123 92 123 123 123 123
123 123 123 123 101 123 123 123 123
123 123 123 123 101 123 123 123 123
123 123 123 123 123 123 123 123 123
504 27 2.4616E-05 -503 imp:n=1 u=124 lat=2 fill= -1:1 -1:1 -5:5 $ Zone 4
124 124 124 124 124 124 124 124 124
124 124 124 124 100 124 124 124 124
124 124 124 124 100 124 124 124 124

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

124 124 124 124 93 124 124 124 124
124 124 124 124 93 124 124 124 124
124 124 124 124 94 124 124 124 124
124 124 124 124 95 124 124 124 124
124 124 124 124 96 124 124 124 124
124 124 124 124 101 124 124 124 124
124 124 124 124 101 124 124 124 124
124 124 124 124 124 124 124 124 124
525 0 -950 imp:n=1 u=125 fill=121 $ B04
526 like 525 but u=126 fill=121 *trcl=(0 0 0 180 90 90 270 180 90 90 90 0) $ B01
527 like 525 but u=127 fill=121 *trcl=(0 0 0 120 30 90 210 120 90 90 90 0) $ B02
528 like 525 but u=128 fill=121 *trcl=(0 0 0 60 330 90 150 60 90 90 90 0) $ B03
529 like 525 but u=129 fill=121 *trcl=(0 0 0 300 210 90 30 300 90 90 90 0) $ B05
530 like 525 but u=130 fill=121 *trcl=(0 0 0 240 150 90 330 240 90 90 90 0) $ B06
531 0 -950 imp:n=1 u=131 fill=122 $ C02
532 like 531 but u=132 fill=122 *trcl=(0 0 0 300 210 90 30 300 90 90 90 0) $ C04
533 like 531 but u=133 fill=122 *trcl=(0 0 0 240 150 90 330 240 90 90 90 0) $ C06
534 like 531 but u=134 fill=122 *trcl=(0 0 0 180 90 90 270 180 90 90 90 0) $ C08
535 like 531 but u=135 fill=122 *trcl=(0 0 0 120 30 90 210 120 90 90 90 0) $ C10
536 like 531 but u=136 fill=122 *trcl=(0 0 0 60 330 90 150 60 90 90 90 0) $ C12
537 0 -950 imp:n=1 u=137 fill=123 $ D05/09
538 like 537 but u=138 fill=123 *trcl=(0 0 0 60 330 90 150 60 90 90 90 0) $ D02/06
539 like 537 but u=139 fill=123 *trcl=(0 0 0 120 30 90 210 120 90 90 90 0) $ D03/17
540 like 537 but u=140 fill=123 *trcl=(0 0 0 300 210 90 30 300 90 90 90 0) $ D08/12
541 like 537 but u=141 fill=123 *trcl=(0 0 0 240 150 90 330 240 90 90 90 0) $ D11/15
542 like 537 but u=142 fill=123 *trcl=(0 0 0 180 90 90 270 180 90 90 90 0) $ D14/18
543 0 -950 imp:n=1 u=143 fill=124 $ D07
544 like 543 but u=144 fill=124 *trcl=(0 0 0 120 30 90 210 120 90 90 90 0) $ D01
545 like 543 but u=145 fill=124 *trcl=(0 0 0 60 330 90 150 60 90 90 90 0) $ D04
546 like 543 but u=146 fill=124 *trcl=(0 0 0 300 210 90 30 300 90 90 90 0) $ D10
547 like 543 but u=147 fill=124 *trcl=(0 0 0 240 150 90 330 240 90 90 90 0) $ D13
548 like 543 but u=148 fill=124 *trcl=(0 0 0 180 90 90 270 180 90 90 90 0) $ D16
c
c --- Control Column -----
c ----- Control Rod Segments -----
601 24 8.7530E-02 -103 imp:n=1 u=150 $ spine
602 27 2.4616E-05 103 -104 imp:n=1 u=150 $ helium gap
603 24 8.7530E-02 104 -101 imp:n=1 u=150 $ inner clad
604 23 9.8436E-02 101 -102 imp:n=1 u=150 $ absorber
605 24 8.7530E-02 102 -105 imp:n=1 u=150 $ outer clad
606 27 2.4616E-05 105 imp:n=1 u=150 $ helium
607 0 -151 imp:n=1 u=151 lat=2 fill=150 $ rod segment
608 0 -152 imp:n=1 u=152 fill=151 $ control rod
609 27 2.4616E-05 152 imp:n=1 u=152 $ helium
c
c ----- Positions -----
610 0 -999 imp:n=1 u=153 fill=152 (0 0 189.9) $ C
611 0 -154 imp:n=1 u=154 fill=153 (10.8 0 0)
612 0 -155 imp:n=1 u=154 fill=153 (-5.4 -9.35307 0)
613 27 2.4616E-05 -156 imp:n=1 u=154 $ RSS
614 like 610 but u=155 fill=152 (0 0 189.9) $ R1
615 like 611 but u=156 fill=155 (10.8 0 0)
616 like 612 but u=156 fill=155 (-5.4 -9.35307 0)
617 like 613 but u=156
618 like 610 but u=157 fill=152 (0 0 189.9) $ R2
619 like 611 but u=158 fill=157 (10.8 0 0)
620 like 612 but u=158 fill=157 (-5.4 -9.35307 0)
621 like 613 but u=158
622 like 610 but u=159 fill=152 (0 0 405) $ R3
623 like 611 but u=160 fill=159 (10.8 0 0)
624 like 612 but u=160 fill=159 (-5.4 -9.35307 0)
625 like 613 but u=160
c
c ----- C Column -----
626 25 8.7804E-02 154 155 156 -550 imp:n=1 u=154 $ graphite blocks
627 27 2.4616E-05 550 imp:n=1 u=154
628 0 -950 imp:n=1 u=161 fill=154 $ A01
c
c ----- R1 Columns -----
629 25 8.7804E-02 154 155 156 -550 imp:n=1 u=156 $ graphite blocks
630 like 627 but u=156
631 like 628 but u=162 fill=156 $ C01
632 like 631 but u=163 *trcl=(0 0 0 300 210 90 30 300 90 90 90 0) $ C03
633 like 631 but u=164 *trcl=(0 0 0 240 150 90 330 240 90 90 90 0) $ C05
634 like 631 but u=165 *trcl=(0 0 0 180 90 90 270 180 90 90 90 0) $ C07
635 like 631 but u=166 *trcl=(0 0 0 120 30 90 210 120 90 90 90 0) $ C09

```



## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

636 like 631 but u=167 *trcl=(0 0 0 60 330 90 150 60 90 90 90 0) $ C11
c
c ----- R2 Columns -----
637 25 8.7804E-02 154 155 156 -550 imp:n=1 u=158 $ graphite blocks
638 like 627 but u=158
639 like 628 but u=168 fill=158 $ E23
640 like 639 but u=169 *trcl=(0 0 0 300 210 90 30 300 90 90 90 0) $ E03
641 like 639 but u=170 *trcl=(0 0 0 240 150 90 330 240 90 90 90 0) $ E07
642 like 639 but u=171 *trcl=(0 0 0 180 90 90 270 180 90 90 90 0) $ E11
643 like 639 but u=172 *trcl=(0 0 0 120 30 90 210 120 90 90 90 0) $ E15
644 like 639 but u=173 *trcl=(0 0 0 60 330 90 150 60 90 90 90 0) $ E19
c
c ----- R3 Columns -----
645 25 8.7804E-02 154 155 156 -550 imp:n=1 u=160 $ graphite blocks
646 like 627 but u=160
647 like 628 but u=174 fill=160 $ E01
648 like 647 but u=175 *trcl=(0 0 0 240 150 90 330 240 90 90 90 0) $ E09
649 like 647 but u=176 *trcl=(0 0 0 120 30 90 210 120 90 90 90 0) $ E17
c
c --- Instrumentation Column -----
c ----- Positions -----
661 27 2.4616E-05 -155 imp:n=1 u=181
662 27 2.4616E-05 -154 imp:n=1 u=181
663 27 2.4616E-05 -156 imp:n=1 u=181
c
c ----- Columns -----
664 25 8.7804E-02 154 155 156 -550 imp:n=1 u=181 $ graphite blocks
665 like 627 but u=181
666 0 -950 imp:n=1 u=182 fill=181
c
c --- Reflector Column -----
c ----- Columns -----
671 25 8.7804E-02 -550 imp:n=1 u=183 $ graphite blocks
672 like 627 but u=183
673 0 -950 imp:n=1 u=184 fill=183
c
c --- HTTR Core -----
c ----- Core Map -----
701 26 8.6134E-02 -551 imp:n=1 lat=2 u=200 fill=-6:6 -6:6 0:0
    200 12r
    200 12r
    200 5r      175 184 170 184 182      200 1r
    200 4r      184 143 138 137 145 184      200 1r
    200 3r      171 140 164 132 163 139 169      200 1r
    200 2r      184 137 133 128 401 131 138 184      200 1r
    200 1r      182 146 165 401 161 126 162 144 174      200 1r
    200 1r      184 141 134 129 401 136 142 184      200 2r
    200 1r      172 140 166 135 167 139 168      200 3r
    200 1r      184 147 142 141 148 184      200 4r
    200 1r      176 184 173 184 182      200 5r
    200 12r
    200 12r

c
c ----- Core Map Legend ---
c   u 12r
c   u 12r
c   u 5r      Z G Y G I      u 1r
c   u 4r      G 4 3 3 4 G      u 1r
c   u 3r      Y 3 X 2 X 3 Y      u 1r
c   u 2r      G 3 2 1 D 2 3 G      u 1r
c   u 1r      I 4 X D C 1 X 4 Z      u 1r
c   u 1r      G 3 2 1 D 2 3 G      u 2r
c   u 1r      Y 3 X 2 X 3 Y      u 3r
c   u 1r      G 4 3 3 4 G      u 4r
c   u 1r      Z G Y G I      u 5r
c   u 12r
c   u 12r

c
c   1 = Fuel Columns #1
c   2 = Fuel Columns #2
c   3 = Fuel Columns #3
c   4 = Fuel Columns #4
c   D = Dummy Fuel Columns
c   C = Central Control Column
c   X = R1 Control Columns
c   Y = R2 Control Columns

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

c      Z = R3 Control Columns
c      I = Instrumentation Columns
c      G = Removable Reflector Columns
c
702  0  -602 imp:n=1 fill=200
c
c --- Permanent Reflector -----
711  26 8.6134E-02 602 -651 imp:n=1
c
c --- The Great Void -----
999  0 651 imp:n=0
c

c Surface Cards *****
c --- Fuel Blocks -----
c ----- TRISO Particles -----
1    so 0.03  $ UO2 kernal
2    so 0.036 $ buffer
3    so 0.039 $ IPyC
4    so 0.0415 $ SiC
5    so 0.046 $ OPyC
6    so 0.066 $ overcoat
901  px -0.125
902  px  0.125
903  py -0.125
904  py  0.125
905  pz -0.125
906  pz  0.125
c
c ----- Compacts -----
911  px -0.053
912  px  0.053
913  py -0.053
914  py  0.053
915  pz -0.05
916  pz  0.05
921  px -1.31
922  px  1.31
923  py -1.31
924  py  1.31
925  pz -0.05
926  pz  0.05
12   rcc 0 0 -27.3 0 0 54.6 0.5 $ inside
13   rcc 0 0 -27.3 0 0 54.6 1.3 $ outside
c
c ----- Fuel Pins -----
21   rcc 0 0 -27.45 0 0 54.9 1.325 $ inside
22   rcc 0 0 -28.85 0 0 57.7 1.7  $ outside
c
c ----- Coolant Channels -----
31   rcc 0 0 -31 0 0 62 2.05
c
c ----- BP Pins -----
41   rcc 0 0 -25 0 0 20 0.7  $ BP
42   rcc 0 0 -5 0 0 10 0.7  $ graphite
43   rcc 0 0  5 0 0 20 0.7  $ BP
44   rcc 0 0 -25 0 0 50 0.75 $ pin
c
c --- Control Blocks -----
c ----- Control Rod Segments -----
101  rcc 0 0 11 0 0 29 3.75 $ inside
102  rcc 0 0 11 0 0 29 5.25 $ outside
103  rcc 0 0 11 0 0 29 0.5 $ spine
104  rcc 0 0 11 0 0 29 3.25 $ inside clad
105  rcc 0 0 10 0 0 31 5.65 $ outside clad
c
c ----- Positions -----
151  hex 0 0 10 0 0 31 10 $ "box"
152  rcc 0 0 -145 0 0 310 6.30 $ control rod
154  rcc 10.8 0 -155 0 0 416 6.15 $ control rod hole
155  rcc -5.4 -9.35307 -155 0 0 416 6.15 $ control rod hole
156  rcc -5.4 9.35307 -155 0 0 416 6.15 $ control rod hole
c
c --- Reflector Blocks -----
c ----- Coolant Channels -----
201  rcc 0 0 -31 0 0 62 1.15

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

c
c --- Dummy Blocks -----
c ----- Coolant Channels -----
301 rcc -10.8 0 -29.5 0 0 59 6.15
302 rcc 5.4 9.35307 -29.5 0 0 59 6.15
303 rcc 5.4 -9.35307 -29.5 0 0 59 6.15
c
c --- Blocks -----
501 hex 0 0 -30 0 0 60 2.575 0 0 $ pitch
502 hex 0 0 -29.5 0 0 59 0 18 0 $ graphite
503 hex 0 0 -29 0 0 58 0 18.2 0 $ helium
c
c --- Columns -----
550 hex 0 0 -261.5 0 0 523 0 18 0
551 hex 0 0 -261 0 0 522 0 18.1 0
c
c --- HTTR Core -----
602 hex 0 0 -261 0 0 522 -148 0 0
c
c --- Permanent Reflector -----
651 rcc 0 0 -261 0 0 522 212.5
c
c --- Auxiliary Organization -----
950 rcc 0 0 -1000 0 0 2000 25 $ small cylinder
999 rcc 0 0 -2500 0 0 5000 2500 $ big cylinder
c

c Data Cards *****
c --- Material Cards -----
c ----- Kernel (3.4%) -----
m1 5010.00c 1.7299E-07
    8016.00c 4.6386E-02
    8017.00c 1.7633E-05
    92234.00c 6.1026E-06
    92235.00c 7.9888E-04
    92238.00c 2.2405E-02
c   Total      6.9614E-02
mt1 OU02.00t
    UU02.00t
c
c ----- Kernel (3.9%) -----
m2 5010.00c 1.7299E-07
    8016.00c 4.6386E-02
    8017.00c 1.7633E-05
    92234.00c 7.0000E-06
    92235.00c 9.1637E-04
    92238.00c 2.2288E-02
c   Total      6.9616E-02
mt2 OU02.00t
    UU02.00t
c
c ----- Kernel (4.3%) -----
m3 5010.00c 1.7299E-07
    8016.00c 4.6386E-02
    8017.00c 1.7633E-05
    92234.00c 7.7180E-06
    92235.00c 1.0104E-03
    92238.00c 2.2195E-02
c   Total      6.9617E-02
mt3 OU02.00t
    UU02.00t
c
c ----- Kernel (4.8%) -----
m4 5010.00c 1.7299E-07
    8016.00c 4.6386E-02
    8017.00c 1.7633E-05
    92234.00c 8.6154E-06
    92235.00c 1.1278E-03
    92238.00c 2.2078E-02
c   Total      6.9618E-02
mt4 OU02.00t
    UU02.00t
c
c ----- Kernel (5.2%) -----
m5 5010.00c 1.7299E-07
    8016.00c 4.6386E-02

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

      8017.00c 1.7633E-05
      92234.00c 9.3334E-06
      92235.00c 1.2218E-03
      92238.00c 2.1984E-02
c      Total      6.9619E-02
mt5    OUO2.00t
      UUO2.00t

c
c ----- Kernel (5.9%) -----
m6      5010.00c 1.7299E-07
      8016.00c 4.6386E-02
      8017.00c 1.7633E-05
      92234.00c 1.0590E-05
      92235.00c 1.3863E-03
      92238.00c 2.1821E-02
c      Total      6.9622E-02
mt6    OUO2.00t
      UUO2.00t

c
c ----- Kernel (6.3%) -----
m7      5010.00c 1.7299E-07
      8016.00c 4.6386E-02
      8017.00c 1.7633E-05
      92234.00c 1.1308E-05
      92235.00c 1.4803E-03
      92238.00c 2.1727E-02
c      Total      6.9623E-02
mt7    OUO2.00t
      UUO2.00t

c
c ----- Kernel (6.7%) -----
m8      5010.00c 1.7299E-07
      8016.00c 4.6386E-02
      8017.00c 1.7633E-05
      92234.00c 1.2026E-05
      92235.00c 1.5743E-03
      92238.00c 2.1634E-02
c      Total      6.9624E-02
mt8    OUO2.00t
      UUO2.00t

c
c ----- Kernel (7.2%) -----
m9      5010.00c 1.7299E-07
      8016.00c 4.6386E-02
      8017.00c 1.7633E-05
      92234.00c 1.2923E-05
      92235.00c 1.6918E-03
      92238.00c 2.1517E-02
c      Total      6.9625E-02
mt9    OUO2.00t
      UUO2.00t

c
c ----- Kernel (7.9%) -----
m10     5010.00c 1.7299E-07
      8016.00c 4.6386E-02
      8017.00c 1.7633E-05
      92234.00c 1.4180E-05
      92235.00c 1.8562E-03
      92238.00c 2.1353E-02
c      Total      6.9628E-02
mt10    OUO2.00t
      UUO2.00t

c
c ----- Kernel (9.4%) -----
m11     5010.00c 1.7299E-07
      8016.00c 4.6386E-02
      8017.00c 1.7633E-05
      92234.00c 1.6872E-05
      92235.00c 2.2087E-03
      92238.00c 2.1002E-02
c      Total      6.9632E-02
mt11    OUO2.00t
      UUO2.00t

c
c ----- Kernel (9.9%) -----
m12     5010.00c 1.7299E-07

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

      8016.00c 4.6386E-02
      8017.00c 1.7633E-05
      92234.00c 1.7769E-05
      92235.00c 2.3262E-03
      92238.00c 2.0886E-02
c      Total      6.9634E-02
mt12  OU02.00t
      UU02.00t
c
c ----- Buffer Layer -----
m13   5010.00c 1.8290E-08
      6000.00c 5.5153E-02
c      Total      5.5153E-02
mt13  Graph.00t
c
c ----- IPyC Layer -----
m14   5010.00c 3.0761E-08
      6000.00c 9.2758E-02
c      Total      9.2758E-02
mt14  Graph.00t
c
c ----- SiC Layer -----
m15   5010.00c 5.3208E-08
      6000.00c 4.8061E-02
      14028.00c 4.4327E-02
      14029.00c 2.2508E-03
      14030.00c 1.4837E-03
c      Total      9.6122E-02
mt15  Graph.00t
c
c ----- OPyC Layer -----
m16   5010.00c 3.0761E-08
      6000.00c 9.2758E-02
c      Total      9.2758E-02
mt16  Graph.00t
c
c ----- Graphite Overcoat -----
m17   5010.00c 2.8267E-08
      6000.00c 8.5237E-02
c      Total      8.5237E-02
mt17  Graph.00t
c
c ----- Graphite Compact -----
m18   5010.00c 1.5452E-08
      6000.00c 8.5237E-02
c      Total      8.5237E-02
mt18  Graph.00t
c
c ----- Graphite Sleeve -----
m19   5010.00c 7.2596E-09
      6000.00c 8.8747E-02
c      Total      8.8747E-02
mt19  Graph.00t
c
c ----- Burnable Poison (2.0%) -----
m20   5010.00c 3.9906E-04
      5011.00c 1.6063E-03
      6000.00c 8.8446E-02
c      Total      9.0451E-02
mt20  Graph.00t
c
c ----- Burnable Poison (2.5%) -----
m21   5010.00c 4.9882E-04
      5011.00c 2.0078E-03
      6000.00c 8.7995E-02
c      Total      9.0501E-02
mt21  Graph.00t
c
c ----- Graphite Disks -----
m22   5010.00c 7.2596E-09
      6000.00c 8.8747E-02
c      Total      8.8747E-02
mt22  Graph.00t
c
c ----- Neutron Absorber -----
m23   5010.00c 6.3184E-03

```

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATE

```

      5011.00c 2.5432E-02
      6000.00c 6.6685E-02
c      Total      9.8436E-02
mt23 Graph.00t
c
c ----- Alloy 800H -----
m24      6000.00c 3.2210E-04
      13027.00c 6.7209E-04
      14028.00c 5.5580E-04
      14029.00c 2.8222E-05
      14030.00c 1.8604E-05
      15031.00c 3.1225E-05
      16032.00c 1.4316E-05
      16033.00c 1.1462E-07
      16034.00c 6.4698E-07
      16036.00c 3.0162E-09
      22046.00c 3.1254E-05
      22047.00c 2.8186E-05
      22048.00c 2.7928E-04
      22049.00c 2.0495E-05
      22050.00c 1.9624E-05
      24050.00c 8.4860E-04
      24052.00c 1.6364E-02
      24053.00c 1.8556E-03
      24054.00c 4.6189E-04
      25055.00c 8.8022E-04
      26054.00c 2.2265E-03
      26056.00c 3.4951E-02
      26057.00c 8.0717E-04
      26058.00c 1.0742E-04
      28058.00c 1.8229E-02
      28060.00c 7.0217E-03
      28061.00c 3.0523E-04
      28062.00c 9.7320E-04
      28064.00c 2.4785E-04
      29063.00c 1.5791E-04
      29065.00c 7.0383E-05
c      Total      8.7530E-02
mt24      Fe.00t
      Al.00t
c
c ----- IG-110 Graphite -----
m25      5010.00c 1.1453E-08
      6000.00c 8.7804E-02
c      Total      8.7804E-02
mt25 Graph.00t
c
c ----- PGX Graphite -----
m26      5010.00c 3.6372E-08
      6000.00c 8.6134E-02
c      Total      8.6134E-02
mt26 Graph.00t
c
c ----- Helium Coolant -----
m27      2003.00c 3.3724E-11
      2004.00c 2.4616E-05
c      Total      2.4616E-05
c
c ----- IG-11 Graphite -----
m28      5010.00c 5.9835E-08
      6000.00c 8.7305E-02
c      Total      8.7305E-02
mt28 Graph.00t
c
c --- Control Cards -----
mode n
kcode 50000 1 50 1050
ksrc 93.545      0 -20 93.545      0 20
      -93.545      0 -20 -93.545      0 20
      55.050 76.350 -20 55.050 76.350 20
      -55.050 76.350 -20 -55.050 76.350 20
      55.050 -76.350 -20 55.050 -76.350 20
      -55.050 -76.350 -20 -55.050 -76.350 20
c print

```

## A.2 Buckling and Extrapolation Length Configurations

Buckling and extrapolation length measurements were not made.

## A.3 Spectral-Characteristics Configurations

Spectral characteristics measurements were not made.

## A.4 Reactivity-Effects Configurations

*MCNP5 Input Deck for the excess reactivity measurements of the HTTR:*

The input decks from the 30-fuel-column core configuration in [HTTR-GCR-RESR-001](#) and the 19-, 21-, 24-, and 27-fuel-column core configurations in this report are used to determine the excess reactivity of the HTTR core loading. Control rod positions are either fully withdrawn or adjusted to positions already reported in this report and [HTTR-GCR-RESR-001](#).

## A.5 Reactivity Coefficient Configurations

Reactivity coefficient measurements have not been evaluated.

## A.6 Kinetics Parameter Configurations

Kinetics measurements have not been evaluated.

## A.7 Reaction-Rate Configurations

*MCNP5 Input Deck for the axial neutron fission reaction rate in the instrumentation columns of the HTTR:*

The input deck used to determine the axial reaction rate in the instrumentation columns is that of either configuration 3 or 4 (the 24-fuel-column annular core) with the following appended coding to the end of the input deck:

```

c --- Tally Cards -----
c ----- Plutonium Foil in Fission Chamber -----
m101 92235.00c 1.
c
fmesh4:n geom cyl origin 114.6005 72.4 -261
        imesh 6.15 jmesh 522 jint 522 kmesh 1
fm4 (1 101 -6)
fmesh14:n geom cyl origin 5.4 -135.447 -261
        imesh 6.15 jmesh 522 jint 522 kmesh 1
fm14 (1 101 -6)
fmesh24:n geom cyl origin -120 63.04693 -261
        imesh 6.15 jmesh 522 jint 522 kmesh 1
fm24 (1 101 -6)
c

```

#### **A.8 Power Distribution Configuration**

Power distribution measurements were not made.

#### **A.9 Isotopic Configurations**

Isotopic measurements were not made.

#### **A.10 Configurations of Other Miscellaneous Types of Measurements**

Other miscellaneous types of measurements were not made.



**APPENDIX B: CALCULATED SPECTRAL DATA****B.1 Spectral Data for the Critical and Subcritical Configurations**

Data generated in the MCNP5 output files include information regarding the energy of the average lethargy causing fission (EALF) and the percentages of fission caused by thermal, intermediate, and fast energy neutrons for each case shown in Tables 4.1 through 4.5; results are shown in Tables B.1 through B.5, respectively. There was no significant difference in the spectra when using different neutron libraries. The MCNP5 calculations were performed with 1,050 generations (skipping the first 50) and 50,000 neutrons per generation. The only significant difference is that the EALF values are slightly elevated and the neutron fission spectra is distributed slightly more in the fast energy range in Case 4. This configuration uses only the control rods in the reflector region to manage core criticality whereas the other configurations typically remove the reflector rods and maintain criticality via the core control systems. The JENDL-3.3 analysis was performed with the inclusion of ENDF/B-VII.0 thermal neutron scattering data because it was not included in the JENDL-3.3 library.

Table B.1. Spectral Data for the HTTR Benchmark Model  
Evaluation using an Ordered Lattice (Case 1).

Neutron Cross-Section Library	EALF (eV)	Percentage of Neutrons Causing Fission		
		<0.625 eV	0.625 eV – 100 keV	>100 keV
ENDF/B-V.2	0.0776	92.36	6.73	0.91
ENDF/B-VI.8	0.0758	92.53	6.57	0.90
END/B-VII.0	0.0758	92.53	6.57	0.90
JEFF-3.1	0.0755	92.53	6.57	0.90
JENDL-3.3 with ENDF/B-VII.0 S( $\alpha,\beta$ )	0.0763	92.48	6.60	0.92

Table B.2. Spectral Data for the HTTR Benchmark Model  
Evaluation using an Ordered Lattice (Case 2).

Neutron Cross-Section Library	EALF (eV)	Percentage of Neutrons Causing Fission		
		<0.625 eV	0.625 eV – 100 keV	>100 keV
ENDF/B-V.2	0.0774	92.39	6.71	0.90
ENDF/B-VI.8	0.0757	92.56	6.55	0.89
END/B-VII.0	0.0758	92.56	6.55	0.90
JEFF-3.1	0.0754	92.56	6.55	0.89
JENDL-3.3 with ENDF/B-VII.0 S( $\alpha,\beta$ )	0.0761	92.52	6.57	0.91

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATETable B.3. Spectral Data for the HTTR Benchmark Model  
Evaluation using an Ordered Lattice (Case 3).

Neutron Cross-Section Library	EALF (eV)	Percentage of Neutrons Causing Fission		
		<0.625 eV	0.625 eV – 100 keV	>100 keV
ENDF/B-V.2	0.0775	92.41	6.69	0.90
ENDF/B-VI.8	0.0759	92.56	6.55	0.89
END/B-VII.0	0.0759	92.57	6.54	0.89
JEFF-3.1	0.0756	92.58	6.54	0.89
JENDL-3.3 with ENDF/B-VII.0 S( $\alpha,\beta$ )	0.0763	92.53	6.57	0.90

Table B.4. Spectral Data for the HTTR Benchmark Model  
Evaluation using an Ordered Lattice (Case 4).

Neutron Cross-Section Library	EALF (eV)	Percentage of Neutrons Causing Fission		
		<0.625 eV	0.625 eV – 100 keV	>100 keV
ENDF/B-V.2	0.0813	91.98	7.11	0.91
ENDF/B-VI.8	0.0795	92.15	6.94	0.90
END/B-VII.0	0.0797	92.14	6.95	0.91
JEFF-3.1	0.0792	92.16	6.94	0.90
JENDL-3.3 with ENDF/B-VII.0 S( $\alpha,\beta$ )	0.0800	92.11	6.98	0.92

Table B.5. Spectral Data for the HTTR Benchmark Model  
Evaluation using an Ordered Lattice (Case 5).

Neutron Cross-Section Library	EALF (eV)	Percentage of Neutrons Causing Fission		
		<0.625 eV	0.625 eV – 100 keV	>100 keV
ENDF/B-V.2	0.0769	92.52	6.58	0.90
ENDF/B-VI.8	0.0752	92.69	6.42	0.89
END/B-VII.0	0.0753	92.69	6.42	0.89
JEFF-3.1	0.0749	92.70	6.42	0.89
JENDL-3.3 with ENDF/B-VII.0 S( $\alpha,\beta$ )	0.0756	92.66	6.45	0.90

**APPENDIX C: DATA FROM THE 16<sup>TH</sup> EDITION CHART OF THE NUCLIDES<sup>a</sup>****C.1 Isotopic Abundances and Atomic Weights**

This evaluation incorporated atomic weights and isotopic abundances found in the 16<sup>th</sup> edition of the Chart of the Nuclides. A list of the values used in the benchmark model or in the generation of the MCNP input deck is compiled in Table C.1.

Table C.1. Summary of Data Employed from the 16<sup>th</sup> Ed. of the Chart of the Nuclides.

Isotope or Element	Atomic Weight	Isotopic Abundance
He	4.002602	--
<sup>3</sup> He	--	0.000137
<sup>4</sup> He	--	99.999863
<sup>10</sup> B	10.0129370	19.9
<sup>11</sup> B	11.0093055	80.1
C	12.0107	--
N	14.0067	--
<sup>14</sup> N	--	99.632
<sup>15</sup> N	--	0.368
O	15.9994	--
<sup>16</sup> O	--	99.757
<sup>17</sup> O	--	0.038
<sup>18</sup> O <sup>(a)</sup>	--	0.205
Na	22.989770	--
Al	26.981538	--
Si	28.0855	--
<sup>28</sup> Si	--	92.2297
<sup>29</sup> Si	--	4.6832
<sup>30</sup> Si	--	3.0872
P	30.973761	--
S	32.065	--
<sup>32</sup> S	--	94.93
<sup>33</sup> S	--	0.76
<sup>34</sup> S	--	4.29
<sup>36</sup> S	--	0.02
Ca	40.078	--

<sup>a</sup> Nuclides and Isotopes: Chart of the Nuclides, 16<sup>th</sup> edition, (2002).

## Gas Cooled (Thermal) Reactor - GCR

HTTR-GCR-RESR-002  
CRIT-REAC-RRATETable C.1 (cont'd.). Summary of Data Employed  
from the 16<sup>th</sup> Ed. of the Chart of the Nuclides.

Isotope or Element	Atomic Weight	Isotopic Abundance
<sup>40</sup> Ca	--	96.941
<sup>42</sup> Ca	--	0.647
<sup>43</sup> Ca	--	0.135
<sup>44</sup> Ca	--	2.086
<sup>46</sup> Ca	--	0.004
<sup>48</sup> Ca	--	0.187
Ti	47.867	--
<sup>46</sup> Ti	--	8.25
<sup>47</sup> Ti	--	7.44
<sup>48</sup> Ti	--	73.72
<sup>49</sup> Ti	--	5.41
<sup>50</sup> Ti	--	5.18
Cr	51.9961	--
<sup>50</sup> Cr	--	4.345
<sup>52</sup> Cr	--	83.789
<sup>53</sup> Cr	--	9.501
<sup>54</sup> Cr	--	2.365
Mn	54.938049	--
Fe	55.845	--
<sup>54</sup> Fe	--	5.845
<sup>56</sup> Fe	--	91.754
<sup>57</sup> Fe	--	2.119
<sup>58</sup> Fe	--	0.282
Ni	58.6934	--
<sup>58</sup> Ni	--	68.0769
<sup>60</sup> Ni	--	26.2231
<sup>61</sup> Ni	--	1.1399
<sup>62</sup> Ni	--	3.6345
<sup>64</sup> Ni	--	0.9256
Cu	63.546	--
<sup>63</sup> Cu	--	69.17
<sup>65</sup> Cu	--	30.83

Table C.1 (cont'd.). Summary of Data Employed  
from the 16<sup>th</sup> Ed. of the Chart of the Nuclides.

Isotope or Element	Atomic Weight	Isotopic Abundance
<sup>234</sup> U	234.040946	0.0055 <sup>(b)</sup>
<sup>235</sup> U	235.043923	0.7200 <sup>(b)</sup>
<sup>238</sup> U	238.050783	99.2745 <sup>(b)</sup>

(a) Neutronically, <sup>18</sup>O is treated as <sup>16</sup>O.

(b) Natural isotopic abundance of U.